

APPENDIX C QRA KAPUNI WELLSITES – WORLEY

TODD ENERGY LTD

Kapuni Wellsites Quantitative Risk Assessment

610114-RPT-R0002
July 2022

Worley New Zealand Ltd
25 Gill Street, New Plymouth 4310
PO Box 705, New Plymouth 4340
New Zealand

Telephone +64-6-759 6300
Facsimile +64-6-759 6301

www.worley.com




Rev	Description	Originator	Reviewer	Worley Approver	Date	Client Approval	Date
A	Issued for Review/Comment	_____ Y Lee	_____ L Ong	_____ Y Lee	10/2020	_____	
0	Approved for Use	_____ Y Lee	_____ L Ong	_____ Y Lee	09/2021	_____	
1	Re-Approved for Use	 Y Lee	 O Kilian	 Y Lee	07/2022	_____	
		_____	_____	_____		_____	

TABLE OF CONTENTS

1.	ABBREVIATIONS	3
2.	INTRODUCTION	4
2.1	Background.....	4
2.2	Objective.....	4
2.3	Scope	4
2.4	Exclusions	5
2.5	QRA Study Cases.....	6
2.6	Site Overview.....	6
3.	METHODOLOGY	10
3.1	Assessment Tools	10
3.2	Assumptions	11
4.	HAZARD IDENTIFICATION	16
4.1	Hazardous Materials.....	16
4.2	Isolatable Sections and Inventory	16
5.	RISK ASSESSMENT CRITERIA	18
6.	WELLSITE KA-1, KA-7, KA-19 AND KA-20	19
6.1	Release Scenarios	19
6.2	Release Frequency.....	21
6.3	Risk Results	22
6.4	Risk Contributors	24
7.	WELLSITE KA-2	27
7.1	Release Scenarios	27
7.2	Release Frequency.....	30
7.3	Risk Results	31
7.4	Risk Contributors	31
8.	WELLSITE KA-4 AND KA-14	34
8.1	Release Scenarios	34
8.2	Release Frequency.....	36
8.3	Risk Results	37
8.4	Risk Contributors	38
9.	WELLSITE KA-5 AND KA-10	39
9.1	Release Scenarios	39
9.2	Release Frequency.....	41
9.3	Risk Results	41
9.4	Risk Contributors	43
10.	WELLSITE KA-6, KA-11 AND KA-17	44
10.1	Release Scenarios	44
10.2	Release Frequency.....	46
10.3	Risk Results	47
10.4	Risk Contributors	48
11.	WELLSITE KA-8, KA-12, KA-15 AND KA-18	50

11.1	Release Scenarios	50
11.2	Release Frequency.....	55
11.3	Risk Results	57
11.4	Risk Contributors	59
12.	WELLSITE KA-13	61
12.1	Release Scenarios	61
12.2	Release Frequency.....	62
12.3	Risk Results	62
12.4	Risk Contributors	64
13.	CONCLUSIONS.....	65
14.	REFERENCES.....	67

APPENDICES

- APPENDIX 1. P&ID SECTIONALISATION FOR KA-19
- APPENDIX 2. P&ID SECTIONALISATION FOR KA-2
- APPENDIX 3. P&ID SECTIONALISATION FOR KA-4 AND KA-14
- APPENDIX 4. P&ID SECTIONALISATION FOR KA-5 AND KA-10
- APPENDIX 5. P&ID SECTIONALISATION FOR KA-6 AND KA-17
- APPENDIX 6. P&ID SECTIONALISATION FOR KA-8 AND KA-18
- APPENDIX 7. P&ID SECTIONALISATION FOR KA-13
- APPENDIX 8. FULL WELLSITES HEAT AND MATERIAL BALANCE

EXECUTIVE SUMMARY

Todd Energy Ltd. (Todd) operates the Kapuni wellsites which are at an onshore gas and condensate field located in South Taranaki approximately 50 km south of New Plymouth. 20 Kapuni wells are located on nine (9) separate wellsites in the area surrounding the Kapuni Production Station (KPS).

Quantitative Risk Assessments (QRAs) have been conducted for these wellsites. The purpose of the QRAs is to develop risk contours to meet the risk assessment requirements of the operative South Taranaki District Plan, Section 11: Hazardous Substances.

Table 1 presents the summary of main findings of the risk assessments.

Table 1: Summary of Main Findings

Wellsite	HIPAP4 Land Use Criteria <i>(For proposed development of a potentially hazardous nature, or for land use planning in the vicinity of existing hazardous installations)</i>	
	5E-05 / year <i>(5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable)</i>	1E-6 / year <i>(1E-6 / year risk contour for residential development, and places of continuous occupancy such as hotels, tourist resorts)</i>
KA-1/7/19/20		
Base Case	Criteria met. The 5E-05 / year risk contour is within the site boundary.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as Base Case	Same as Base Case
KA-2		
Base Case	Criteria met. The 5E-05 / year risk contour is within the site boundary.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
KA-4/14		
Base Case	Criteria met. The 5E-05 / year risk contour is within the site boundary.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as Base Case	Same as Base Case
KA-5/10		
Base Case	Criteria met. The 5E-05 / year risk contour is within the site boundary.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as Base Case	Same as Base Case
KA-6/11/17		
Base Case	Criteria met. The risk level is lower than 5E-05 / year.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as Base Case	Same as Base Case

Wellsite	HIPAP4 Land Use Criteria <i>(For proposed development of a potentially hazardous nature, or for land use planning in the vicinity of existing hazardous installations)</i>	
	5E-05 / year <i>(5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable)</i>	1E-6 / year <i>(1E-6 / year risk contour for residential development, and places of continuous occupancy such as hotels, tourist resorts)</i>
KA-8/12/15/18		
Base Case	The 5E-05 / year risk contour exceeds the site boundary at the north as the compressor buildings are located at the northern side of the wellsite.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as Base Case	Same as Base Case
KA-13		
Base Case	Criteria met. The 5E-05 / year risk contour is within the site boundary.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as Base Case	Same as Base Case

The HIPAP4 Land Use Criteria are met for all wellsites except for KA-8/18 wellsite where the 5E-05/year risk contour exceeds the site boundary at the north as the compressor buildings are located at the northern side of the wellsite.

For all sensitivity cases (where the aboveground sections of the gathering pipelines are included), the risk contours are only slightly larger compared to the base case. This is due to the low release frequencies from the additional pipeline sections which do not contribute significantly to the overall risk. The assessments against the HIPAP4 criteria are all consistent with the base case findings.

Risk contributors to offsite risks are also identified to help to identify the equipment / section of wellsites that are leading to offsite impact. For wellsites that have no offsite impact, risk contributor analyses were not conducted.

1. ABBREVIATIONS

AWS	Automatic Weather Station
BLEVE	Boiling Liquid Expanding Vapour Explosion
CO2	Carbon Dioxide
DNV	Det Norske Veritas Germanischer
EI	Energy Institute
ESDV	Emergency Shutdown Valve
HCRD	Hydrocarbon Release Database
HIPAP4	NSW Hazardous Industry Planning Advisory Paper No. 4
HMB	Heat and Material Balance
HPKO	High Pressure Knock Out
IOGP	International Association of Oil and Gas Producers
IRPA	Individual Risk Per Annum
KGTP	Kapuni Gas Treatment Plant
KPS	Kapuni Production Station
LFL	Lower Flammable Limit
LPG	Liquefied Petroleum Gas
LSIR	Location Specific Individual Risk
LTS	Low Temperature Separator
N2	Nitrogen
NIWA	National Institute of Water and Atmospheric Research Ltd
NNF	Normally No Flow
P&ID	Piping & Instrumentation Diagram
P/L	Pipeline
PECPR	Pressure Equipment, Cranes, and Passenger Ropeways
PLL	Potential Loss of Life
QRA	Quantitative Risk Assessment
STDC	South Taranaki District Council
Todd	Todd Petroleum Mining Company
VCE	Vapour Cloud Explosion
Worley	Worley New Zealand Ltd

2. INTRODUCTION

2.1 Background

Todd Energy Ltd. (Todd) operates the Kapuni wellsites which are at an onshore gas and condensate field located in South Taranaki approximately 50 km south of New Plymouth. Worley New Zealand Ltd. (Worley) has been commissioned by Todd to conduct a Quantitative Risk Assessment (QRA) for the Kapuni wellsites.

2.2 Objective

The objective of the QRA is to develop risk contours to meet the risk assessment requirements of the South Taranaki District Council (STDC) District Plan, Section 11: Hazardous Substances.

2.3 Scope

The scopes include:

- 1) Conduct risk assessment for seven (7) Kapuni wellsites with 17 wells; and
- 2) Update the existing KA-4/14 and KA-13 wellsites QRA [Ref. 1] and hence supersedes the results from that QRA.

Currently, seven (7) wellsites are producing, KA-3 is out of service and KA-9 is designed for water disposal only. The wellsite details are summarised in Table 2-1. Only the producing wells are considered in the risk assessment.

Table 2-1: Kapuni Wellsites

Wellsite	Number of wells	Producing	Scheduled for Abandonment ^{Note 1}	Suspended ^{Note 2}	Shut in ^{Note 3}	Observation / water ^{Note 4}	Notes
KA-1, KA-7, KA-19 and KA-20	4	1			1 (KA-7)	2 (KA-1 ^{Note 1} and KA-20)	
KA-2	1	1					
KA-3	1			1			
KA-4 and KA-14	2	2					KA-14 is only operating once (for 24 hours) every 10 days.
KA-5 and KA-10	2	1				1 (KA-10)	
KA-6, KA-11 and KA-17	3	2		1 (KA-11)			
KA-8, KA-12, KA-15 and KA-18	4	2	1 (KA-12)		1 (KA-15)		
KA-9	2					2	A new well, KW03, is drilled in May 2021 for further water injection purposes.
KA-13	1	1					KA-13 is only operating in 1 out of every 3 months.
Total	20	10	1	2	2	5	

Notes:

1. Wells that are scheduled for abandonment are plugged with abandonment plans underway.
2. Suspended wells are plugged and major intervention is required to bring the well back to service.
3. Shut in wells are isolated but could be brought back into service. Note that KA-7 and KA-15 were considered as producing wells in the Kapuni Safety Case [Ref. 1], however, the wells are currently shut-in and hence are not included in the risk assessment.
4. Water wells are for water injection only and will not be used for hydrocarbon / producing. Observation wells are only for monitoring reservoir conditions and informing development of reserves estimates. They are designed for instrumentation only and cannot inject or produce.

There is no plan to bring the non-producing wells back online in the future. In the unlikely event that this changes, the QRA will be updated to verify any impact on the risk contours. Engagement with STDC will be completed as part of this process and a resource consent process may be required. .

This revision of the report (Rev. 1) also captured the modelling update to consider delayed leak detection as early gas detection systems are not at all wellsites.

2.4 Exclusions

The following are excluded from the QRA:

- Risk from the gathering pipelines to Kapuni Production Station (KPS). The scope for each wellsite includes up to the pipeline isolation valves (if available) or when the pipelines go underground. Pipelines passing through the wellsites (e.g., at KA-4/14 and KA-5) are not considered in the base case. The pipeline sections are assessed in the sensitivity case. Note that the pipeline (P/L) to PECPR on the P&ID are used in some sections to identify the pipeline boundary;
- Risk other than hydrocarbon / process risk (e.g., transportation risk, seismic risk and volcanic risks);
- Decommissioned and/or mothballed and isolated equipment;
- Utilities such as produced water and instrument air as they do not contain any hydrocarbon inventory;
- Individual risk calculations, including Individual Risk Per Annum (IRPA) and Potential Loss of Life (PLL) as the wellsites are normally unmanned;
- Societal risk (F-N curve) as the wellsites are located as remote area with low populations;
- Corrosion inhibitors present at the wellsites as they are not flammable;
- Methanol injecting pumps as they are only used during start-up (except for KA-8/12/15/18 wellsite where methanol dosing is required throughout the year). Note that methanol tanks are always full and connected to the methanol pumps, with the pumps turned off when methanol is not being injected, hence the methanol tanks and tubing to the methanol pumps are included;
- Toxic effect of carbon dioxide; and
- Vapour Cloud Explosion (VCE), as there is limited equipment at the wellsites, and these areas are open with good ventilation expected throughout the year. The possibility of flammable vapour accumulating and developing into subsequent vapour cloud explosions, are considered not credible.

2.5 QRA Study Cases

The QRA study includes the base case and a sensitivity case to study the impact of different modelling input / assumption on the risk results. The QRA base case includes the current operations of the Kapuni wellsites with wellsites' equipment up to the pipeline isolation valves (if available) or when the pipelines go underground. Pipelines passing through the wellsites (e.g., at KA-4/14 and KA-5) are not considered in the base case.

One sensitivity case is considered in the Kapuni Wellsites QRA:

1. Include the aboveground gathering pipeline sections downstream of the pipeline isolation valves. The pipeline sections contain the entire pipeline inventory. The pipelines inventories are referenced from the Kapuni Safety Case [Ref. 1].

The details of the base case and sensitivity case are summarised in Table 2-2.

Table 2-2: Kapuni Wellsites QRA Base Case and Sensitivity Case

QRA Case	Details	Potential Impact
Base case	Current wellsites' operation up to the gathering pipeline isolation valves (if available) or when the pipelines go underground	-
Sensitivity case	<p>Include the aboveground gathering pipeline sections downstream of the pipeline isolation valves.</p> <p>Note that there is no sensitivity case for KA-2 wellsite as there is no pipeline isolation valves and no PECPR identification for the pipeline. The entire aboveground gathering pipeline sections are considered in the base case only.</p>	Addition QRA section(s) for the pipeline sections with the entire pipeline inventory.

2.6 Site Overview

Kapuni is an onshore gas and condensate field located in South Taranaki, approximately 50 km south of New Plymouth. 20 Kapuni wells are located on nine (9) separate wellsites in the area surrounding the Kapuni Production Station (KPS). The production wellsite process is a simple separation of gas and liquids involving the direction of wellstream gas and liquids to a low temperature separator (LTS) unit on the wellsite. The LTS separates the gas and liquids by means of pressure reduction to cause cooling.

An aerial overview of the wellsites location with reference to KPS is shown in Figure 2-1.

The wellsites access points are via vehicle gates which are normally adjacent to the main wellsite control huts for the wellsites. Each wellsite hut is a single storey building which contains the wellsite control logic systems, emergency and communications equipment.

The wellsites have an open layout with areas separated from each other to prevent knock-on effects. The open area reduces the potential for overpressure from an explosion and reduces fire damage / escalation potential.




Figure 2-1: Kapuni Wellsites Location with reference to Kapuni Production Station (KPS)

The details of each of the wellsite is as below.

2.6.1 Wellsite KA-1, KA-7, KA-19 and KA-20

Located off Palmer Road, the site contains 4 wells. A wellstream heater is fitted to the KA-19 well. KA-1 well is a contingency for water injection, KA-7 is not operational and KA-20 well is an observation well.

This site also acts as a distribution point for gas from the northern wells. It re-routes gas arriving from the gathering lines from wellsite KA-4/14 and KA-8/12/15/18 to KPS.

2.6.2 Wellsite KA-2

Located on Palmer Road, the site has an LTS unit and the flowline is equipped with two wellstream coolers.

2.6.3 Wellsite KA-3

This wellsite has been suspended and plugged.

2.6.4 Wellsite KA-4 and KA-14

Located just off Palmer Road, the site contains two wells, two LTS units, and a wellstream heater.

2.6.5 Wellsite KA-5 and KA-10

Located just off Skeet Road, this site contains one producing well (KA-5) and one observation well (KA-10), with a Desander unit for solids separation, and a PCV used on start-up.

2.6.6 Wellsite KA-6, KA-11 and KA-17

Located just off Ahipaipa Road, this site contains two producing wells and one suspended well (KA-11). KA-6 and KA-17 wellstream fluids are co-mingled, routed through a wellstream cooler and then to an LTS Unit.

2.6.7 Wellsite KA-8, KA-12, KA-15 and KA-18

Located off Eltham Road, this site contains two producing wells. KA-12 well is scheduled for abandonment and KA-15 well is shut-in and isolated. Two wellstream process skids and two wellhead compression units are fitted to the wells.

2.6.8 Wellsite KA-13

Located just off Skeet Road, this site contains one well, Desander, a flowline choke valve and a High Pressure Knock Out (HPKO) vessel. It connects into the KA-6/5 gathering lines. The HPKO is now bypassed and is not considered.

2.6.9 Wellsite KA-9

Located on Lower Duthie Road, two wells were drilled on the site, KA-9 (referred to as KW-2) and KA-16. Both wells are currently in service as water injection wells. There is very little equipment left on the wellsite, only the water injection line, a filter, and two pig receivers.

The wellsites flow schematic is presented in Figure 2-2.




Figure 2-2: Kapuni Wellsites Flow Schematic

3. METHODOLOGY

The methodology followed for completing the QRA is aligned with good industry practice and the Todd Energy Fire and Explosion Analysis and Quantitative Risk Assessment Methodology Guideline [Ref. 2]. The generic process, specified in the Worley’s Onshore QRA Method Statement [Ref. 3], is illustrated in Figure 3-1.




Figure 3-1: QRA Methodology

3.1 Assessment Tools

DNV Safeti Software (formerly known as Phast Risk) [Ref. 4] is used to build the QRA model. Safeti is an integrated consequence and risk modelling package developed by DNV Software aimed at the onshore petrochemical and chemical process industry for assessing process plant risks via comprehensive QRA. It is designed to perform all the analytical, data processing and results presentation elements of a QRA within a structured framework. Note that the QRA study started in 2020, where the QRA model was built using Safeti version 8.22, which was the latest version at that time. For the subsequent modelling update, a newer software version at the time of update was used. For this revision of the report (Rev. 1), Safeti version 8.6 was used to perform the required updates. Not all wellsite models were updated to Safeti 8.6.

3.2 Assumptions

An Assumptions Register [Ref. 5] was generated which outlines the basis of all assumptions and the input bases inherent in the QRA study. Key assumptions are shown in the following subsections for reference.

3.2.1 Atmospheric Conditions

Meteorological conditions impact the outcomes of release modelling, including downwind flammable and toxic vapour cloud dispersion distance (influenced by atmospheric stability and wind speed), rate of pool vaporisation (ambient temperature), and atmospheric attenuation of radiant heat (temperature and relative humidity).

The following conditions are used for the QRA modelling.

Wind Speed and Direction

Wind speed and direction data are taken from NIWA’s CliFlo database [Ref. 6] for the Hawera Automatic Weather Station (AWS) to represent the atmospheric conditions at Kapuni. Data for 5-year period from January 2008 to December 2012 are taken, with wind speed and direction measurements taken every hour. The wind rose is shown in Figure 3-2.




Figure 3-2: Hawera AWS Windrose

The following wind speed and atmospheric stability (Pasquill stability) combinations are used in the QRA. The wind data in tabular format is given in Table 3-1.

Table 3-1: Hawera AWS Wind Data

Wind Speed / Pasquill Stability	North	North East	East	South East	South	South West	West	North West	Total
0 - 2 m/s / F	2.1%	1.1%	0.3%	1.4%	0.6%	0.3%	1.7%	1.5%	9.0%
2 - 5 m/s / D	10.1%	5.1%	1.5%	6.9%	3.1%	1.4%	8.2%	7.2%	43.5%
> 5 m/s / D	11.1%	5.6%	1.7%	7.5%	3.4%	1.5%	8.9%	7.9%	47.5%
Total	23.3%	11.8%	3.5%	15.9%	7.1%	3.2%	18.7%	16.5%	100.0%

Note:

- Pasquill Stability F – stable, night with moderate clouds and light/moderate wind
- Pasquill Stability D – neutral, little sun and high wind or overcast/windy night

For the modelling, the wind speed reference height (the height at which the wind impacts a release), is set at 1 m (i.e. so as to match the release height). The Power Law wind profile is applied, where the wind speed varies with height according to power-law profile.

Ambient Temperature and Relative Humidity

The following ambient temperature and relative humidity are used in the QRA:

- Ambient temperature: 14°C
- Relative humidity: 83%

Solar Radiation

Solar radiation is not included in the thermal radiation calculations.

Topography

Safeti cannot take into account the effects of the local undulating topography for the gas dispersion. A surface roughness of 30 mm was applied, which generally represents an area of “open flat terrain; grass, few isolated objects” to represent the open area of the wellsites.

3.2.2 General Release Frequency

The leak frequencies for process equipment are taken from the International Association of Oil and Gas Producers (IOGP) Process Release Frequency 2019 [Ref. 7]. Release frequencies of the main process equipment items are based on an analysis of the UK HSE hydrocarbon release database (HCRD). Two sets of data are presented in IOGP Process Release Frequency, which include the 1992 – 2015 data and 2006 – 2015 data. The recommended values based on experience in the period 2006 – 2015 (inclusive) are used.

The IOGP Release Frequency Data does not provide the frequencies for atmospheric storage tanks. Therefore, the following leak frequencies from the TNO Purple Book [Ref. 8] are used for the methanol tanks.

The blowout likelihood from the IOGP Blowout Frequencies [Ref. 9] are used, specifically data for offshore operations in areas not operating according to North Sea Standard (Table 2-3 in the IOGP). It is noted that the Kapuni wellsites are located onshore, however, IOGP recommends the use of offshore data presented in Section 2 in the IOGP but noted that there will be a greater degree of uncertainty.

3.2.3 Release Hole Sizes

For every component failure, there is a range of credible hole sizes from pinhole leak to full bore rupture. The hole size grouping from the OGP Process Release Frequency together with the representative hole sizes used in the QRA is shown in Table 3-2.

Table 3-2: Hole Size Distribution

OGP Hole Size Group (mm)	Representative Hole Size (mm)
1 - 3	2
3 - 10	6
10 - 50	22
50 - 150	85
> 150	Range geometric mean

The representative hole sizes are chosen using the geometric mean of the smallest and largest hole sizes in each group. The same approach is taken to select the representative hole size for rupture cases (release > 150 mm).

It is noted for methanol tanks that references to TNO Purple Book failure data, actual hole sizes following the failure data are used as there are no sufficient leak size distribution data in Purple Book to calculate the geometric mean.

22 mm is used as the maximum hole size for small bore fittings. The maximum hole size for a flange is also limited to 22 mm as a release from a flange is normally limited to a segment of a gasket between bolts.

Leak frequency modification factors are also applied to the release frequency database as per Todd Energy's Methodology Guideline [Ref. 2].

3.2.4 Ignition Probabilities

The probability of ignition of a release is a function of the release rate, the nature of the material being released and the conditions of the surrounding plant. The Energy Institute (EI) ignition probability models [Ref. 10] referenced in IOGP Ignition Probabilities [Ref. 11] are used for the estimation of overall ignition probability of loss of containment scenarios.

For wellsites, ignition probabilities are taken from Scenario 5 and 6 and assumed to particularly apply to a 'plant' where processing takes place. This is considered conservative for use at wellsites as not much processing takes place.

The scenarios are described as:

- Scenario 5 – Small Plant Gas LPG (Gas or LPG release from small onshore plant) - Releases of flammable gases, vapour or liquids significantly above their normal boiling point from small onshore plants (plant area up to 1200 m², site area up to 35,000 m²).
- Scenario 6 - Small Plant Liquid (Liquid release from small onshore plant) - Releases of flammable liquids that do not have any significant flash fraction (10% or less) if released from small onshore plants (plant area up to 1200 m², site area up to 35,000 m²) and which are not banded or otherwise contained.

The graphs of ignition probabilities as a function of mass release rate are shown in Figure 3-3.




Figure 3-3: Ignition Probabilities

The graph represents the total ignition probability. The Energy Institute suggests that an overall distribution for early to delayed ignition ratio of 30:70 to 50:50 split is considered reasonable. The timing of ignition is used as a means to predict the nature of the ignited event. Early ignition is taken to indicate a jet fire or pool fire depending on the material released. Delayed ignition is taken to indicate that the ignition would initially result in a flash fire or explosion.

For this study, a 30:70 split for early to delayed ignition probability is used. Given the maturity of the hazardous area, it can be assumed that probability of early ignition would be low.

3.2.5 Fatality Criteria

Thermal Radiation

The method of calculating the probability of fatality for an individual, given known exposure duration and thermal heat radiation levels, is undertaken by using a Probit function. The Probit function is a general formula which takes the same form, but with various constants used. The Probit used for lethality calculations is taken from the TNO Green Book [Ref. 12]. The Probit function is defined as follows:

$$\text{Probit} = -36.38 + 2.56 \ln (t \times q^{4/3})$$

Where:

t = exposure duration in seconds

q = thermal radiation level in W/m²

Safeti calculates the Probit values during the analysis.

An exposure duration of 20 seconds has been used as a base case, although it is noted that personnel are likely to find some form of shielding protection within this time frame.

Flash Fire

If personnel are within the 100% lower flammable limit (LFL) of the gas plume, 100% fatality is assumed. LFL is the lower end of the concentration range over which the flammable mixture of a gas/ vapour in air can be ignited at a given temperature/ pressure.

A flash fire occurs when a dispersed cloud of flammable gas or vapour and air mixture is ignited within its flammable regions, causing a wall of flame to spread throughout the flammable region and back to the release point. The flame propagates through the cloud in a manner such that negligible or no damaging overpressure is generated. This flash is almost instantaneous as the flame propagates at high speed through the cloud and back to the source.

An assumption of 100% fatality rate within the footprint of the cloud is conservative and does not allow for potential risk reducing considerations such as;

- Uneven mixing of gas and air in the cloud resulting in uneven propagation of the flame,
- Topography,
- Sparsely populated rural land use adjoining the site,
- Availability of shelter,
- Opportunity for escape, and
- Clothing worn by persons exposed to the flash fire.

Thermal radiation outside of the flash fire falls off rapidly and is not sustained due to the instantaneous nature of the event. The potential for fatality outside the flash fire footprint is not considered credible.

BLEVE

Boiling Liquid Expanding Vapour Explosion (BLEVE) is an escalation scenario that occurs as a result of prolonged flame impingement on above ground pressurised vessels containing materials such as LPG or lighter end hydrocarbon. The probability of BLEVE depends on various factors, including the types of flammable material and liquid inventory in the vessel, material of construction of the vessel, types and number of fire protection systems (e.g. relief valves, cooling systems), mechanism of vessel failure (external impact, jet fire impingement or pool fire impingement), etc. Passive Fire Protection can be provided on pressurised vessels to minimise the probability of BLEVE. There is no clear guideline or criteria to determine the likelihood of a BLEVE on a pressurised vessel. For this QRA, BLEVE is considered credible if a pressurised vessel containing at least 4 m³ of volatile hydrocarbon (liquid butane or lighter) is exposed to direct flame impingement for 5 minutes or longer.

However, based on the liquid inventory and liquid composition in the vessels, BLEVE is considered not possible for any vessel at Kapuni wellsites.

4. HAZARD IDENTIFICATION

4.1 Hazardous Materials

The Heat and Balances (HMBs) for the wellsites are provided by Todd Process Engineer. The wellstream fluid from each well have different flowrates, material compositions and operating conditions. Any stream that has unique consequences will be represented by dedicated sections. For sections with similar operating conditions or fluid composition that have similar consequence results, the worst case scenario will be selected as representative, to rationalise the number of scenarios performed. This is to avoid the averaging out of inputs of different wellstreams, as it may create a stream with 'brand new' operating conditions, material compositions and flowrates which does not represent the actual release conditions.

As far as is reasonable, the compositions in each stream are simplified, i.e. isomers are summed together and the C6+ hypothetical materials (KP01, up to KP30) are represented by different heavy alkanes. The following alkanes are selected to represent different ranges of hypothetical materials found in the streams based on their properties:

- KP01 to KP10 are assumed to be C7;
- KP11 to KP20 are assumed to be C10; and
- KP21 to KP30 are assumed to be C20.

The important characteristic of molecular weight is kept close to the actual value to ensure the release rate is representative. The simplified HMB used in the QRA is presented in Appendix 8.

The effects of water cut of the hydrocarbon on fire hazards are considered identify the streams that are considered not flammable due to high water content. According to Oil and Gas UK Fire and Explosion Guidance [Ref. 13], for water cuts under 50%, no significant reduction in heat fluxes to engulfed objects can be expected (<10%). However, for water cuts over 50%, the flames are significantly less radiative, and the overall heat flux to an obstacle can be reduced by 40% or more. In line with Oil and Gas UK Fire and Explosion Guidance, it is assumed that a mixture remains flammable if it has a water cut of up to 125% (defined as mass of water/ mass of fuel x 100%), although not necessarily capable of supporting a stable flame in the absence of some other supporting mechanisms.

Similarly, increasing concentrations of CO₂ were found to reduce the likelihood of ignition of a methane jet release. At CO₂ concentrations of 22–40% (v/v) it was possible for a self-sustaining flame to exist, but beyond these concentrations a pilot flame was required to aid combustion. Beyond 60% CO₂ the pilot flame had no effect and the mixture was completely inert [Ref. 14].

The average flammability limits of the mixtures are calculated by Safeti software, considering the effects of the inert components (e.g. CO₂, N₂ and water).

4.2 Isolatable Sections and Inventory

An ESD system can limit the outflow once a loss of containment occurs. When activated, emergency shut-down valves (ESDVs) divide the process system into a number of isolatable sections, with each potential leak source associates with a particular isolatable inventory. These sections were split further where necessary and the entire contained inventory was considered as available for release.

Isolatable sections are highlighted in the Piping and Instrumentation Diagrams (P&IDs) and presented in Appendix 1 to Appendix 7. Following the sectionalisation process, parts counts are conducted to perform the frequency analysis for the QRA.

All wellsites have automated ESD on fire detection, and KA-8/18 has automatic ESD on gas detection as well. To assess the impact of additional release inventory due to the delayed detection and isolation, a sensitivity check was conducted on the QRA models for a few selected wellsites. It was found for hydrocarbon gas releases, there is no noticeable impact to the risk results and the study conclusion, as the consequence distances from the gas scenarios have reached steady state and the additional gas inventory will only lead to longer release duration

with no impact to the effect distances. However, for condensate releases, the longer release duration can lead to a larger pool accumulation on the ground.

Condensate leaks at the wellsites or along the pipelines (other than minor leaks) will lead to pressure and/or liquid level drop at the process at KPS, which will alert the operators to perform a check at the wellsite(s). Given the proximity to the KPS, operators can generally arrive at the wellsites within 15 minutes to initiate the site ESD. As such, 15 minutes delayed detection will be assumed where 15 minutes of released inventory will be added. Full bore rupture cases are only considered credible when there is major work on site, and the wellsite would be manned to detect the leak immediately. Hence undetected full bore rupture is not considered credible.

The wellsites bunding and drainage systems are designed to contain hazardous materials within the boundaries of the wellsite. Therefore, the condensate pool is assumed to remain confined within the site.

5. RISK ASSESSMENT CRITERIA

This section presents results of the QRA. Risks estimated in this study are presented in the form of Location Specific Individual Risk (LSIR) contours. LSIR is defined as the risk of fatality at a point in space to a hypothetical individual at a location for 365 days per year, 24 hours a day, unprotected and unable to escape. In practice this is not the case and this criterion is therefore conservative.

As there are no standard risk criteria which have been developed for the New Zealand context, this has been assessed against the suggested risk criteria in the NSW HIPAP No. 4 “Risk Criteria for Land Use Planning” [Ref. 16] as shown in Table 5-1.

Table 5-1: Individual Fatality Risk Criteria

Land Use	Risk Criteria Adopted (per annum)	Interpretation for QRA
Industrial	5E-05 (1 in 20,000)	5E-05 risk contour should, as a target, be contained within the boundaries of the industrial site where applicable
Sporting complexes and active open space	1E-05 (1 in 100,000)	1E-05 risk contour should not extend to these areas
Commercial developments including retail centres, offices and entertainment centres	5E-06 (1 in 200,000)	5E-06 risk contour should not extend to these areas
Residential developments, hotels, tourist resorts	1E-06 (1 in 1 million)	1E-06 risk contour should not extend to these areas
Hospitals, schools, childcare facilities, old age housing	5E-07 (1 in 2 million)	5E-07 risk contour should not extend to these areas

Kapuni wellsites are situated in the zone classified as “Rural” under the operative South Taranaki District Plan [Ref. 17] and surrounded by dairy farmland, and as such a suitable land use category is not easily inferred from the above table. There are no industrial, sporting complexes, hospitals or commercial developments in the area surrounding the wellsites. The closest identified offsite parties are dwellings or houses. Therefore, only the “Industrial” (5E-05 / year) and “Residential” (1E-06 / year) are considered.

6. WELLSITE KA-1, KA-7, KA-19 AND KA-20

6.1 Release Scenarios

The P&IDs showing the isolatable sections for KA-19, which is the only producing well at this wellsite, are presented in Appendix 1. Table 6-1 details the section description and the respective operating conditions that are used in the QRA.

Table 6-1: Release Scenarios and Operating Conditions for KA-19

No.	Section ID	Description	Material / Stream Note 1	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
1	01_KA19_01_WLHEAD_V	Wellstream fluid from KA-19 wellhead to SDV-2140A	15	33.8	40.29	150	Unlimited Note 2	
2	02_KA19_02_FLWLNE_V	Wellstream fluid from wellhead SDV-2140A to choke valve HCV-2140X	15	33.8	40.29	150	0.8	6.6
3	03_KA19_02_CHKLINE_V	Wellstream fluid from choke valve HCV-2140X to Wellstream Cooler (E-2153)	16	23.1	33.6	150	1.3	6.6
4	04_KA19_02_WSCOOL_V	Wellstream fluid from Wellstream Cooler (E-2153) to Wellhead Knockout (V-2154)	17	22.8	24	150	1.2	6.6
5	05_KA19_02_WLHKOT_V	Hydrocarbon gas from Wellhead Knockout (V-2154) to SDV-2154A and manual valve 150V385	19	22.8	24	80	3.3	6.6
6	06_KA19_02_WLHKOB_L	Hydrocarbon liquid from Wellhead Knockout (V-2154) to SDV-2154B	18	22.8	24	150	2.1	2.1 Note 4
16	16_KA19_04_CONPIP_L	Hydrocarbon liquid from SDV-2154B and SDV-2853A to Condensate Pipeline	18	22.8	24	100	38.2 Note 3	38.2 Note 5
17	17_KA19_05_GASPP1_V	Hydrocarbon gas from SDV-2154A mix with wet gas from A-5002 to XSV-2165A on the Gas Pipeline to KA-8 via KA-4/14	19	22.8	24	250	15.9	17.9
18	18_KA19_05_GPIG65_V	Scraper Trap (A-2165)	19	22.8	24	250	1.0	17.9
19	19_KA19_05_GPIG63_V	Scraper Trap (A-2163)	19	22.8	24	200	1.0	17.9
20	20_KA19_06_GASPP2_V	Hydrocarbon gas from SDV-2852C mix with dry gas from KA-4/14 wellsite to Gas Pipeline to KPS	8	28.2	23.11	250	7.2 Note 3	8.2

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

No.	Section ID	Description	Material / Stream <small>Note 1</small>	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
21	21_KA19_06_GPIG67_V	Scraper Trap (A-2167)	8	28.2	23.11	250	1.0	8.2
22	22_KA19_06_GPIG66_V	Scraper Trap (A-2166)	8	28.2	23.11	150	1.0	8.2
23	23_KA19_07_VEKGAS_V	KGTP Treated Gas to XSV-2169A for export pipeline (to Kiwi Dairy Co. & Taranaki Byproduct Co.)	Kiwi GC	21.1	38.9	250	7.7 <small>Note 3</small>	15.4
24	24_KA19_07_PG2169_V	Scraper Trap (A-2169)	Kiwi GC	21.1	38.9	250	7.7	15.4
25	25_KA19_07_PG2164_V	Scraper Trap (A-2164)	Kiwi GC	21.1	38.9	150	7.7	15.4
26	26_KA19_08_METTNK_L	Methanol Tank (T-2191) to Methanol Pumps	Methanol	Atm.	Amb.	50	5.0	5.0
<i>Sensitivity Cases</i>								
27	27_KA19_09_KA4GPL_V	Dry gas from KA-4/14 to XSV-2167A	8	28.2	23.11	250	97.3 <small>Note 3</small>	97.3
28	28_KA19_10_KA8GPL_V	Wet gas from XSV-2165A to KA-8/18	19	22.8	24	250	38.7 <small>Note 3</small>	38.7
29	29_KA19_11_KIWICO_V	KGTP Treated Gas from XSV-2169A to export pipeline (to Kiwi Dairy Co. & Taranaki Byproduct Co.)	Kiwi GC	21.1	38.9	250	1100.0 <small>Note 3</small>	1100.0

Notes:

1. Stream composition refers to the stream numbers in the HMB. The full HMB for all wellsites is attached Appendix 8.
2. Inventory from the wellhead section is considered to be unlimited because they can be supplied from the downhole reservoir.
3. Sections connecting to the pipeline inventories due to the lack of isolation valve.
4. Inventories for modelling the 22 mm leak was increased to 12739 kg and 190159 kg for 85 mm leak, assuming the delayed detection and isolation of 15 min (i.e., the releases can sustain up to 15 min). This is conservatively assumed that the leaks can sustain at initial pressure with no depressurisation at the system.
5. Inventory for modelling the 71 mm leak was increased to 131598 kg, assuming the delayed detection and isolation of 15 min (i.e., the releases can sustain up to 15 min). This is conservatively assumed that the leaks can sustain at initial pressure with no depressurisation at the system.

6.2 Release Frequency

The leak frequencies for the process releases are estimated for each representative hole size using parts count results and the historical leak frequencies. The leak frequencies for KA-19 sections for the base case are shown in Table 6-2.

Table 6-2: Hydrocarbon Release Frequencies for KA-19 (Base Case)

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
1	01_KA19_01_WLHEAD_V	3.37E-05	1.38E-05	5.67E-06	1.13E-06	7.09E-07	5.50E-05	0.3%
	KA-19 Blowout					4.20E-05	4.20E-05	0.2%
2	02_KA19_02_FLWLNE_V	9.10E-04	3.85E-04	2.06E-04	7.36E-06	1.58E-06	1.51E-03	7.9%
3	03_KA19_02_CHKLNE_V	1.88E-03	8.15E-04	4.43E-04	3.27E-05	3.77E-06	3.18E-03	16.6%
4	04_KA19_02_WSCOOL_V	1.25E-03	4.67E-04	1.93E-04	4.23E-05	7.70E-07	1.95E-03	10.2%
5	05_KA19_02_WLHKOT_V	1.21E-03	5.38E-04	2.88E-04	4.71E-05		2.08E-03	10.8%
6	06_KA19_02_WLHKOB_L	7.25E-04	3.42E-04	1.88E-04	5.65E-05	1.41E-06	1.31E-03	6.8%
16	16_KA19_04_CONPIP_L	1.28E-03	5.68E-04	2.99E-04	5.02E-05		2.20E-03	11.5%
17	17_KA19_05_GASPP1_V	7.89E-04	3.47E-04	1.85E-04	2.45E-05	5.30E-06	1.35E-03	7.0%
18	18_KA19_05_GPIG65_V	7.94E-07	4.05E-07	2.24E-07	5.42E-08	1.77E-08	1.49E-06	0.01%
19	19_KA19_05_GPIG63_V	3.75E-07	1.94E-07	1.08E-07	2.83E-08	8.83E-09	7.15E-07	0.004%
20	20_KA19_06_GASPP2_V	1.11E-03	4.89E-04	2.60E-04	3.01E-05	5.67E-06	1.90E-03	9.9%
21	21_KA19_06_GPIG67_V	1.84E-07	9.52E-08	5.28E-08	1.35E-08	4.42E-09	3.50E-07	0.002%
22	22_KA19_06_GPIG66_V	9.29E-08	4.81E-08	2.67E-08	1.32E-08	4.39E-12	1.81E-07	0.001%
23	23_KA19_07_VEKGAS_V	1.60E-03	6.89E-04	3.71E-04	3.38E-05	3.59E-06	2.70E-03	14.1%
24	24_KA19_07_PG2169_V	1.17E-06	5.96E-07	3.30E-07	7.64E-08	2.67E-08	2.20E-06	0.011%
25	25_KA19_07_PG2164_V	1.01E-07	5.17E-08	2.86E-08	1.35E-08	4.39E-12	1.95E-07	0.001%
26	26_KA19_08_METTNK_L	4.64E-04	3.03E-04	1.12E-04	1.35E-05	5.00E-06	9.03E-04	4.7%
TOTAL		1.13E-02	4.96E-03	2.55E-03	3.44E-04	6.99E-05	1.92E-02	
% Contribution		59%	26%	13%	2%	0.4%		

The total leak frequencies for KA-19 wellsite (for the base case) is 1.92E-02 per year, which is equivalent to one leak every 52.1 years. Most of the leaks are predicted to be from small leaks, where 85% of the leaks are from hole sizes less than 10 mm diameter.

The leak frequencies for KA-19 sections for the sensitivity case are shown in Table 6-3.

Table 6-3: Hydrocarbon Release Frequencies for KA-19 (Sensitivity Case)

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
27	27_KA19_09_KA4GPL_V	3.19E-05	1.42E-05	7.35E-06	1.14E-06	3.54E-07	5.50E-05	0.3%
28	28_KA19_10_KA8GPL_V	3.19E-05	1.42E-05	7.35E-06	1.14E-06	3.54E-07	5.50E-05	0.3%
29	29_KA19_11_KIWICO_V	3.19E-05	1.42E-05	7.35E-06	1.14E-06	3.54E-07	5.50E-05	0.3%
TOTAL (Base Case and Sensitivity)		1.14E-02	5.00E-03	2.57E-03	3.48E-04	7.09E-05	1.93E-02	
% Contribution		59%	26%	13%	2%	0.4%		

The total leak frequency for KA-19 wellsite (including the sensitivity cases) is 1.93E-02 per year, which is equivalent to one leak every 51.7 years.

6.3 Risk Results

The risk results are presented in this section. The risk contours are contributed from both flammable and toxic risks from all release scenarios based on all the hazardous materials onsite.

The only toxic risk onsite is from the methanol tank due to methanol toxicity. As the methanol tank is stored at atmospheric condition with limited inventory (5 m³ at maximum capacity) and bunded, the methanol toxic risk is very minor and localised. Hence no separate toxic risk contour was provided. Methanol toxic effect was modelled by using the probit method as detailed in the Assumptions Register [Ref. 5].

6.3.1 Base Case

The base case LSIR for KA-19 wellsite is presented in Figure 6-1.



Figure 6-1: LSIR Contours for KA-19 Wellsite (Base Case)

The risk assessed against the HIPAP4 criteria are summarised in Table 6-4.

Table 6-4: LSIR Results Assessed Against the HIPAP4 Land Use Criteria for KA-19 (Base Case)

LSIR	Risk Contour	HIPAP4 Land Use Criteria	Result
5E-05 / year	Blue	5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable.	Criteria met. The 5E-05 / year risk contour is within the site boundary.
1E-6 / year	Red	1E-6 / year risk contour should not extend to residential developments, hotels, tourist resorts.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.

6.3.2 Sensitivity Case

The LSIR for KA-19 wellsite sensitivity case, which include the gathering pipeline sections is presented in Figure 6-2.



Figure 6-2: LSIR Contours for KA-19 Wellsite (Sensitivity Case)

The risk contours for the sensitivity case are larger compared to the base case. Nonetheless, and the assessment against the HIPAP4 criteria is the same. Hence is it not repeated.

6.4 Risk Contributors

The risk contributors to offsite risks at selected locations (points A to D) as shown in Figure 6-3 can be identified from the QRA model.




Figure 6-3: Location Selected to Identify Risk Contributors at KA-19 wellsite

6.4.1 Base Case

The risk contributors for the base case with the risk contributors and percentage of contribution are shown in Table 6-5.

Table 6-5: Risk Contributors to Selected Locations for KA-19 (Base Case)

Point	LSIR (per year)	Contributor	% Contribution	Consequence
A	5.87E-07	06_KA19_02_WLHKOB_L_85 mm (Hydrocarbon liquid from Wellhead Knockout (V-2154) to SDV-2154B)	56.8%	Jet fire with pool fire from early ignition (78%) Delayed pool fire with flash fire (22%)
		16_KA19_04_CONPIP_L_71 mm (Hydrocarbon liquid from SDV-2154B (from Wellhead Knockout (V-2154)) to Condensate Pipeline)	42.2%	Jet fire with pool fire from early ignition (76%) Delayed pool fire with flash fire (24%)
B	5.44E-07	06_KA19_02_WLHKOB_L_85 mm (Hydrocarbon liquid from Wellhead Knockout (V-2154) to SDV-2154B)	61.3%	Jet fire with pool fire from early ignition (78%) Delayed pool fire with flash fire (22%)

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

Point	LSIR (per year)	Contributor	% Contribution	Consequence
		16_KA19_04_CONPIP_L_71 mm (Hydrocarbon liquid from SDV-2154B (from Wellhead Knockout (V-2154)) to Condensate Pipeline)	38.7%	Jet fire with pool fire from early ignition (69%) Delayed pool fire with flash fire (31%)
C	2.04E-06	06_KA19_02_WLHKOB_L_85 mm (Hydrocarbon liquid from Wellhead Knockout (V-2154) to SDV-2154B)	44.8%	Jet fire with pool fire from early ignition (69%) Delayed pool fire with flash fire (31%)
		16_KA19_04_CONPIP_L_71 mm (Hydrocarbon liquid from SDV-2154B (from Wellhead Knockout (V-2154)) to Condensate Pipeline)	37.8%	Delayed pool fire with flash fire (68%) Jet fire with pool fire from early ignition (32%)
D	3.46E-07	06_KA19_02_WLHKOB_L_85 mm (Hydrocarbon liquid from Wellhead Knockout (V-2154) to SDV-2154B)	63.5%	Jet fire with pool fire from early ignition (91%) Delayed pool fire with flash fire (9%)
		16_KA19_04_CONPIP_L_71 mm (Hydrocarbon liquid from SDV-2154B (from Wellhead Knockout (V-2154)) to Condensate Pipeline)	34.6%	Jet fire with pool fire from early ignition (87%) Delayed pool fire with flash fire (13%)

The risk contributor analysis shows that the offsite risk contributors at different locations are contributed by two (2) same scenarios, which are the liquid sections from the Wellhead Knockout (V-2154) to the SDV-2154B (06_KA19_02_WLHKOB_L) and from the same SDV to the condensate export pipeline (16_KA19_04_CONPIP_L).

These sections have relatively high release frequencies (contributed 18.5% to the total wellsite leak frequency), and with the potential to have a large leak for 15 minutes (conservatively assumed that the leaks were remained at initial release rate with no depressurisation due to the leaks), hence can lead to a large liquid release.

6.4.2 Sensitivity Case

The risk contributors for the sensitivity case with the risk contributors and percentage of contribution are shown in Table 6-6.

Table 6-6: Risk Contributors to Selected Locations for KA-19 (Sensitivity Case)

Point	LSIR (per year)	Contributor	% Contribution	Consequence
A	7.32E-07	06_KA19_02_WLHKOB_L_85 mm (Hydrocarbon liquid from Wellhead Knockout (V-2154) to SDV-2154B)	45.5%	Jet fire with pool fire from early ignition (78%) Delayed pool fire with flash fire (22%)
		16_KA19_04_CONPIP_L_71 mm (Hydrocarbon liquid from SDV-2154B (from Wellhead Knockout (V-2154)) to Condensate Pipeline)	33.8%	Jet fire with pool fire from early ignition (76%) Delayed pool fire with flash fire (24%)

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

Point	LSIR (per year)	Contributor	% Contribution	Consequence
B	5.44E-07	06_KA19_02_WLHKOB_L_85 mm (Hydrocarbon liquid from Wellhead Knockout (V-2154) to SDV-2154B)	61.3%	Jet fire with pool fire from early ignition (78%) Delayed pool fire with flash fire (22%)
		16_KA19_04_CONPIP_L_71 mm (Hydrocarbon liquid from SDV-2154B (from Wellhead Knockout (V-2154)) to Condensate Pipeline)	38.7%	Jet fire with pool fire from early ignition (69%) Delayed pool fire with flash fire (31%)
C	2.78E-06	06_KA19_02_WLHKOB_L_85 mm (Hydrocarbon liquid from Wellhead Knockout (V-2154) to SDV-2154B)	32.9%	Jet fire with pool fire from early ignition (68%) Delayed pool fire with flash fire (32%)
		16_KA19_04_CONPIP_L_71 mm (Hydrocarbon liquid from SDV-2154B (from Wellhead Knockout (V-2154)) to Condensate Pipeline)	27.8%	Delayed pool fire with flash fire (68%) Jet fire with pool fire from early ignition (32%)
D	9.95E-07	27_KA19_09_KA4GPL_V_194 mm (Dry gas pipeline)	38.8%	Immediate jet fire (100%)
		29_KA19_11_KIWICO_V_194 mm (KGTP Treated Gas to export pipeline (to Kiwi Dairy Co. & Taranaki Byproduct Co.))	27.6%	Immediate jet fire (97%) Delayed flash fire (3%)
		06_KA19_02_WLHKOB_L_85 mm (Hydrocarbon liquid from Wellhead Knockout (V-2154) to SDV-2154B)	21.4%	Jet fire with pool fire from early ignition (91%) Delayed pool fire with flash fire (9%)
		16_KA19_04_CONPIP_L_71 mm (Hydrocarbon liquid from SDV-2154B (from Wellhead Knockout (V-2154)) to Condensate Pipeline)	11.6%	Delayed pool fire with flash fire (87%) Jet fire with pool fire from early ignition (13%)

The risk contributors for the sensitivity case are largely consistent with the base case, except at point D (at the west side of the wellsite) where the risks are also contributed by jet fires from the export pipelines.

It should be noted that Safeti cannot consider the effect of the obstacles / objects located along the way where the heat is radiated from the release source. In reality heat may be shielded by some process equipment / piping before extending offsite. Safeti also cannot consider the ground topography for pool spread, instead, flat area is assumed and the pool can spread until it reaches a bund wall or the pool formed minimum thickness (normally 5 mm).

7. WELLSITE KA-2

7.1 Release Scenarios

The P&IDs showing the isolatable sections for KA-2 are presented in Appendix 2. Table 7-1 details the section description and the respective operating conditions that are used in the QRA. There are no sensitivity cases for this wellsite.

Table 7-1: Release Scenarios and Operating Conditions for KA-2

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
1	01_KA02_01_WLHEAD_V	Wellstream fluid from KA-02 wellhead to XSV-0200C	1	31.74	43.72		<i>Unlimited</i> ^{Note 2}	
2	02_KA02_02_FLWLNE_V	Wellstream fluid from XSV-0200C to XSV-0200A	1	31.74	43.72	100	0.1	0.1
3	03_KA02_03_FLWLNE_V	Wellstream fluid from XSV-0200A to Wellstream Coolers (E-2210 & E-2260)	1	31.74	43.72	150	1.1	75.8
4	04_KA02_03_WSCOL1_V	Wellstream fluid from Wellstream Cooler (E-2210) to Gas/Condensate Exchanger (E-0201A)	2	31.64	24	150	1.4	75.8
5	05_KA02_03_WSCOL2_V	Wellstream fluid from Wellstream Cooler (E-2260) to Gas/Condensate Exchanger (E-0201A)	2	31.64	24	150	1.7	75.8
6	06_KA02_03_GCEXCT_V	Hydrocarbon gas from Gas/Condensate Exchanger (E-0201A) (tube side) to LT Separator (V-0202A)	2	31.64	24	150	1.1	75.8
7	07_KA02_03_LTSEPR_V	Wellstream fluid from LT Separator (V-0202A) to HP Knockout (V-201A)	2	31.64	24	150	0.1	75.8
8	08_KA02_03_HPKNOT_V	Hydrocarbon gas from HP Knockout (V-0201A) to Gas/Gas Exchanger (E-0202A)	2	31.64	24	150	0.9	75.8
9	09_KA02_03_HPKNOB_L	<i>Hydrocarbon liquid from HP Knockout (V-0201A) to Secondary Knockout (V-0204A)</i>	<i>3</i> ^{Note 4}	<i>18.96</i>	<i>30</i>	-	-	-
10	10_KA02_03_SCDKOT_V	Hydrocarbon gas from Secondary Knockout (V-0204A) to LT Separator (V-0202A)	2	31.64	24	50	1.0	75.8

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
11	11_KA02_03_SCDKOB_L	<i>Hydrocarbon liquid from Secondary Knockout (V-0204A) to Gas/Condensate Exchanger (E-0201A)</i>	3 ^{Note 4}	18.96	30	-	-	-
12	12_KA02_03_GGEX1T_V	Hydrocarbon gas from Gas/Gas Exchanger (E-0202A) (tube side) to Gas/Gas Exchanger (E-0203A)	2	31.64	24	150	1.1	75.8
13	13_KA02_03_GGEX2T_V	Hydrocarbon gas from Gas/Gas Exchanger (E-0203A) (tube side) to LT Separator (V-0202A)	2	31.64	24	150	1.1	75.8
14	14_KA02_03_LTSEPT_V	Hydrocarbon gas from LT Separator (V-0202A) to Gas/Gas Exchanger (E-0203A)	4	22.8	14.21	150	2.3	75.8
15	15_KA02_03_GGEX1S_V	Hydrocarbon gas from Gas/Gas Exchanger (E-0203A) (shell side) to Gas/Gas Exchanger (E-0202A)	4	22.8	14.21	150	1.1	75.8
16	16_KA02_03_GGEX2S_V	Hydrocarbon gas from Gas/Gas Exchanger (E-0202A) (shell side) to gas export pipeline	5	22.56	22.4	200	61.7 ^{Note 3}	75.8
17	17_KA02_03_LTSEPB_L	<i>Hydrocarbon liquid from LT Separator (V-0202A) to Gas/Condensate Exchanger (E-0201A)</i>	3 ^{Note 4}	18.96	30	-	-	-
18	18_KA02_03_GCEXCS_L	<i>Hydrocarbon liquid from Gas/Condensate Exchanger (E-0201A) (shell side) to condensate export pipeline</i>	3 ^{Note 4}	18.96	30	-	-	-
19	19_KA02_03_FGK POT_V	Hydrocarbon gas from PCV-0216A through Fuel Gas KO Pot (V-0203A) and Instrument Gas Receiver (V-0205A) to XSV-0203A	5	7	22.4	40	0.1	75.8
20	20_KA02_04_FUELGS_V	Fuel gas from XSV-0203A to Inhibitor Pumps (P-0202A/B/C) and Methanol Pump (P-0203)	5	7	22.4	25	0.03	0.03
21	21_KA02_03_GASPIG_V	Gas Scraper Trap (A-0103) to A-0503	5	22.56	22.4	200	1.0	75.8
22	22_KA02_03_CONPIG_L	<i>Condensate Scraper Trap (A-0101B) to A-0501A</i>	3 ^{Note 4}	18.96	30	-	-	-
23	23_KA02_05_METT NK_L	Methanol Tank (T-0203) to Methanol Pump (P-0203)	Methanol	Atm.	Amb.	25	2.2	2.2

Notes:

1. Stream composition refers to the stream numbers in the HMB. The full HMB for all wellsites is attached Appendix 8.
2. Inventory from the wellhead section is considered to be unlimited because they can be supplied from the downhole reservoir.
3. Sections connecting to the pipeline inventories due to the lack of isolation valve.
4. Stream 3 is constituting of high water content (% water cut is >125%) and is not considered as flammable. Hence these sections are not considered in the QRA.

7.2 Release Frequency

The leak frequencies for the process releases are estimated for each representative hole size using parts count results and the historical leak frequencies. The leak frequencies for KA-2 sections are shown in Table 7-2.

Table 7-2: Hydrocarbon Release Frequencies for KA-2

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
1	01_KA02_01_WLHEAD_V	3.37E-05	1.38E-05	5.67E-06	1.84E-06		5.50E-05	0.2%
	KA02 Blowout				4.20E-05		4.20E-05	0.2%
2	02_KA02_02_FLWLNE_V	4.33E-04	1.88E-04	9.75E-05	1.16E-05		7.30E-04	2.8%
3	03_KA02_03_FLWLNE_V	6.85E-04	2.92E-04	1.55E-04	8.31E-06	1.44E-06	1.14E-03	4.4%
4	04_KA02_03_WSCOL1_V	1.10E-03	3.99E-04	1.59E-04	2.95E-05	3.91E-07	1.69E-03	6.5%
5	05_KA02_03_WSCOL2_V	1.37E-03	5.11E-04	2.18E-04	3.01E-05	5.22E-07	2.13E-03	8.2%
6	06_KA02_03_GCExCT_V	6.05E-04	3.22E-04	1.98E-04	1.14E-04	3.85E-07	1.24E-03	4.8%
7	07_KA02_03_LTSEPR_V	2.93E-04	1.27E-04	6.53E-05	6.06E-06	1.65E-06	4.93E-04	1.9%
8	08_KA02_03_HPKNOT_V	6.34E-04	2.86E-04	1.53E-04	3.44E-05	3.85E-07	1.11E-03	4.3%
9	09_KA02_03_HPKNOB_L	<i>Not flammable</i>						
10	10_KA02_03_SCDKOT_V	6.75E-04	3.04E-04	1.63E-04	3.81E-05		1.18E-03	4.6%
11	11_KA02_03_SCDKOB_L	<i>Not flammable</i>						
12	12_KA02_03_GGEX1T_V	6.96E-04	3.58E-04	2.17E-04	1.12E-04	3.85E-07	1.38E-03	5.3%
13	13_KA02_03_GGEX2T_V	8.90E-04	4.39E-04	2.45E-04	1.26E-04	3.85E-07	1.70E-03	6.6%
14	14_KA02_03_LTSEPT_V	1.10E-03	4.93E-04	2.64E-04	4.57E-05	2.91E-06	1.91E-03	7.4%
15	15_KA02_03_GGEX1S_V	1.01E-03	4.80E-04	2.36E-04	1.04E-04	3.85E-07	1.83E-03	7.1%
16	16_KA02_03_GGEX2S_V	2.62E-03	1.19E-03	6.14E-04	1.52E-04	4.96E-06	4.58E-03	17.7%
17	17_KA02_03_LTSEPB_L	<i>Not flammable</i>						
18	18_KA02_03_GCExCS_L	<i>Not flammable</i>						
19	19_KA02_03_FGK POT_V	1.39E-03	6.61E-04	4.84E-04			2.54E-03	9.8%
20	20_KA02_04_FUELGS_V	9.12E-04	3.91E-04	2.28E-04			1.53E-03	5.9%
21	21_KA02_03_GASPIG_V	1.12E-06	5.81E-07	3.21E-07	8.28E-08	2.65E-08	2.14E-06	0.01%
22	22_KA02_03_CONPIG_L	<i>Not flammable</i>						
23	23_KA02_05_METTNK_L	2.97E-04	1.26E-04	7.22E-05	5.00E-06	5.00E-06	6.05E-04	2.3%
TOTAL		1.47E-02	6.68E-03	3.57E-03	8.62E-04	1.88E-05	2.59E-02	
% Contribution		57%	26%	14%	3%	0.07%		

The total estimated release frequency from KA-2 is 2.59E-2 per year, or equivalent to one leak every 38.6 years. Most of the leaks are predicted to be from small leaks, where 83% of the leaks are from hole sizes less than 10 mm in diameter.

7.3 Risk Results

The risk results are presented in this section. The risk contours are contributed from both flammable and toxic risks from all release scenarios based on all the hazardous materials onsite.

The only toxic risk onsite is from the methanol tank due to methanol toxicity. As the methanol tank is stored at atmospheric condition with limited inventory (2.2 m³ at maximum capacity) and bunded, the methanol toxic risk is very minor and localised. Hence no separate toxic risk contour was provided. Methanol toxic effect was modelled by using the probit method as detailed in the Assumptions Register [Ref. 5].

The risk contour for KA-2 wellsite is presented in Figure 7-1.



Figure 7-1: Risk Contour for KA-2 Wellsite

The risk assessed against the HIPAP4 criteria are summarised in Table 7-3.

Table 7-3: LSIR Results Assessed Against the HIPAP4 Land Use Criteria for KA-2

LSIR	Risk Contour	HIPAP4 Land Use Criteria	Result
5E-05 / year	Blue	5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable.	Criteria met. The 5E-05 / year risk contour is within the site boundary.
1E-6 / year	Red	1E-6 / year risk contour should not extend to residential developments, hotels, tourist resorts.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.

7.4 Risk Contributors

The risk contributors to offsite risks at selected locations (points A and B) as shown in Figure 6-2 can be identified from the QRA model.



Figure 7-2: Location Selected to Identify Risk Contributors at KA-2

The risk contributors with the risk contributors and percentage of contribution are shown in Table 7-4.

Table 7-4: Risk Contributors to Selected Locations for KA-2

Point	LSIR (per year)	Contributor	% Contribution	Consequence
A	2.06E-06	13_KA02_03_GGEX2T_V_85mm (Hydrocarbon gas from Gas/Gas Exchanger (E-0203A) (tube side) to LT Separator (V-0202A))	17.6%	Jet fire due to early ignition
		06_KA02_03_GCEXCT_V_85mm (Hydrocarbon gas from Gas/Condensate Exchanger (E-0201A) (tube side) to LT Separator (V-0202A))	15.8%	Jet fire due to early ignition
		16_KA02_03_GGEX2S_V_85mm (Hydrocarbon gas from Gas/Gas Exchanger (E-0203A) (shell side) to Gas/Gas Exchanger (E-0202A))	15.8%	Jet fire due to early ignition
		12_KA02_03_GGEX1T_V_85mm (Hydrocarbon gas from Gas/Gas Exchanger (E-0202A) (tube side) to Gas/Gas Exchanger (E-0203A))	15.5%	Jet fire due to early ignition
B	1.29E-06	13_KA02_03_GGEX2T_V_85mm	18.7%	Jet fire due to early ignition
		06_KA02_03_GCEXCT_V_85mm	17.2%	Jet fire due to early ignition
		12_KA02_03_GGEX1T_V_85mm	16.6%	Jet fire due to early ignition
		16_KA02_03_GGEX2S_V_85mm	10.0%	Jet fire due to early ignition

The risk contributor analysis shows that the offsite risk contributors are jet fires from early ignition from large releases (85 mm) from multiple heat exchangers that are connected with the gas export pipeline, and hence sharing a large inventory. The main risk contributors at both offsite locations are the same (with slight differences in the percentage of contributions due to the equipment locations).

It should be noted that Safeti cannot consider the effect of the obstacles / objects located along the way where the heat is radiated from the release source. In reality heat may be shielded by some process equipment / piping before extending offsite. Safeti also cannot consider the ground topography for pool spread, instead, flat area is assumed and the pool can spread until it reaches a bund wall or the pool formed minimum thickness (normally 5 mm).

8. WELLSITE KA-4 AND KA-14

8.1 Release Scenarios

The P&IDs showing the isolatable sections for KA-4 and KA-14 are presented in Appendix 3. Table 8-1 details the section description and the respective operating conditions that are used in the QRA.

Table 8-1: Release Scenarios and Operating Conditions for KA-4 and KA-14

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
1	01_KA04_01_KA4WHD_V	KA-04 wellhead	37	18	17.6	100	Unlimited ^{Note 2}	
3	03_KA04_03_KA14WH_V	KA-14 wellhead	40	19.2	18.6	100	Unlimited ^{Note 2}	
5	05_KA04_05_KA14FW_V	Wellfluid from KA-14 wellhead to SDV-2430B	40	19.2	18.6	100	0.6	0.6
6	06_KA04_06_KA14CK_V	Wellfluid from SDV-2430B to the commingled line	41	18.5	18.1	150	0.0	1.4
7	07_KA04_06_KA4FLW_V	Wellfluid from KA-4 wellhead to the commingled line	38	16.2	16.1	150	1.0	1.4
8	08_KA04_06_MIXFLW_V	Mixed flow to SDV-2404A	39	18.3	13.5	100	0.4	1.4
9	09_KA04_07_METTNK_L	Methanol Tank (T-2429) to Methanol Pumps	Methanol	Atm.	Amb.	50	4.7	4.7
10	10_KA04_08_GASPPL_V	Dry gas pipeline from KA-8 Launcher A-2814 to XSV-2440A	33	17.21	30	250	18.1 ^{Note 3}	19.1
11	11_KA04_08_GASPIG_V	Scraper Launcher (A-2440)	33	17.21	30	250	1.0	19.1
<i>Sensitivity Cases</i>								
12	12_KA04_09_MTPPLN_V	From SDV-2404A to multiphase pipeline	39	18	27	100	20.8 ^{Note 3}	20.8
13	13_KA04_10_GASPLN_V	Gas pipeline from KA-8 A-2813 to KPS Receiver A-502D	33	17.21	30	150	85.8 ^{Note 3}	85.8
14	14_KA04_11_GASKA7_V	From XSV-2440A to Dry Gas Pipeline to KA-7	33	17.21	30	250	97.2 ^{Note 3}	97.2
15	15_KA04_08_GASPPL_V	Dry gas pipeline from KA-8 Launcher A-2814 to KA-4/14	33	17.21	30	250	18.1 ^{Note 3}	19.1

Notes:

1. Stream composition refers to the stream numbers in the HMB. The full HMB for all wellsites is attached Appendix 8.
2. Inventory from the wellhead section is considered to be unlimited because they can be supplied from the downhole reservoir.
3. Sections connecting to the pipeline inventories due to the lack of isolation valve.

8.2 Release Frequency

The leak frequencies for the process releases are estimated for each representative hole size using parts count results and the historical leak frequencies. The leak frequencies for KA-4 and KA-14 sections for the base case are shown in Table 6-2. The KA-14 well is only in operation for 24 hours every 10 days.

Table 8-2: Hydrocarbon Release Frequencies for KA-4 and KA-14 (Base Case)

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
1	01_KA04_01_KA4WHD_V	3.37E-05	1.38E-05	5.67E-06	1.84E-06		5.50E-05	0.9%
	KA-04 Blowout				4.20E-05		4.20E-05	0.7%
3	03_KA04_03_KA14WH_V	3.37E-06	1.38E-06	5.67E-07	1.84E-07		5.50E-06	0.1%
	KA-14 Blowout				4.20E-06		4.20E-06	0.1%
5	05_KA04_05_KA14FW_V	3.06E-05	1.33E-05	6.71E-06	1.13E-06		5.17E-05	0.9%
6	06_KA04_06_KA14CK_V	1.40E-04	5.92E-05	3.22E-05	4.30E-07	1.26E-07	2.32E-04	3.9%
7	07_KA04_06_KA4FLW_V	1.33E-03	5.66E-04	2.98E-04	1.78E-05	2.14E-06	2.21E-03	37.1%
8	08_KA04_06_MIXFLW_V	1.01E-03	4.36E-04	2.12E-04	3.79E-05		1.70E-03	28.4%
9	09_KA04_07_METTNK_L	2.49E-04	2.18E-04	6.64E-05	2.66E-05	5.00E-06	5.65E-04	9.5%
10	10_KA04_08_GASPL_V	6.45E-04	2.86E-04	1.51E-04	2.05E-05	3.69E-06	1.11E-03	18.5%
11	11_KA04_08_GASPIG_V	1.83E-07	9.46E-08	5.25E-08	1.35E-08	4.39E-09	3.48E-07	0.01%
	TOTAL	3.44E-03	1.59E-03	7.73E-04	1.53E-04	1.10E-05	5.97E-03	100.0%
	% Contribution	58%	20%	10%	2%	0.1%		

The total leak frequency for KA-4 and KA-14 wellsite (for the base case) is 5.97E-03 per year, which is equivalent to one leak every 167 years. Most of the leaks are predicted to be from small leaks, where 78% of the leaks are from hole sizes less than 10 mm diameter.

The leak frequencies for KA-4 and KA-14 sections for the sensitivity case are shown in Table 8-3.

Table 8-3: Hydrocarbon Release Frequencies for KA-4 and KA-14 (Sensitivity Case)

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
12	12_KA04_09_MTPPLN_V	2.30E-04	9.88E-05	5.12E-05	6.01E-06		3.86E-04	4.8%
13	13_KA04_10_GASPLN_V	5.18E-04	2.22E-04	1.19E-04	6.49E-06	9.87E-07	8.66E-04	10.7%
14	14_KA04_11_GASKA7_V	6.03E-05	2.81E-05	1.43E-05	2.86E-06	8.86E-07	1.06E-04	1.3%
15	15_KA04_08_GASPL_V	4.64E-04	2.03E-04	1.10E-04	1.01E-05	1.24E-06	7.88E-04	9.7%
	TOTAL (Base Case and Sensitivity)	4.71E-03	2.14E-03	1.07E-03	1.78E-04	1.41E-05	8.12E-03	
	% Contribution	58%	26%	13%	2%	0.2%		

The total leak frequencies for KA-19 wellsite (including the sensitivity cases) is 8.12E-03 per year, which is equivalent to one leak every 123 years.

8.3 Risk Results

The risk results are presented in this section. The risk contours are contributed from both flammable and toxic risks from all release scenarios based on all the hazardous materials onsite.

The only toxic risk onsite is due to methanol toxicity from the methanol tank. As the methanol tank is stored at atmospheric condition with limited inventory (4.7 m³ at maximum capacity) and bunded, the methanol toxic risk is very minor and localised. Hence no separate toxic risk contour was provided. Methanol toxic effect was modelled by using the probit method as detailed in the Assumptions Register [Ref. 5].

8.3.1 Base Case

The base case risk contour for KA-4 and KA-14 wellsite is presented in Figure 8-1.



Figure 8-1: Risk Contour for KA-4 and KA-14 Wellsite (Base Case)

The risk assessed against the HIPAP4 criteria for the base case are summarised in Table 8-4.

Table 8-4: LSIR Results Assessed Against the HIPAP4 Land Use Criteria for KA-4 and KA-14 (Base Case)

LSIR	Risk Contour	HIPAP4 Land Use Criteria	Result
5E-05 / year	Blue	5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable.	Criteria met. The 5E-05 / year risk contour is within the site boundary.
1E-6 / year	Red	1E-6 / year risk contour should not extend to residential developments, hotels, tourist resorts.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.

8.3.2 Sensitivity Case

The risk contour for KA-4/14 wellsite sensitivity case, which include the gathering pipeline sections is presented in Figure 8-2.




Figure 8-2: Risk Contour for KA-4 and KA-14 Wellsite (Sensitivity Case)

The risk contours for the sensitivity case similar to the base case and the assessment against the HIPAP4 criteria is the same, hence is it not repeated.

8.4 Risk Contributors

For both the base case and sensitivity cases, the 5E-05 / year risk contour and the 1E-06 /year risk contour remain within the site boundary. This is due to the low operating frequencies for the KA-4 well. As the risk contours did not extend offsite, no locations were selected for risk contributor identification.

9. WELLSITE KA-5 AND KA-10

9.1 Release Scenarios

The P&IDs indicate the isolatable sections presented in Appendix 4 for KA-5, which is the only producing well at this wellsite. Table 9-1 details the section description and the respective operating conditions that are used in the QRA.

Table 9-1: Release Scenarios and Operating Conditions for KA-5

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
Base Cases								
1	01_KA05_01_WLHEAD_L	Wellstream fluid from KA-05 wellhead to XSV-0500B	6	23.3	28.13		<i>Unlimited</i> ^{Note 2}	
2	02_KA05_02_FLWLNE_L	Wellstream fluid from XSV-0500B to Desander (V-0516)	6	23.3	28.13	150	0.1	3.2 ^{Note 4}
3	03_KA05_02_DESAND_L	Wellstream fluid from Desander (V-0516) to choke valve PCV-0514A	6	23.3	28.13	150	2.4	3.2 ^{Note 4}
4	04_KA05_02_CHKLNE_L	Wellstream fluid choke valve PCV-0514A to XSV-0514A	7	18	22.33	150	0.7	3.2 ^{Note 5}
5	05_KA05_03_METHTK_L	Methanol Tank (T-0509) to Methanol Pump (P-0509)	Methanol	Atm	Amb	25	0.5	0.5
Sensitivity Cases								
7	07_KA05_04_LIQPIP_L	Wellstream fluid from XSV-0514A mix with condensate from A-2614 to liquid pipeline to KA-13 and KPS	8	18	21	150	1.9	57.4 ^{Note 3, 6}
8	08_KA05_05_KA6PPL_V	Gas from KA-6 & KA-11 passing through KA-5 to KA-13 and KPS	13	20.71	22.93	250	5.2	158.1 ^{Note 3}

Notes:

- Stream composition refers to the stream numbers in the HMB. The full HMB for all wellsites is attached Appendix 8.
- Inventory from the wellhead section is considered to be unlimited because they can be supplied from the downhole reservoir.
- Sections connecting to the pipeline inventories due to the lack of isolation valve.

4. Inventories for modelling the 6 mm leak was increased to 133 kg, 1,791 kg for 22 mm and 26,728 kg for 85 mm leak, assuming the delayed detection and isolation of 15 min (i.e., the releases can sustain up to 15 min). This is conservatively assumed that the leaks can sustain at initial pressure with no depressurisation at the system.
5. Inventories for modelling the 6 mm leak was increased to 103 kg, 1,388 kg for 22 mm and 20,714 Inventory for modelling the 85 mm leak was increased to 24,839 kg, assuming the delayed detection and isolation of 15 min (i.e., the releases can sustain up to 15 min). This is conservatively assumed that the leak can sustain at initial pressure with no depressurisation at the system.
6. Inventory for modelling the 85 mm leak was increased to 21,428 kg, assuming the delayed detection and isolation of 15 min (i.e., the releases can sustain up to 15 min). This is conservatively assumed that the leaks can sustain at initial pressure with no depressurisation at the system.

9.2 Release Frequency

The leak frequencies for the process releases are estimated for each representative hole size using parts count results and the historical leak frequencies. The leak frequencies for KA-5 sections for the base case are shown in Table 9-2.

Table 9-2: Hydrocarbon Release Frequencies for KA-5 (Base Case)

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
1	01_KA05_01_WLHEAD_L	3.37E-05	1.38E-05	5.67E-06	1.13E-06	7.09E-07	3.37E-05	1.1%
	KA-05 Blowout					4.20E-05	4.20E-05	0.9%
2	02_KA05_02_FLWLNE_L	5.97E-04	2.50E-04	1.34E-04	2.04E-06	4.47E-07	5.97E-04	20.4%
3	03_KA05_02_DESAND_L	8.91E-04	4.14E-04	2.21E-04	6.15E-05	2.63E-06	8.91E-04	33.0%
4	04_KA05_02_CHKLNE_L	8.30E-04	3.56E-04	1.88E-04	1.24E-05	2.75E-06	8.30E-04	28.9%
5	05_KA05_03_METHTK_L	4.45E-04	2.93E-04	1.17E-04	5.00E-06	5.00E-06	8.69E-04	15.7%
	TOTAL	2.80E-03	1.33E-03	6.65E-04	8.21E-05	5.35E-05	4.92E-03	100.0%
	% Contribution	57%	27%	14%	2%	1%		

The total leak frequency for KA-5 wellsite (for the base case) is 4.92E-03 per year, which is equivalent to one leak every 208 years. Most of the leaks are predicted to be from small leaks, where 86% of the leaks are from hole sizes less than 10 mm diameter.

The leak frequencies for KA-5 sections for the sensitivity case are shown in Table 9-3.

Table 9-3: Hydrocarbon Release Frequencies for KA-5 (Sensitivity Case)

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
7	07_KA05_04_LIQPIP_L	7.27E-04	3.09E-04	1.65E-04	8.32E-06	1.39E-06	1.21E-03	17.3%
8	08_KA05_05_KA6PPL_V	5.12E-04	2.27E-04	1.22E-04	1.72E-05	2.99E-06	8.80E-04	12.6%
	TOTAL (Base Case and Sensitivity)	4.03E-03	1.86E-03	9.51E-04	1.08E-04	5.79E-05	7.01E-03	
	% Contribution	58%	27%	14%	2%	0.8%		

The total leak frequency for KA-5 wellsite (including the sensitivity cases) is 7.01E-03 per year, which is equivalent to one leak every 143 years.

9.3 Risk Results

The risk results are presented in this section. The risk contours are contributed from both flammable and toxic risks from all release scenarios based on all the hazardous materials onsite.

The only toxic risk onsite is due to methanol toxicity from the methanol tank. As the methanol tank is stored at atmospheric condition with limited inventory (0.5 m³ at maximum capacity) and banded, the methanol toxic risk is very minor and localised. Hence no separate toxic risk contour was provided. Methanol toxic effect was modelled by using the probit method as detailed in the Assumptions Register [Ref. 5].

9.3.1 Base Case

The base case risk contour for KA-5 and KA-10 wellsite is presented in Figure 9-1.



Figure 9-1: Risk Contour for KA-5 and KA-10 Wellsite (Base Case)

The risk assessed against the HIPAP4 criteria for the base case are summarised in Table 9-4.

Table 9-4: LSIR Results Assessed Against the HIPAP4 Land Use Criteria for KA-5 and KA-10 (Base Case)

LSIR	Risk Contour	HIPAP4 Land Use Criteria	Result
5E-05 / year	Blue	5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable.	Criteria met. The 5E-05 / year risk contour is within the site boundary.
1E-6 / year	Red	1E-6 / year risk contour should not extend to residential developments, hotels, tourist resorts.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.

9.3.2 Sensitivity Case

The risk contour for KA-5 and KA-10 wellsite sensitivity case, which include the gathering pipeline sections is presented in Figure 9-2.



Figure 9-2: Risk Contour for KA-5 and KA-10 Wellsite (Sensitivity Case)

The risk contours for the sensitivity case are slightly larger compared to the base case due to the additional sections, however the assessment against the HIPAP4 criteria is the same. Hence it is not repeated.

9.4 Risk Contributors

For both the base case and sensitivity cases, the 5E-05 / year risk contour and the 1E-06 / year risk contour remain within the site boundary. This is because there is only very limited equipment onsite. As the risk contours did not extend offsite, no locations were selected for risk contributor identification.

10. WELLSITE KA-6, KA-11 AND KA-17

10.1 Release Scenarios

The P&IDs indicate the isolatable sections presented in Appendix 5 for KA-6 and KA-17, which are the producing wells at this wellsite. The wellsite modification from CUSP Phase 3 has been considered in this revision of the report, which includes the bypass of the High Pressure Knockout vessel (V-2654) and the installation of new header. V-2654 is currently isolated and will be permanently disconnected from process as part of the execution of the project, which the vessel may remain on site post CUSP until permanently demolished and removed. If the vessel were to be brought back into operation, it will require a consent and the QRA will be updated.

Table 10-1 details the section description and the respective operating conditions that are used in the QRA.

Table 10-1: Release Scenarios and Operating Conditions for KA-6 and KA-17

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
1	01_KA06_01_WLHEAD_V	Wellstream fluid from KA-06 wellhead to XSV-2600	9	36.5	28.18	150	Unlimited ^{Note 2}	
2	02_KA17_02_WLHEAD_V	Wellstream fluid from KA-17 wellhead to XSV-2680A	14	22	29.82	150	Unlimited ^{Note 2}	
3	03_KA06_03_DESAND_V	Wellstream fluid from XSV-2600 through KA-6 Desander (V-2601) to Wellstream Cooler (E-2651)	9	36.5	28.2	150	2.5	11.0
4	04_KA17_03_DESAND_V	Wellstream fluid from XSV-2680A through KA-17 Desander (V-2682) to condensate pipeline	14	22	29.8	150	3.0	11.0
6	06_KA06_03_WSCOOL_V	Wellstream fluid from Wellstream Cooler (E-2651) to gas pipeline	9	36.5	28.2	150	1.4	11.0
7	07_KA06_03_GASPLN_V	Wellstream fluid from Wellstream Cooler (E-2651) to XSV-2671A to gas pipeline	9	36.5	28.2	250	1.5	11.0
8	08_KA06_03_CONPLN_L	Wellstream fluid from KA-17 well to XSV-2672A	14	22	29.8	150	0.5	11.0 ^{Note 4}
9	09_KA06_03_GASPIG_V	Scraper Trap (A-2613) on gas gathering pipeline	9	36.5	28.2	250	1.1	11.0
10	10_KA06_03_CONPIG_L	Scraper Trap (A-2614) on condensate gathering pipeline	14	22	29.8	150	1.0	11.0 ^{Note 4}
12	12_KA06_04_METNK2_L	Methanol Tank (T-2609) to Methanol Pumps (P-2609A & C)	Methanol	Atm.	Amb.	50	2.2	2.2

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
<i>Sensitivity Cases</i>								
14	14_KA06_05_GASPLN_V	Gas pipeline to KA-05	9	36.5	28.2	250	152.9 ^{Note 3}	152.9
15	15_KA06_06_CONPLN_L	Condensate pipeline to KA-05	14	22	29.8	150	55.5 ^{Note 3}	55.5 ^{Note 5}

Notes:

1. Stream composition refers to the stream numbers in the HMB. The full HMB for all wellsites is attached Appendix 8.
2. Inventory from the wellhead section is considered to be unlimited because they can be supplied from the downhole reservoir.
3. Sections connecting to the pipeline inventories due to the lack of isolation valve.
4. Inventories for modelling the 22 mm leak was increased to 1,664 kg, and 24,839 kg for 85 mm leak, assuming the delayed detection and isolation of 15 min (i.e., the releases can sustain up to 15 min). This is conservatively assumed that the leaks can sustain at initial pressure with no depressurisation at the system.
5. Inventory for modelling the 85 mm leak was increased to 24,839 kg, assuming the delayed detection and isolation of 15 min (i.e., the releases can sustain up to 15 min). This is conservatively assumed that the leak can sustain at initial pressure with no depressurisation at the system.

10.2 Release Frequency

The leak frequencies for the process releases are estimated for each representative hole size using parts count results and the historical leak frequencies. The leak frequencies for KA-6 and KA-17 sections for the base case are shown in Table 10-2.

Table 10-2: Hydrocarbon Release Frequencies for KA-6 and KA-17 (Base Case)

No.	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
1	01_KA06_01_WLHEAD_V	3.37E-05	1.38E-05	5.67E-06	1.13E-06	7.09E-07	5.50E-05	0.3%
	KA-06 Blowout					4.20E-05	4.20E-05	0.3%
2	02_KA17_02_WLHEAD_V	3.37E-05	1.38E-05	5.67E-06	1.13E-06	7.09E-07	5.50E-05	0.4%
	KA-17 Blowout					4.20E-05	4.20E-05	0.4%
3	03_KA06_03_DESAND_V	2.09E-03	9.26E-04	4.97E-04	7.38E-05	4.39E-06	3.59E-03	26.6%
4	04_KA17_03_DESAND_V	1.90E-03	8.51E-04	4.58E-04	7.86E-05	4.17E-06	3.30E-03	24.4%
6	06_KA06_03_WSCOOOL_V	1.57E-03	5.98E-04	2.67E-04	3.14E-05	8.95E-07	2.46E-03	18.2%
7	07_KA06_03_GASPLN_V	8.40E-04	3.76E-04	2.03E-04	3.56E-05	4.22E-06	1.46E-03	10.8%
8	08_KA06_03_CONPLN_L	1.01E-03	4.41E-04	2.40E-04	1.79E-05	2.72E-06	1.71E-03	12.7%
9	09_KA06_03_GASPIG_V	1.14E-06	5.93E-07	3.29E-07	8.87E-08	2.65E-08	2.18E-06	0.02%
10	10_KA06_03_CONPIG_L	1.13E-06	5.86E-07	3.25E-07	1.62E-07	5.27E-11	2.20E-06	0.02%
12	12_KA06_04_METNK2_L	3.82E-04	2.74E-04	1.19E-04	5.00E-06	5.00E-06	7.85E-04	5.8%
	TOTAL	7.86E-03	3.49E-03	1.80E-03	2.45E-04	1.07E-04	1.35E-02	100.0%
	% Contribution	58%	26%	13%	1.8%	0.8%		

The total leak frequency for KA-6/17 wellsite (for the base case) is 1.35E-02 per year, which is equivalent to one leak every 74 years. Most of the leaks are predicted to be from small leaks, where 84% of the leaks are from hole sizes less than 10 mm diameter.

The leak frequencies for KA-6 and KA-17 sections for the sensitivity case are shown in Table 10-3.

Table 10-3: Hydrocarbon Release Frequencies for KA-6 (Sensitivity Case)

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
14	14_KA06_05_GASPLN_V	7.53E-05	3.61E-05	1.89E-05	5.56E-06	8.86E-07	1.37E-04	1.0%
15	15_KA06_06_CONPLN_L	5.93E-05	2.46E-05	1.07E-05	1.76E-06	3.85E-07	9.67E-05	0.7%
	TOTAL (Base Case and Sensitivity)	8.00E-03	3.56E-03	1.83E-03	2.52E-04	1.08E-04	1.37E-02	
	% Contribution	58%	26%	13%	2%	0.8%		

The total leak frequency for KA-6/17 wellsite (including the sensitivity cases) is 1.37E-02 per year, which is equivalent to one leak every 73 years.

10.3 Risk Results

The risk results are presented in this section. The risk contours are contributed from both flammable and toxic risks from all release scenarios based on all the hazardous materials onsite.

The only toxic risk onsite is due to methanol toxicity from the methanol tank. As the methanol tank is stored at atmospheric condition with limited inventory (2.2 m³ at maximum capacity) and bunded, the methanol toxic risk is very minor and localised. Hence no separate toxic risk contour was provided. Methanol toxic effect was modelled by using the probit method as detailed in the Assumptions Register [Ref. 5].

10.3.1 Base Case

The base case risk contour for KA-6/17 wellsite is presented in Figure 10-1.



Figure 10-1: LSIR Contours for KA-6/17 Wellsite (Base Case)

The risk assessed against the HIPAP4 criteria are summarised in Table 10-4.

Table 10-4: LSIR Results Assessed Against the HIPAP4 Land Use Criteria for KA-6/17 (Base Case)

LSIR	Risk Contour	HIPAP4 Land Use Criteria	Result
5E-05 / year	Blue	5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable.	Criteria met. The risk level is lower than 5E-05 / year.
1E-6 / year	Red	1E-6 / year risk contour should not extend to residential developments, hotels, tourist resorts.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.

10.3.2 Sensitivity Case

The LSIR for KA-6/17 wellsite sensitivity case, which include the gathering pipeline sections is presented in Figure 10-2.



Figure 10-2: LSIR Contours for KA-6/17 Wellsite (Sensitivity Case)

The risk contours for the sensitivity case are slightly larger compared to the base case due to the additional sections, however the assessment against the HIPAP4 criteria is the same. Hence is it not repeated.

10.4 Risk Contributors

The risk contributors to offsite risks at selected location (point A) as shown in Figure 6-2 can be identified from the QRA model.



Figure 10-3: Location Selected to Identify Risk Contributors at KA-6/17 wellsite

10.4.1 Base Case

The risk contributors for the base case with the risk contributors and percentage of contribution are shown in Table 10-5.

Table 10-5: Risk Contributors to Selected Locations for KA-6/17 (Base Case)

Point	LSIR (per year)	Contributor	% Contribution	Consequence
A	1.83E-06	07_KA06_03_GASPLN_V_85 mm (horizontal release) (Wellstream fluid from Wellstream Cooler (E-2651) to gas export pipeline)	44.1%	Fireball from early ignition
		07_KA06_03_GASPLN_V_85 mm (vertical release) (Wellstream fluid from Wellstream Cooler (E-2651) to gas export pipeline)	18.9%	Fireball from early ignition
		07_KA06_03_GASPLN_V_194 mm (horizontal release) (Wellstream fluid from Wellstream Cooler (E-2651) to gas export pipeline)	18.4%	Fireball from early ignition (96%) Flash fire from delayed ignition (4%)

The risk contributor analysis shows that the offsite risk contributors are contributed by one scenario, which is the wellstream fluid from the Wellstream Cooler (E-2651) to the gas export pipeline isolation valve from large releases. This is because the leak frequency from this section is relatively high (contributed 10.8% to the total wellsite leak frequency) and the equipment are close to the boundary at the north.

10.4.2 Sensitivity Case

The risk contributors for the sensitivity case with the risk contributors and percentage of contribution are shown in Table 10-6.

Table 10-6: Risk Contributors to Selected Locations for KA-6/17 (Sensitivity Case)

Point	LSIR (per year)	Contributor	% Contribution	Consequence
A	1.86E-06	07_KA06_03_GASPLN_V_85 mm (horizontal release) (Wellstream fluid from Wellstream Cooler (E-2651) to gas export pipeline)	43.4%	Fireball from early ignition
		07_KA06_03_GASPLN_V_85 mm (vertical release) (Wellstream fluid from Wellstream Cooler (E-2651) to gas export pipeline)	18.6%	Fireball from early ignition
		07_KA06_03_GASPLN_V_194 mm (horizontal release) (Wellstream fluid from Wellstream Cooler (E-2651) to gas export pipeline)	18.1%	Fireball from early ignition (96%) Flash fire from delayed ignition (4%)

The risk contributors for the sensitivity case are almost consistent with the base case, where the offsite risk contributors are contributed the same scenario, which is the which is the wellstream fluid from the Wellstream Cooler (E-2651) to the gas export pipeline isolation valve from large release.

It should be noted that Safeti cannot consider the effect of the obstacles / objects located along the way where the heat is radiated from the release source. In reality heat may be shielded by some process equipment / piping before extending offsite.

11. WELLSITE KA-8, KA-12, KA-15 AND KA-18

11.1 Release Scenarios

The P&IDs indicate the isolatable sections presented in Appendix 6 for KA-8 and KA-18, which are the producing wells at this wellsite. The wellsite modification from CUSP Phase 3 has been considered in this revision of the report, which include the installation of two slug catcher pumps (P-28201/28202). Table 11-1 details the section description and the respective operating conditions that are used in the QRA.

Table 11-1: Release Scenarios and Operating Conditions for KA-8 and KA-18

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
1	01_KA08_01_WLHEAD_V	Wellstream fluid from KA-08 wellhead (XSV-2801) to XSV-2820	28	23.83	28.09	100	<i>Unlimited</i> ^{Note 2}	
2	02_KA08_02_FLWLNE_V	Wellstream fluid from XSV-2820 (KA-08) to XCV-2858E, XCV-2858D, XCV-2858C, XCV-2840C, XCV-2840E, XCV-2840F and XSV-2800	28	23.83	28.09	150	1.65	1.65
3	03_KA18_03_WLHEAD_V	Wellstream fluid from KA-18 wellhead (XSV-2850A) to SDV-2850B	21	29.68	34.01	100	<i>Unlimited</i> ^{Note 2}	
4	04_KA18_04_CHKLNE_V	Wellstream fluid from SDV-2850b to choke valve HCV-2850A	21	29.68	34.01	150	0.10	0.21
5	05_KA18_04_CHKLNE_V	Wellstream fluid from choke valve HCV-2850A to XCV2840D and XCV-2840F	22	22.06	30.76	150	0.11	0.21
6	06_KA18_05_SLGCAT_V	Wellstream fluid from XCV-2840D to Slug Catcher (V-2858) and SDV-2858A and HCV2858A	23	19.5	21.54	250	2.62	34.30
7	07_KA18_05_SLGCAT_V	Vapour from Slug Catcher (V-2858) to Separators V-9010 and V-9020, XCV-2858E and XCV-2858C	27	19.52	21.54	250	31.68	34.30
8	08_KA08_06_COMGAS_V	Compressed Gas from Compressors A-9101 and A-9201 (from SDV-9101G, SDV-9201G, XCV-2840E, XCV-2858D) to SDV-2808A and XCV-2840C	32	51.67	34.50	150	3.57	3.57

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
9	09_KA18_07_WGSLTS_V	Wet Gas from XSV-2863A, TCV-2808B, Gas Exchangers E-2801/2 and LTS Vessel V-2804 and Pig Receiver (A-2863) to SDV-2858A and HCV-2858A, Pig Launchers A-2913 and A2814 and through Fuel Gas Heater E-9030 to SDV-9030A	43	39.17	15.25	150	6.18	15.52
10	10_KA18_07_PIGL13_V	Pig Launcher A-2813	33(2)	39.05	26.45	150	1.02	15.52
11	11_KA18_07_PIGL14_V	Pig Launcher A-2814	33(2)	39.05	26.45	100	0.01	15.52
12	12_KA08_07_GASEXC_V	Hydrocarbon Gas from XSV-2800 through Tube side Gas/condensate exchanger E-2800, though LTS vessel V-2804 to HPKO V-2803	32	51.67	34.50	150	0.73	15.52
13	13_KA08_07_HPKOGS_V	Hydrocarbon Gas from HP KO V-2803 to PCVs 2804A/E	40	51.17	23.74	150	2.94	15.52
14	14_KA08_07_CLSSFR_L	<i>Hydrocarbon Liquid from HP KO V-2803 through Classifier V-2805 to LCV-2805 ^{Note 4}</i>	38	39.17	34.00	-	-	-
15	15_KA08_07_CONEXC_L	Hydrocarbon Liquid from LTS V-2804 and LCV-2805 to TICV-2804A	46	39.15	20.00	50	2.24	15.52
16	16_KA18_08_LPIG64_L	Wellstream liquids from SDV-2808C and SDV-2858B to Pig Launcher A-2864	33	17.21	30.00	100	0.31	26.08
17	17_KA18_08_LPIG64_L	Pig Launcher A-2864	33	17.21	30.00	100	1.01	26.08
18	18_KA08_09_SEPRTR_V	Hydrocarbon Gas from Separator V-9010 to shut down valves SDV-9101C/D	31	19.43	22.18	200	4.68	8.41
19	19_KA08_09_SEPRTR_L	<i>Hydrocarbon Liquid from Separator V-9010 to SDV-9015C ^{Note 4}</i>	30	19.43	22.18	-	-	-
20	20_KA08_09_BLWCSE_L	<i>Hydrocarbon liquid from SDV-9141C to Separator V-9010 ^{Note 4}</i>	-	-	-	-	-	-
21	21_KA08_09_PUMPBP_L	<i>Hydrocarbon Liquid from SDV-9015C through P-9015 to SDV-9015A ^{Note 4}</i>	30	19.43	22.18	-	-	-
22	22_KA08_09_BLWCSE_V	Hydrocarbon gas from SDVs SDV-9101H, SDV-9141B, SDV-9141A through Blowcase V-9141 to Suction Scrubber V-9111	32	51.67	34.50	80	0.10	8.41

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
23	23_KA08_09_COOLER_V	Hydrocarbon Gas from SDV-9101C/D to suction scrubbers V-9111 & V-9121, TCV-9101A and PCV-9101C	31	19.43	22.18	100	0.01	8.41
24	24_KA08_09_SS9111_V	Hydrocarbon Gas from Suction Scrubber V-9111 and SDV-9131A to Compressor K-9101A	31	19.43	22.18	150	1.73	8.41
25	25_KA08_09_SS9121_V	Hydrocarbon Gas from Suction Scrubber V-9121 to Compressor K-9101B	31	19.43	22.18	150	1.69	8.41
26	26_KA08_09_COMPSTR_V	Hydrocarbon Gas from Compressors K-9101A/B through Afterstage Coolers E-9131A/B to SDV-9101F, SDV-9101G, PCV-9101C and TCV-9101A	32	51.67	34.50	100	0.19	8.41
27	27_KA18_10_SEPRTR_V	Hydrocarbon Gas from Separator V-9020 to shut down valves SDV-9201C/D	31	19.43	22.18	200	4.68	6.76
28	28_KA18_10_SEPRTR_L	<i>Hydrocarbon Liquid from Separator V-9020 to SDV-9025C ^{Note 4}</i>	30	19.43	22.18	-	-	-
29	29_KA18_10_BLCWSE_L	<i>Hydrocarbon Liquid from SDV-9241C to Separator V-9020 ^{Note 4}</i>	-	-	-	-	-	-
30	30_KA18_10_COOLER_V	Hydrocarbon Gas from SDV-9201C/D, TCV-9201A and PCV-9201C	31	19.43	22.18	150	0.01	6.76
31	31_KA18_10_SS9111_V	Hydrocarbon Gas from Suction Scrubber V-9211 and SDV-9241A to Compressor K-9201A	32	51.67	34.50	150	1.73	6.76
32	32_KA18_10_SS9101_V	Hydrocarbon Gas from Suction Scrubber V-9221 to Compressor K-9201B	31	19.43	22.18	150	0.03	6.76
33	33_KA18_10_PUMPBP_L	<i>Hydrocarbon Liquid from SDV-9025C through P-9025 to SDV-9025A ^{Note 4}</i>	30	19.43	22.18	-	-	-
34	34_KA18_10_BLCWSE_V	Hydrocarbon Liquid from SDVs SDV-9201H, SDV-9241B, SDV-9241A through Blowcase V-9241 to SDV-9241C	32	51.67	34.50	50	0.10	6.76
35	35_KA18_10_COMPSTR_V	Hydrocarbon Gas from Compressors K-9201A/B through Afterstage Coolers E-9231A/B to SDV-9201F, SDV-9201G, PCV-9201C and TCV-9201A	32	51.67	34.50	100	0.19	6.76

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
36	36_KA18_07_FUELGVS_V	Fuel Gas from SDV-9030A to PCVs 9030B/C	33(2)	39.05	26.45	50	0.01	15.52
37	37_KA18_07_FLGSSS_V	Fuel Gas from PCVs 9030B/C through Fuel Gas Scrubber V-9031 to SDV-9101A and SDV-9201A	33(2)	7	26.45	80	0.13	15.52
38	38_KA08_07_FLGSEP_V	Fuel gas from SDV-9101A through fuel gas coalescing separator (F-9171) to PCV-9101D and PCV-9101E	33(2)	3.45	26.45	50	0.59	15.52
39	39_KA18_07_FLGSEP_V	Fuel Gas from SDV-9201A through fuel gas coalescing separator (F-9271) to PCV-9201D and PCV-9201E	33(2)	3.45	26.45	50	0.63	15.52
40	40_KA18_11_GASEXC_V	Dry Gas from LTS Unit B V-2080 through Gas exchangers E-2816, E-2817 and E-2818 to TCV-2808B	33(2)	39.05	26.45	150	2.41	2.41
41	41_KA18_08_LTSUNB_V	Dry Gas from PCV-2808A to LTS Unit B V-2080	33(2)	39.05	26.45	100	7.73	9.99
42	42_KA18_08_LTSUNB_L	Liquid from LTS Unit B V-2080 to SDV-2808C	33	17.21	30.00	80	7.66	26.08
43	43_KA18_08_SHLEXC_V	Gas from LTS V-2808 through Gas exchangers (E-2816/7/8) back to LTS V-2808	32	51.67	34.50	150	2.25	9.99
44	44_KA18_07_GPIG63_V	Pig Receiver A-2863	33(2)	39.05	26.45	250	1.05	15.52
45	45_KA18_14_MTHNOL_L	Methanol storage tank (T-2866) to Pumps P-2884/2876/2877/2878	Methanol	Atm.	Amb.	50	4.68	6.24
46	46_KA18_14_MT2884_L	Methanol from Pump P-2884 to KA-18	Methanol	30	14	15	0.54	6.24
47	47_KA18_14_MT2876_L	Methanol from Pump P-2876 to LTS Units 8 and B	Methanol	30	14	15	0.51	6.24
48	48_KA18_14_MT2877_L	Methanol from Pump P-2878 to LTS Unit B	Methanol	30	14	25	0.52	6.24
49	49_KA18_05_SLGCAT_L	Liquid from Slug Catcher (V-2858) to Slug Catcher Pumps (P-28201/28202) ^{Note 4}	24	19.52	21.54	-	-	-
54	47_KA18_05_SCPUMP_L	Slug Catcher Pumps (P28201/28202) to condensate pipeline ^{Note 4}	24	19.52	21.54	-	-	-

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
<i>Sensitivity Cases</i>								
50	50_KA18_15_KA4WGP_V	Wet gas from KA-4 & 14 to XSV-2863A	33(2)	39.05	26.45	250	112.9 ^{Note 3}	112.9
51	51_KA18_16_KA4P13_V	Dry gas from XSV-2813A to wellsite KA-4	33(2)	39.05	26.45	150	38.7 ^{Note 3}	38.7
52	52_KA18_17_KA4P14_V	Dry gas from XSV-2814 to wellsite KA-4	33(2)	39.05	26.45	100	18.1 ^{Note 3}	18.1
53	53_KA18_18_KA1PPL_L	Condensate from XSV-2864A to wellsite KA-1 & 7	33	17.21	30.00	100	17.1 ^{Note 3}	17.1

Notes:

1. Stream composition refers to the stream numbers in the HMB. The full HMB for all wellsites is attached Appendix 8.
2. Inventory from the wellhead section is considered to be unlimited because they can be supplied from the downhole reservoir.
3. Sections connecting to the pipeline inventories due to the lack of isolation valve.
4. Sections are not considered in the QRA due to either the sections are Normally No Flow (NNF) or the material constituting of high water content (% water cut is >125%) and considered as not flammable (Streams 24, 30 and 38).

11.2 Release Frequency

The leak frequencies for the process releases are estimated for each representative hole size using parts count results and the historical leak frequencies. The leak frequencies for KA-8 and KA-18 sections for the base case are shown in Table 11-2.

Table 11-2: Hydrocarbon Release Frequencies for KA-8 and KA-18 (Base Case)

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
1	01_KA08_01_WLHEAD_V	3.37E-05	1.38E-05	5.67E-06	1.84E-06		5.50E-05	0.03%
	KA-08 Blowout				4.20E-05		4.20E-05	0.02%
2	02_KA08_02_FLWLNE_V	1.73E-03	7.57E-04	3.99E-04	3.56E-05	8.21E-06	2.94E-03	1.4%
3	03_KA18_03_WLHEAD_V	3.37E-05	1.38E-05	5.67E-06	1.84E-06		5.50E-05	0.03%
	KA-18 Blowout				4.20E-05		4.20E-05	0.02%
4	04_KA18_04_CHKLNE_V	3.01E-04	1.31E-04	6.61E-05	7.13E-06	1.93E-06	5.07E-04	0.2%
5	05_KA18_04_CHKLNE_V	1.25E-03	5.33E-04	2.84E-04	1.34E-05	3.74E-06	2.08E-03	1.0%
6	06_KA18_05_SLGCAT_V	8.53E-04	3.71E-04	1.91E-04	2.27E-05	3.62E-06	1.44E-03	0.7%
7	07_KA18_05_SLGCAT_V	1.66E-03	7.40E-04	3.87E-04	6.69E-05	7.46E-06	2.87E-03	1.4%
8	08_KA08_06_COMGAS_V	1.33E-03	5.87E-04	2.95E-04	3.89E-05	1.05E-05	2.27E-03	1.1%
9	09_KA18_07_WGSLTS_V	1.26E-02	5.05E-03	2.21E-03	5.33E-04	1.12E-05	2.04E-02	9.9%
10	10_KA18_07_PIGL13_V	3.73E-07	1.93E-07	1.07E-07	5.30E-08	7.35E-11	7.27E-07	0.0004%
11	11_KA18_07_PIGL14_V	1.15E-06	5.98E-07	3.32E-07	1.65E-07		2.25E-06	0.001%
12	12_KA08_07_GASEXC_V	9.22E-04	4.58E-04	2.73E-04	1.20E-04	4.90E-07	1.77E-03	0.9%
13	13_KA08_07_HPKOGS_V	1.33E-03	6.03E-04	3.16E-04	7.79E-05	3.01E-06	2.33E-03	1.1%
14	14_KA08_07_CLSSFR_L	Section not included						
15	15_KA08_07_CONEXC_L	7.83E-04	3.53E-04	1.83E-04	4.96E-05		1.37E-03	0.7%
16	16_KA18_08_LPIG64_L	2.17E-03	9.91E-04	5.02E-04	1.41E-04		3.81E-03	1.8%
17	17_KA18_08_LPIG64_L	5.43E-06	2.82E-06	1.56E-06	7.77E-07		1.06E-05	0.01%
18	18_KA08_09_SEPRTR_V	1.09E-03	4.83E-04	2.42E-04	4.33E-05	6.11E-06	1.87E-03	0.9%
19	19_KA08_09_SEPRTR_L	Section not included						
20	20_KA08_09_BLWCSE_L	Section not included						
21	21_KA08_09_PUMPBP_L	Section not included						
22	22_KA08_09_BLWCSE_V	6.80E-04	2.91E-04	1.43E-04	2.57E-05		1.14E-03	0.6%
23	23_KA08_09_COOLER_V	7.95E-04	3.34E-04	1.57E-04	2.43E-05		1.31E-03	0.6%
24	24_KA08_09_SS9111_V	1.28E-03	6.02E-04	3.28E-04	1.07E-04	2.10E-07	2.32E-03	1.1%
25	25_KA08_09_SS9121_V	1.52E-03	7.04E-04	3.75E-04	1.14E-04	2.10E-07	2.71E-03	1.3%
26	26_KA08_09_COMPSPR_V	3.04E-02	1.25E-02	5.25E-03	1.68E-03		4.98E-02	24.2%
27	27_KA18_10_SEPRTR_V	1.02E-03	4.47E-04	2.21E-04	3.52E-05	6.11E-06	1.73E-03	0.8%
28	28_KA18_10_SEPRTR_L	Section not included						

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
29	29_KA18_10_BLWCSE_L	<i>Section not included</i>						
30	30_KA18_10_COOLER_V	7.92E-04	3.32E-04	1.57E-04	2.35E-05	1.40E-07	1.30E-03	0.6%
31	31_KA18_10_SS9111_V	1.26E-03	5.95E-04	3.25E-04	1.07E-04	2.10E-07	2.28E-03	1.1%
32	32_KA18_10_SS9101_V	1.48E-03	6.86E-04	3.73E-04	1.07E-04	2.10E-07	2.64E-03	1.3%
33	33_KA18_10_PUMPBP_L	<i>Section not included</i>						
34	34_KA18_10_BLWCSE_V	1.21E-03	5.41E-04	2.70E-04	7.57E-05		2.10E-03	1.0%
35	35_KA18_10_COMP SR_V	3.01E-02	1.24E-02	5.21E-03	1.67E-03		4.94E-02	23.9%
36	36_KA18_07_FUELGS_V	4.07E-04	1.74E-04	7.57E-05	2.50E-05		6.82E-04	0.3%
37	37_KA18_07_FLGSSS_V	2.01E-03	8.53E-04	4.24E-04	5.92E-05		3.35E-03	1.6%
38	38_KA08_07_FLGSEP_V	3.33E-03	1.37E-03	6.08E-04	1.60E-04		5.47E-03	2.7%
39	39_KA18_07_FLGSEP_V	3.22E-03	1.33E-03	5.89E-04	1.55E-04		5.29E-03	2.6%
40	40_KA18_11_GASEXC_V	1.88E-03	1.00E-03	6.21E-04	3.52E-04	1.61E-06	3.86E-03	1.9%
41	41_KA18_08_LTSUNB_V	8.76E-04	3.98E-04	2.14E-04	4.94E-05		1.54E-03	0.7%
42	42_KA18_08_LTSUNB_L	1.93E-03	8.56E-04	4.59E-04	8.51E-05		3.33E-03	1.6%
43	43_KA18_08_SHLEXC_V	5.16E-03	2.35E-03	1.21E-03	3.29E-04	3.60E-06	9.05E-03	4.4%
44	44_KA18_07_GPIG63_V	1.12E-06	5.80E-07	3.22E-07	8.49E-08	2.65E-08	2.13E-06	0.001%
45	45_KA18_14_MTHNOL_L	1.73E-03	7.74E-04	2.73E-04	7.29E-05	5.00E-06	2.85E-03	1.4%
46	46_KA18_14_MT2884_L	1.44E-03	8.23E-04	1.03E-03			3.29E-03	1.6%
47	47_KA18_14_MT2876_L	1.50E-03	8.76E-04	1.10E-03			3.48E-03	1.7%
48	48_KA18_14_MT2877_L	1.57E-03	8.96E-04	1.10E-03			3.56E-03	1.7%
49	49_KA18_05_SLGCAT_L	<i>Section not included</i>						
54	54_KA18_05_SCPUMP_L	<i>Section not included</i>						
TOTAL		1.22E-01	5.22E-02	2.59E-02	6.45E-03	7.35E-05	2.06E-01	100.0%
% Contribution		59%	25%	13%	3%	0.04%		

The total leak frequency for KA-8 and KA-18 wellsite (for the base case) is 2.06E-01 per year, which is equivalent to one leak every 4.9 years. Most of the leaks are predicted to be from small leaks, where 84% of the leaks are from hole sizes less than 10 mm diameter.

The leak frequencies for KA-8 and KA-18 sections for the sensitivity case are shown in Table 11-3.

Table 11-3: Hydrocarbon Release Frequencies for KA-8 and KA-18 (Sensitivity Case)

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
50	50_KA18_15_KA4WGP_V	1.29E-04	5.72E-05	2.84E-05	6.52E-06	1.07E-06	2.22E-04	0.1%
51	51_KA18_16_KA4P13_V	2.35E-05	1.01E-05	5.44E-06	3.20E-07	7.00E-08	3.94E-05	0.02%
52	52_KA18_17_KA4P14_V	4.29E-05	2.01E-05	1.13E-05	3.09E-06		7.74E-05	0.04%
53	53_KA18_18_KA1PPL_L	2.79E-05	1.21E-05	6.73E-06	3.90E-07		4.71E-05	0.02%
TOTAL (Base Case and Sensitivity)		1.22E-01	5.23E-02	2.59E-02	6.46E-03	7.47E-05	2.07E-01	0.2%
% Contribution		59%	25%	13%	3%	0.04%		

The total leak frequency for KA-8 and KA-18 wellsite (including the sensitivity cases) is 2.07E-01 per year (with only 3.9E-04 per year increment compared with the base case), which is equivalent to one leak every 4.8 years.

11.3 Risk Results

The risk results are presented in this section. The risk contours are contributed from both flammable and toxic risks from all release scenarios based on all the hazardous materials onsite.

The only toxic risk onsite is due to methanol toxicity from the methanol injection system. As the methanol tank is stored at atmospheric condition with limited inventory (4.7 m³ at maximum capacity) and banded, the methanol toxic risk is very minor and localised. Hence no separate toxic risk contour was provided. Methanol toxic effect was modelled by using the probit method as detailed in the Assumptions Register [Ref. 5].

11.3.1 Base Case

The base case risk contour for KA-8 and KA-18 wellsite is presented in Figure 11-1.




Figure 11-1: Risk Contour for KA-8 and KA-18 Wellsite (Base Case)

The risk assessed against the HIPAP4 criteria for the base case are summarised in Table 11-4.

Table 11-4: LSIR Results Assessed Against the HIPAP4 Land Use Criteria for KA-8 and KA-18 (Base Case)

LSIR	Risk Contour	HIPAP4 Land Use Criteria	Result
5E-05 / year	Blue	5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable.	The 5E-05 / year risk contour exceeds the site boundary at the north as the compressor buildings are located at the northern side of the wellsite.
1E-6 / year	Red	1E-6 / year risk contour should not extend to residential developments, hotels, tourist resorts.	Criteria met. There are residential developments, hotels, tourist resorts within the contour.

11.3.2 Sensitivity Case

The LSIR for KA-8 and KA-18 wellsite sensitivity case, which include the gathering pipeline sections is presented in Figure 11-2.



Figure 11-2: LSIR Contours for KA-8 and KA-18 Wellsite (Sensitivity Case)

The risk contours for the sensitivity case are slightly larger compared to the base case due to the additional sections, however the assessment against the HIPAP4 criteria is the same. Hence is it not repeated.

11.4 Risk Contributors

The risk contributors to offsite risks at selected locations (points A, B and C) as shown in Figure 11-3 can be identified from the QRA model.



Figure 11-3: Location Selected to Identify Risk Contributors at KA-8 and KA-18 Wellsite

11.4.1 Base Case

The risk contributors for the base case with the risk contributors and percentage of contribution are shown in Table 11-5.

Table 11-5: Risk Contributors to Selected Locations for KA-8/18 (Base Case)

Point	LSIR (per year)	Contributor	% Contribution	Consequence
A	5.99E-05	35_KA18_10_COMP SR_V_71 mm (Hydrocarbon Gas from Compressors K-9201A/B discharge)	90%	Fireball from early ignition
B	5.78E-05	26_KA08_09_COMP SR_V_71 mm (Hydrocarbon Gas from Compressors K-9101A/B discharge)	94%	Fireball from early ignition
C	3.02E-05	09_KA18_07_WGSLTS_V_85 mm (Wet Gas from LTS (V-2804) to the gathering pipelines)	61%	Fireball from early ignition
		12_KA08_07_GASEXC_V_85 mm (Hydrocarbon Gas from KA-08 wellhead to HPKO V-2803)	12%	Fireball from early ignition

The risk contributor analysis shows that for both locations at plant north, the offsite risk contributors are mainly contributed by a single scenario, which are the rupture case from the compressors due to the proximity of the compressor buildings to the wellsite boundary. Compressors also have high leak frequencies as shown in Table 11-2, where these compressor discharge sections contributed approximately 24% each to the overall plant release frequencies.

For the offsite point at the plant west (point C), the risks are mainly contributed by the equipment (scenario 09 is from the vapour section of the LT Separator and scenario 12 is the gas feeding into the LTS unit) from the LTS units due to proximity of the LTS unit to the wellsite western boundary.

11.4.2 Sensitivity Case

The risk contributors for the sensitivity case with the contributors and percentage of contribution are shown in Table 11-6.

Table 11-6: Risk Contributors to Selected Locations for KA-8/18 (Sensitivity Case)

Point	LSIR (per year)	Contributor	% Contribution	Consequence
A	5.99E-05	35_KA18_10_COMPSCR_V_71 mm (Hydrocarbon Gas from Compressors K-9201A/B discharge)	90%	Fireball from early ignition
B	5.78E-05	26_KA08_09_COMPSCR_V_71 mm (Hydrocarbon Gas from Compressors K-9101A/B discharge)	94%	Fireball from early ignition
C	3.02E-05	09_KA18_07_WGSLTS_V_85 mm (Wet Gas from LTS (V-2804) to the gathering pipelines)	61%	Fireball from early ignition
		12_KA08_07_GASEXC_V_85 mm (Hydrocarbon Gas from KA-08 wellhead to HPKO V-2803)	12%	Fireball from early ignition

The risk contributors for the sensitivity case are consistent with the base case, where the sensitivity cases contributed very low incremental risk to the wellsite due to the low release frequencies from the additional pipeline sections.

It should be noted that Safeti cannot consider the effect of the obstacles / objects located along the way where the heat is radiated from the release source. In reality heat may be shielded by some process equipment / piping before extending offsite.

12. WELLSITE KA-13

12.1 Release Scenarios

The P&IDs showing the isolatable sections for KA-3 are presented in Appendix 7. Table 12-1 details the section description and the respective operating conditions that are used in the QRA.

Table 12-1: Release Scenarios and Operating Conditions for KA-3

No.	Section ID	Description	Material / Stream ^{Note 1}	Pressure (barg)	Temp. (°C)	Largest Connection Size (mm)	Section Inventory (m ³)	Isolatable Inventory (m ³)
1	01_KA13_01_WLHEAD_L	Wellstream fluid from KA-13 wellhead to XSV-21330	35	18.7	23.8	100	<i>Unlimited</i> ^{Note 2}	
2	02_KA13_02_FLWLNE_L	Wellstream fluid from XSV-21330 to Condensate Pipeline SDV-21310B	36	18.6	23.7	150	2.06	2.06
3	03_KA13_03_METNK1_L	Methanol Tank (T-21331) to Methanol Pump (P-21309)	Methanol	Atm	Amb	50	0.10	0.10
4	04_KA13_04_METNK2_L	Methanol Tank (T-21316) to Methanol Pump (P-21320)	Methanol	Atm	Amb	50	0.10	0.10
<i>Sensitivity Cases</i>								
5	05_KA13_05_LIQPIP_L	Wellstream fluid from SDV-21310B feed into liquid pipeline from KA-05 to KPS	36	18.6	23.7	150	55.50 ^{Note 3}	55.50
6	06_KA13_06_GASPPL_V	Hydrocarbon gas from wellsites KA-5, 6 and 11 to KPS	34	17.7	20.4	250	152.90 ^{Note 3}	152.90

Notes:

1. Stream composition refers to the stream numbers in the HMB. The full HMB for all wellsites is attached Appendix 8.
2. Inventory from the wellhead section is considered to be unlimited because they can be supplied from the downhole reservoir.
3. Sections connecting to the pipeline inventories due to the lack of isolation valve.

12.2 Release Frequency

The leak frequencies for the process releases are estimated for each representative hole size using parts count results and the historical leak frequencies. The leak frequencies for KA-13 sections for the base case are shown in Table 12-2. KA-13 is only in operation periodically for around 1 out of every 3 months.

Table 12-2: Hydrocarbon Release Frequencies for KA-13 (Base Case)

No	QRA Event	1 - 3 mm (2 mm)	3 - 10 mm (6 mm)	10 - 50 mm (22 mm)	50 - 150 mm (85 mm)	> 150 mm	TOTAL	% Contrib.
1	01_KA13_01_WLHEAD_L	1.12E-05	4.61E-06	1.89E-06	6.14E-07		1.83E-05	0.6%
	KA-13 Blowout				1.40E-05		1.40E-05	0.7%
2	02_KA13_02_FLWLNE_L	6.11E-04	2.62E-04	1.40E-04	8.00E-06	1.69E-06	1.02E-03	41.3%
3	03_KA13_03_METNK1_L	4.33E-04	1.97E-04	6.01E-05	2.01E-05	1.67E-06	7.12E-04	28.7%
4	04_KA13_04_METNK2_L	4.33E-04	1.97E-04	6.01E-05	2.01E-05	1.67E-06	7.12E-04	28.7%
	TOTAL	1.49E-03	6.62E-04	2.62E-04	6.27E-05	5.02E-06	2.48E-03	100.0%
	% Contribution	60%	27%	11%	2%	0.2%		

The total leak frequency for KA-3 wellsite (for the base case) is 2.48E-03 per year, which is equivalent to one leak every 403 years. Most of the leaks are predicted to be from small leaks, where 87% of the leaks are from hole sizes less than 10 mm diameter.

The leak frequencies for KA-13 sections for the sensitivity case are shown in Table 12-3.

Table 12-3: Hydrocarbon Release Frequencies for KA-13 (Sensitivity Case)

No	QRA Event	1 - 3 mm	3 - 10 mm	10 - 50 mm	50 - 150 mm	> 150 mm	TOTAL	% Contrib.
5	05_KA13_05_LIQPIP_L	6.72E-04	2.88E-04	1.55E-04	1.17E-05	8.89E-07	1.13E-03	25.5%
6	06_KA13_06_GASPPL_V	3.97E-04	1.73E-04	9.25E-05	7.26E-06	2.43E-06	6.73E-04	15.2%
	TOTAL (Base Case and Sensitivity)	2.56E-03	1.12E-03	5.09E-04	8.17E-05	8.34E-06	4.28E-03	
	% Contribution	60%	26%	12%	2%	0.2%		

The total leak frequency for KA-13 wellsite (including the sensitivity cases) is 4.28E-03 per year, which is equivalent to one leak every 234 years.

12.3 Risk Results

The risk results are presented in this section. The risk contours are contributed from both flammable and toxic risks from all release scenarios based on all the hazardous materials onsite.

The only toxic risk onsite is due to methanol toxicity from the methanol tanks. As the methanol tanks are stored at atmospheric condition with limited inventory (typically 0.1 m³ at each tank) and banded, the methanol toxic risk is very minor and localised. Hence no separate toxic risk contour was provided. Methanol toxic effect was modelled by using the probit method as detailed in the Assumptions Register [Ref. 5].

12.3.1 Base Case

The base case LSIR for KA-13 wellsite is presented in Figure 12-1.



Figure 12-1: LSIR Contours for KA-13 Wellsite (Base Case)

The risk assessed against the HIPAP4 criteria are summarised in **Table 12-4**.

Table 12-4: LSIR Results Assessed Against the HIPAP4 Land Use Criteria for KA-13 (Base Case)

LSIR	Risk Contour	HIPAP4 Land Use Criteria	Result
5E-05 / year	Blue	5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable.	Criteria met. The 5E-05 / year risk contour is within the site boundary.
1E-6 / year	Red	1E-6 / year risk contour should not extend to residential developments, hotels, tourist resorts.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.

12.3.2 Sensitivity Case

The LSIR for KA-13 wellsite sensitivity case, which include the gathering pipeline sections is presented in Figure 12-2.



Figure 12-2: LSIR Contours for KA-13 Wellsite (Sensitivity Case)

The risk contours for the sensitivity case are significantly larger than the base case risk contour, especially for the 1E-06/ year risk. This is mainly contributed by jet fire events from the gathering pipelines which can be feed by large pipeline inventories. The risk assessed against the HIPAP4 criteria are summarised in Table 12-4.

Table 12-5: LSIR Results Assessed Against the HIPAP4 Land Use Criteria for KA-13 (Base Case)

LSIR	Risk Contour	HIPAP4 Land Use Criteria	Result
5E-05 / year	Blue	5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable.	Criteria met. The 5E-05 / year risk contour is within the site boundary.
1E-6 / year	Red	1E-6 / year risk contour should not extend to residential developments, hotels, tourist resorts.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.

12.4 Risk Contributors

For both the base case and the sensitivity case, the 5E-05 / year risk contour and the 1E-06 /year risk contour remain within the site boundary. This is because there are only very limited equipment onsite. As the risk contours did not extend offsite, no locations were selected for risk contributor identification.

13. CONCLUSIONS

This QRA study represents a comprehensive assessment of risks from Kapuni wellsites, commensurate in detail to the information available at the time. Table 13-1 presents the summary of main findings of the risk assessments.

Table 13-1: Summary of Main Findings

Wellsite	HIPAP4 Land Use Criteria <i>(Proposed development of a potentially hazardous nature, or for land use planning in the vicinity of existing hazardous installations)</i>	
	5E-05 / year <i>(5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable)</i>	1E-6 / year <i>(1E-6 / year risk contour for residential developments and places of continuous occupancy such as hotels, tourist resorts)</i>
KA-1/7/19/20		
Base Case	Criteria met. The 5E-05 / year risk contour is within the site boundary.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as Base Case	Same as Base Case
KA-2		
Base Case	Criteria met. The 5E-05 / year risk contour is within the site boundary.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
KA-4/14		
Base Case	Criteria met. The 5E-05 / year risk contour is within the site boundary.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as Base Case	Same as Base Case
KA-5/10		
Base Case	Criteria met. The 5E-05 / year risk contour is within the site boundary.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as Base Case	Same as Base Case
KA-6/11/17		
Base Case	Criteria met. The risk level is lower than 5E-05 / year.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as Base Case	Same as Base Case
KA-8/12/15/18		
Base Case	The 5E-05 / year risk contour exceeds the site boundary at the north as the compressor buildings are located at the northern side of the wellsite.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as Base Case	Same as Base Case

Wellsite	HIPAP4 Land Use Criteria <i>(Proposed development of a potentially hazardous nature, or for land use planning in the vicinity of existing hazardous installations)</i>	
	5E-05 / year <i>(5E-5 / year risk contour should, as a target, be contained within the boundaries of the industrial site where applicable)</i>	1E-6 / year <i>(1E-6 / year risk contour for residential developments and places of continuous occupancy such as hotels, tourist resorts)</i>
KA-13		
Base Case	Criteria met. The 5E-05 / year risk contour is within the site boundary.	Criteria met. There are no residential developments, hotels, tourist resorts within the contour.
Sensitivity Case	Same as base case	Same as base case

For almost all the wellsites, the HIPAP4 Land Use Criteria are met except for KA-8/18 wellsite where the 5E-05/year risk contour exceeds the site boundary at the north as the compressor buildings are located at the northern side of the wellsite.

For all sensitivity cases (where the aboveground sections of the gathering pipelines are included), the risk contours are only slightly larger compared to the base case. This is due to the low release frequencies from the additional pipeline sections which do not contribute significantly to the overall risk. The assessment against the HIPAP4 criteria are all consistent with the base case findings.


Risk contributors to offsite risks are also identified to help to identify the equipment / section of wellsites that are leading to offsite impact. For wellsites that have no offsite impact, risk contributor analyses were not conducted.

14. REFERENCES

1. Todd Energy, Safety Case – Kapuni Production Station, Doc. No. NOL649981, Rev 1, January 2018.
2. Todd Energy Fire and Explosion Analysis and Quantitative Risk Assessment Methodology Guideline, NZ-1005-TECD721654, Rev. 0.
3. Worley New Zealand Ltd Onshore QRA Procedure (Using Phast Risk), PCD-473.
4. DNV Safeti software version 8.22.
5. Kapuni Wellsites QRA, Assumptions Register, 610114-RPT-R0001, Rev. 0, August 2020.
6. New Zealand National Climate Database (<http://cliflo.niwa.co.nz/>)
7. OGP 434-1, Process Release Frequencies, September 2019
8. TNO Purple Book, Guidelines for Quantitative Risk Assessment, December 2005
9. OGP 434-2, Blowout Frequencies, 2019
10. IP research report, Ignition probability review, model development and look-up correlations, January 2006
11. OGP 434-6, Ignition Probabilities, September 2019
12. Methods for the Determination of Possible Damage (TNO Green Book)
13. Oil and Gas UK, Fire and Explosion Guidance, Issue 1 May 2007
14. Flammability of Hydrocarbon / CO₂ mixtures: Part 1, Ignition and Explosion Characteristic, Symposium Series No. 156, 2011.
15. Taranaki Regional Council,
<https://maps.trc.govt.nz/LocalMapsViewer/?map=5113f49337a84cf098db177c728b1361>
16. New South Wales Hazardous Industry Planning Advisory Paper No. 4, Risk Criteria for Land Use Safety Planning, January 2011
17. South Taranaki District Council, District Plan 2004 (<https://www.southtaranaki.com/our-council/plans-strategies-and-reports/district-plan>)

Appendix 1.
P&ID Sectionalisation for KA-19

ITEM No.
NAME
SIZE
DESIGN BAR(G) @ eC
OPER.
DUTY



- NOTES:
- METHANOL INJECTION LINES TO BE 6mmSS BY INSTRUMENTS. SEE DWG 941-10-001022 FOR INJECTION SYSTEM
 - START UP OVERRIDE ACTS ON PALL-2140F.
 - ALL TUBING IS IMPERIAL STANDARD.
 - SDV-2140A IS FITTED WITH A QUICK VENT WHICH RELIEVES BACK TO THE HYDRAULIC TANK T-2140. THE QUICK VENT RETURN FROM SDV-2140A HAS TWO LO VALVES.
 - BACK PRESSURE REGULATOR STOPS CELLAR PUMP FROM OPERATING BELOW 6.7 BARG AIR PRESSURE.
 - XSDV-2140A CLOSURES 20 SECONDS AFTER SDV-2140A. WELL VALVE OPEN SEQUENCE IS MANUALLY CONTROLLED (NO TIMERS).
 - VALVE IS SS FOR LOW TEMP OF -90°C.
 - VOID.
 - XCV-2140B/C OVERRIDE STEM LOCKED OPEN.
 - REFER TO DEPRESSURING PROCEDURE FOR CONTROL OF LOW TEMPERATURES DURING DEPRESSURISATION.
 - CORROSION PROBE.
 - DROP-OUT SPOOL FOR DESANDER CONNECTION.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CHKD	APPR.	CHD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHD	APPR.	CHD	APPR.	NUMBER	TITLE
07	10/16	BB	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16399KW	JMP	AB	SF										
08	08/16	BB	ECP	ECP K1666 AS BUILT TO SITE MARK UP ASB 16315KW	JMP	AB	SF										
09	04/16	BB	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16313KW	JMP	AB	SF										
10	11/15	BB	ECP	ECP K1630 AS BUILT TO SITE MARK UP ASB 15425KW	JMP	AB	ATH										
11	10/15	BB	ECP	ECP X0213 AS BUILT TO SITE MARK UP ASB 15422KW	JMP	AB	ATH										
12	08/19	SH	ECP	PCR_3_2019_5 AS BUILT TO SITE MARK UP ASB T19012KW	JMP	SG	IMV										
13	08/18	BB	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB T18022KW	JMP	GD	KB										

KAPUNI WELLSITES

PIPING & INSTRUMENT DIAGRAM


WELLHEAD KA-19

WELLSITE KA-1 & 7

DESIGNED: _____ DATE: _____
DRAWN: D WATEMBURG
CHECKED: K CHANNON
APPROVED: _____
APPROVED: _____
SCALE: _____
STICKLE: _____

SHEET No. 1 of 2 REVISION 09
DRAWING No. 941-10-00128

Todd Energy



- NOTES:**
- VOID.
 - 50mm RCS ACCESS FITTING WITH CORROSION PROBE. ELASTOMERS IN ACCESS FITTING ONLY SUITABLE FOR -34°C
 - FLOWLINE CHOKE TO BE RAMPED CLOSED UNDER USD / ESD, OR ALL KPS INLET VALVES CLOSED.
 - CRITICAL HEAT TRACING PROTECTS SAFEGUARDING INSTRUMENT FROM WAX/HYDRATE BLOCKAGE.
 - TWO PHASE AND/OR SLUG FLOW.
 - TARGET TEES FOR POTENTIAL SAND PRODUCTION.
 - REMOVABLE INSULATION ON MONO BLOCKS.
 - VOID.
 - VOID.
 - VOID.
 - INJECTION REQUIRED ONLY WHEN OPERATING KA-20, (KA-19 SHUTDOWN AND ISOLATED).
 - VOID.
 - ECCENTRIC ORIFICE.
 - DROP-OUT SPOOL REMOVED TEMPORARILY.
 - ORIFICE PLATE SIZED FOR ASME 4" 1500# RTJ FLANGE USING R39 RING GASKET. THIS IS ALSO THE API STANDARD GASKET FOR API 5000# 4-1/16" FLANGE AND THEREFORE ACCEPTABLE FOR USE WITH STOS SPEC 50 (API 5000#) PIPING.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
E6	10/16	AMP	CUSP PROJECT ISSUED FOR HAZOP	SG	ML			07	02/17	CB	ECP	ECP K1707 AS BUILT TO SITE MARK UP ASB 1702KW	JMP	AB		SF		
D0	09/16	JMP	ECP K1707 POST FRACKING APC	ML	OKK			06	10/16	BB	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16399KW	JMP	AB		SF		
C2	02/16	NR	ECP K1666 APPROVED FOR CONSTRUCTION	ML	AB			05	09/16	BB	ECP	ECP XS16001 AS BUILT TO SITE MARK UP ASB 16369KW	JMP	AB		SF		
E1	08/15	JL	ECP K1666 APPROVED FOR DESIGN	ML	AB			04	08/16	BB	ECP	ECP K1666 AS BUILT TO SITE MARK UP ASB 16315KW	JMP	AB		SF		
E3	02/18	CSM	K1729 CUSP-RE-APPR. FOR CONSTRUCTION	GD	SG			03	10/15	BB	ECP	ECP K1993 & X0213 AS BUILT TO SITE MARK UP ASB 15419KW & 15422KW	JMP	AB		ATH		
E2	09/17	CSM	K1729 CUSP-APPR. FOR CONSTRUCTION	ML	GD			02	10/14	NR	ECP	ECP K1993 AS BUILT TO SITE MARK UP ASB 14217KW	JMP	AB		ATH		
E4	03/17	JMP	ECP K1729 APPROVED FOR DESIGN	ML	SG			08	08/16	BB	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB 18022KW	JMP	GD		KB		

03_KA19_02_CHKLNE_V

TO E-2513 (UNIT 7)
941-10-00129/1

DESIGNED: . DATE: .
DRAWN: LMEADS 07/10
CHECKED: K CHANNON 07/10
APPROVED: N STONER 07/10
APPROVED: .
SCALE: .
STICKFILE: .

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
WELLHEAD KA-19
WELLSITE KA-1 & 7


SHEET NO. 2 OF 2 REVISION 08
DRAWING NO. 941-10-00128

Todd Energy



ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

H-2194
UNIT 7 WELLSTREAMHEATER

05_KA19_02_WLHKOT_V



03_KA19_02_CHKLNE_V



NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
D3	02/18	CSM	K1729 EUSP RE-APPR FOR CONSTRUCTION	GD	SG		SF	05	08/18	JJP	ECP	ECP K1827 AS BUILT TO SITE MARK UP ASB T19019KW	JMP	SG		MMV		
D2	03/17	CSM	K1729 EUSP RE-APPR FOR CONSTRUCTION	ML	GD		SF	04	06/17	BB	ECP	ECP K1729 AS BUILT TO SITE MARK UP T18022KW	JMP	GD		KB		
D1	03/17	JMP	ECP K1729 APPROVED FOR DESIGN	ML	SG		SF	03	08/16	BB	ECP	ECP K17172 AS BUILT TO SITE MARK UP ASB 17187KW	JMP	TD		SF		
D0	10/16	AMP	EUSP PROJECT ISSUED FOR HAZOP	SG	ML			02	11/15	BB	ECP	ECP K1666 AS BUILT TO SITE MARK UP ASB 16315KW	JMP	AB		SF		
C4	08/16	JMP	ECP K1707 FRACK FLOWBACK AFC				ATH	01	04/14	DG	ECP	ECP K1630 AS BUILT TO SITE MARK UP ASB 15429KW	JMP	AB		ATH		
CG	08/16	JMP	ECP K1707 ISSUED FOR HAZOP					00		DW	ECP	ECP K1334 AS BUILT TO SITE MARK UP ASB 14039KW	JMP	AB		ATH		

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

DESIGNED: . DATE: .
DRAWN: DWATEMBURG .
CHECKED: .
APPROVED: .
SCALE: .
STICKFILE: .


KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
WELLSTREAMHEATER
WELLSITE KA-1 & 7

SHEET No 1 of 2 REVISION 06
DRAWING No 941-10-00129

ITEM No.
NAME
SIZE
DESIGN BARG @ 6C

E-2153
WELLSTREAM COOLER
BARE TUBE 100 SQ.M
238 @ 1216C

V-2154
WELLHEAD KNOCKOUT
1068mm OD x 4572mm TANVTAN
248 @ +5.856C



16

17

19

18

03_KA19_02_CHKLN_V


04_KA19_02_WSCOO_V

06_KA19_02_WLHKOB_L

05_KA19_02_WLHKOT_V

16_KA19_04_CONPIP_L

- NOTES:
- VOID.
 - VOID.
 - FOR MCH INJECTION
 - VALVE USED FOR REPRESSIONATION
 - VOID.
 - TIE-IN POINTS FOR PRODUCTION TESTING V-2154.
 - VOID.
 - FLT DENOTES THE ANALOG INPUT FIELD LOOP MONITORED FOR FAULTS.
 - FO DENOTES FIRST OUT ALARMSEQUENCE ON DCS
 - THIS PIPING INCLUDING SPOOL FLANGES IS SPEC 15 SCH160.
 - VOID.
 - TAL-2154B WILL SHUT DOWN FANS OF E-2153.
 - VOID.
 - VOID.
 - RELIEF VALVE TAIL PIPE IS NOT ROUTED TO SAFE LOCATION AS PER STOS UNMANNED WELLSITE BURN DOWN PHILOSOPHY.
 - WELLSTREAM COOLER FREE DRAINS TO WHKO
 - VSHH-2153AB WILL SHUT DOWN THE CORRESPONDING FAN.
 - SINGLE/DUAL FAN MODE SELECTED FROM DCS.



This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CHKD	APPR.	CHD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CONSULTANT	TODD	NUMBER	TITLE
Q1	10/16	AMP					24	10/16	BB	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16399KW	JMP	AB	SF	
51	05/18	JMP					23	08/16	BB	ECP	ECP K1666 AS BUILT TO SITE MARK UP ASB 16319KW	JMP	AB	SF	
50	03/18	JMP					22	08/14	NR	ECP	ECP K1596 AS BUILT TO SITE MARK UP ASB 14149KW	JMP	AB	ATH	
06	02/18	CSM					21	04/14	DG	ECP	ECP K1334 AS BUILT TO SITE MARK UP ASB 14039KW	JMP	AB	ATH	
04	11/17	CSM					20	02/14	MH	ECP	ECP K1459 & K189 AS BUILT TO SITE MARK UPS ASB 13289KW & ASB 14025KW	JMP	AB	ATH	
03	09/17	CSM					26	08/18	BB	ECP	ECP K1729 & KA-7 REMEDIATION AS BUILT TO ASB T18022KW & T18050KW	JMP	GD	KB	
02	03/17	JMP					25	06/17	BB	ECP	ECP XK17172 AS BUILT TO SITE MARK UP ASB 171870KW	JMP	TD	SF	

DESIGNED: R.P.WILLIAMS
DATE: 24.4.91
DRAWN: R.P.WILLIAMS
CHECKED: M.WEST
APPROVED: M.WEST
SCALE: . . .
STICKLE: . . .

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
WELLHEAD KA-20 (OBSERVATION WELL)
WELLSITE KA-1 & 7


SHEET No. 2 of 2
REVISION: . . .
DRAWING No. 941-10-00103

Todd Energy

ITEM No.
NAME
SIZE
DESIGN BAR(G) @ εC
OPER.
DUTY

V-2853
CLASSIFIER
915mm OD x 3175mm TANTAN
TUBE 238 @ 85εC
SHELL 69 @ 85εC

V-2854
WELLHEAD KNOCKOUT
1068mm OD x 4572mm TANTAN
238 @ -3/85εC



16_KA19_04_CONPIP_L


- NOTES
- REFER TO DWG. 941-10-102 INJECTION SYSTEM
 - CONNECTION FOR PRODUCTION TESTING.
 - CRITICAL HEAT TRACING.
 - CONNECTION FOR WELL TESTING.
 - HC, WATER TOTALIZED FLOW BASED ON ASSUMED LIQUID DENSITIES & CORIOLIS MASS FLOW AND DENSITY MEASUREMENT.
 - RV TAIL PIPES ARE NOT ROUTED TO SAFE LOCATIONS PER STOS UNMANNED WELLSITE AND BURNDOWN PHILOSOPHY. HEAT TRACE RV DISCHARGE PIPE UP TO THE WEEP HOLE/FIRST ELBOW.
 - THE GOVERNING CASE FOR RV-2853B IS HP GAS BREAKTHROUGH VIA WELLHEAD KO LEVEL CONTROL VALVE LCV-2854A.
 - VOID.

9. DO NOT HYDROTEST FLANGES ARE 316SS /316L


This drawing is confidential and is the property of SHELL TODD OIL SERVICES LTD. It must not be disclosed to any third party or lent without written consent from Shell Todd Oil Services Ltd.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	EWR	REVISIONS	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE	REFERENCE DRAWINGS	
E6	09/14	JMP	ECP-K1334 APPROVED FOR CONSTRUCTION	JR	AB	ATH	07	04/14	DG	ECP	ECP K1334 AS BUILT TO SITE MARK UP ASB 14039KW	JMP	AB	ATH	-	-	-	-	-	-	-
E7	09/13	MH	ECP-K1334 RE-APPROVED FOR CONSTRUCTION	JR	AB	ATH	06	04/13	JC	ECP	ECP K1544 AS BUILT TO SITE MARK UP ASB 13063KW	JMP	AC	ATH	-	-	-	-	-	-	-
E8	09/12	SG	ECP-K1334 RE-ISSUED APPROVED FOR CONSTRUCTION	MK	ATH	05	09/11	09/11	SG	ECP	ECP K1392 AS BUILT TO SITE MARK UP ASB 11199KW	VB	JS	AI	-	-	-	-	-	-	-
E5	05/12	SG	ECP-K1334 APPROVED FOR CONSTRUCTION	MF	PB	ATH	04	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM	AI	-	-	-	-	-	-	-
E4	08/11	LMM	ECP-K1334 RE-ISSUED APPROVED FOR CONSTRUCTION	KS	AI	03	10/10	10/10	MH	ECP	ECP K1400 AS BUILT TO SITE MARK UP ASB 10222KW	VB	AP	AI	-	-	-	-	-	-	-
C3	07/11	BA	ECP-K1334 RE-ISSUED FOR HAZOP	MK	KS	-	-	-	BA	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10094KW	VB	AP	AI	-	-	-	-	-	-	-
D6	06/11	VB	ECP-K1392 APPROVED FOR CONSTRUCTION	GB	AP	AI	01	12/08	DW	ECP	ECP K1152 AS BUILT TO SITE MARK UP ASB 8198KW	VB	PVM	AI	-	-	-	-	-	-	-
E1	09/10	LMM	ECP-K1334 RE-ISSUED FOR HAZOP	KC	NE	AI	00	07/08	VB	ECP	FIRST ISSUE	CSM	-	-	-	-	-	-	-	-	-

ITEM No.
NAME
SIZE
DESIGN BARG @ €



FROM KA 7
USD LOGIC
941-10-00119/1



Valve is closed here, 3-4 m distance away

20_KA19_06_GASPP2_V

- NOTES
1. THE 200NB SECTION OF THIS LINE IS SCH 80.
 2. VOID.
 3. SDV-2852C HAS DELAYED CLOSURE COMPARED TO KA-TG-B WELLHEAD SDV TO ALLOW THE LTS SKID TO DROP TO GATHERING LINE PRESSURE
 4. VENT POINT ONLY TO BE USED ONCE THE SYSTEM HAS BEEN FULLY VENTED VIA KIMI DEPRESSURING LINE.
 5. REFER TO DEPRESSURING/REPRESSURING PROCEDURE FOR CONTROL OF LOW TEMPERATURES ISSUES.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

NO	DATE	BY	CHKD	APPR.	CHD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHD	APPR.	CHD	APPR.	NUMBER	TITLE
E3	09/17	CSM	K1729	CUSP	APPR.	FOR CONSTRUCTION	-	-	-	-	-	-	-	-	-	-	-
E2	03/17	JMP	ECP	K1729	APPR.	FOR DESIGN	-	-	-	-	-	-	-	-	-	-	-
E1	10/16	AMP	CUSP	PROJECT	ISSUED FOR HAZOP	-	-	-	-	-	-	-	-	-	-	-	-
E0	08/16	JMP	CUSP	PROJECT	ISSUED FOR REVIEW	-	-	-	-	-	-	-	-	-	-	-	-
B6	09/12	LMM	ECP	K1334	RE ISSUED APPR FOR CONSTRUCTION	-	-	-	-	-	-	-	-	-	-	-	-
B5	05/12	VB	ECP	K1334	APPROVED FOR CONSTRUCTION	-	-	-	-	-	-	-	-	-	-	-	-
B4	09/11	LMM	ECP	K1334	APPROVED FOR DESIGN	-	-	-	-	-	-	-	-	-	-	-	-
FIRST ISSUE																	
CONSTRUCTION ISSUE												REFERENCE DRAWINGS					

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
 KA-7 LTS
 KAPUNI WELLSITE KA-1 & 7



SHEET No. **2** OF **2** REVISION **05**
 DRAWING No. **941-10-00121**

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

T-2147
HYDRAULIC FLUID RESERVOIR
220d x 560L


P-2148
HYDRAULIC FLUID PUMP

P-2149
HYDRAULIC FLUID PUMP

P-2196
WELLHEAD CELLAR PUMP

WELLHEAD KA-7
API 5000#
MAX. SHUT IN PRESSURE 90 BARG

TO CHEMICAL
INJECTION
941-10-00102/1



Assume this
valve is
closed

03_KA19_02_CHKLINE_V

- NOTES
- VOID.
 - VOID.
 - THIS LINE HAS BEEN DERATED FROM SPEC 50/50A TO SPEC 15. FLANGES REMAIN AT 5000#.
 - SAFETY CRITICAL HEAT TRACING
 - WIRELESS INSTRUMENT.
 - VALVE IS SUITABLE FOR LOW TEMP OF -90°C.
 - VOID
 - SIGNAL DISCONNECTED IN DCS LOGIC AS KA-1 IS SUSPENDED (K1334)
 - FLOWLINE CHOKE TO BE RAMPED CLOSED UNDER USD, ESD, KPS ESD OR ALL KPS INLET VALVES CLOSED.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CHKD	APPR.	NO	DATE	BY	CHKD	APPR.	DESCRIPTION
0518		JMP			0818		BB			ECP ECP K1729, K1666 & KA-7 REMEDIATION AS BUILT TO ASB T18022KW & T18059KW
0318		JMP			0617		BB			ECP XJ 17172 AS BUILT TO SITE MARK UP ASB 17189KW
0917		CSM			1016		BB			ECP XK16002 AS BUILT TO SITE MARK UP ASB 16399KW
0517		JMP			0616		NR			ECP K1677 AS BUILT TO SITE MARK UP ASB 16209KW
0715		TW			0416		BB			ECP XK16002 AS BUILT TO SITE MARK UP ASB 16131KW
0816		JMP			0715		BB			ECP K1579 AS BUILT TO SITE MARK UP ASB 15211KW
0216		NR			0315		NR			ECP X0213 AS BUILT TO SITE MARK UP ASB 15059KW
0815		JL			0414		DG			ECP K1334 AS BUILT TO SITE MARK UP ASB 14039KW


DESIGNED: R. H. SYME
DATE: 10.10.78
DRAWN: R. H. SYME
CHECKED: [Signature]
APPROVED: [Signature]

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
WELLHEAD KA-7
KAPUNI WELLSITE KA 1 & 7

SCALE: NTS
STICKLE: [Signature]

Todd Energy

SHEET No. 1 OF 2
REVISION: 46
DRAWING No. 941-10-00101



18_KA19_05_GPIG65_V

22_KA19_06_GPIG66_V

23_KA19_07_VECGAS_V

17_KA19_05_GASPIP_V

05_KA19_02_WLHKOT_V

20_KA19_06_GASPP2_V

27_KA19_09_KA4GPL_V

19_KA19_05_GPIG63_V

21_KA19_06_GPIG67_V

16_KA19_04_CONPIP_L

Flow connecting wellsite into the pipeline, no isolation valve - will contain pipeline inventory

- NOTES:
- 250NB SCH 30 ERW API 5L X46 MDPE COATED CLASS 600 FLANGES 94.5 BARG @ 60°C TO NZS 5223: PART 1 1986
 - VOID.
 - CRITICAL HEAT TRACING - PREVENTS WAX BLOCKAGE IN SAFEGUARDING INSTRUMENT.
 - VOID.
 - VOID.
 - VOID.
 - VOID USING PIG TRAP VENT LINES FOR DEPRESSURISING KA 1/7 TO KA 4/14 FLOWLINE.
 - PIPELINE DESIGN CONDITIONS 94.5 BARG @ 60°C
 - VOID.
 - MINIMUM LENGTH BETWEEN PIG TRAP VALVE AND PLS/PRI EQUAL TO MAXIMUM LENGTH IF PIG.
 - VOID.
 - VOID.

NO	DATE	BY	CONSTRUCTION ISSUE	CHD	APPR.	CHD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHD	APPR.	CHD	APPR.	NUMBER	TITLE
X2	03/17	JMP	ECP K1729 APPROVED FOR DESIGN	M	SG													
X1	10/16	AMP	CUSP PROJECT ISSUED FOR HAZOP	M	SG													
X0	08/16	AME	CUSP PROJECT ISSUED FOR REVIEW	M	SG			35	02/17	AMP	ECP	ECP XX1712 AS BUILT TO SITE MARK UP ASB 17004KK	JMP	AB		SF		
WD	07/14	NR	ECP K1501-08 FOR REVIEW NOT ISSUED	M	AB			34	01/16	BB	ECP	ECP X0213 AS BUILT TO SITE MARK UP ASB 15538KW	JMP	AB		ATH		
VB	05/14	NR	ECP KA14 REMEDIATION - IFR NOT ISSUED	M	AB			33	08/13	JK	ECP	ECPs K1334 & K1334-05 AS BUILT TO SITE MARK UP ASB: 14036KW & 1318KW	JMP	AC		ATH		
								32	02/13	PK	ECP	ECP K1544 AS BUILT TO SITE MARK UP ASB 13018KW	JMP	AC		ATH		

T GIVEN A V NUMBER H SPEC. 5.1.

DESIGNED	DATE	15.11.83
DRAWN	C.VANCE	
CHECKED		
APPROVED		
SCALE	NONE	
STICKFILE		

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
GAS & CONDENSATE LINES
KAPUNI WELLSITE KA 1 & 7

Todd Energy

SHEET NO 1 of 1 REVISION 36
 DRAWING NO 941-10-00106


18

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

ITEM No.
NAME
SIZE
DESIGN BAR(G) @ €
OPER.
DUTY

A-2164
SCRAPER TRAP

V-2116
FUEL GAS KNOCK OUT
914 O.D x 2500 TANTAN
19.6 @ 100



PROJECT NOTES

- NOTES:
1. FLOWSHEET SHOWN IN RECYCLED GAS MODE
2. LSH-2116A DOES NOT CLOSE SDV-2116A (FUEL GAS K.O INLET)
3. LSL-2189 UNIT = NORGREN'S 666/126.
4. LOCAL MIMC SCREEN AT WELLSITE.

This drawing is confidential and is the property of SHELL TODD OIL SERVICES LTD. It must not be disclosed to any third party or lent without written consent from Shell Todd Oil Services Ltd.


NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
J7	04/3	CM	ECP-K1334 APPROVED FOR DESIGN	JR	AB	ATH		23	07/04	RJR	SMR	SMR	K5212 AS BUILT TO SITE MARK UP	BB	CS	M&R	
J6	04/3	JJS	ECP-K1334 RE-ISSUED FOR HAZOP NO CHANGE	JR	AJC			22	06/03	BRT	K995			MG	JP	M&R	
J5	10/2	MI	ECP-K1334 RE-ISSUED FOR HAZOP	JR	MK									JMP	TD	SF	
J4	03/2	SG	ECP-K1334 RE-ISSUED APP FOR CONSTRUCTION	MK		ATH		28	06/17	AMP	ECP	ECP	XX17172 AS BUILT TO SITE MARK UP ASB 17181KK	JMP	AB	ATH	
J3	09/2	VB	ECP-K1334 APPROVED FOR CONSTRUCTION	JR	MK	ATH		27	04/14	DG	ECP	ECP	K1334 AS BUILT TO SITE MARK UP ASB 14039KW	JMP	AC	ATH	
J2	09/2	VB	ECP-K1334 APPROVED FOR CONSTRUCTION	JR	MK	ATH		26	07/13	MH	ECP	ECP	K1544 AS BUILT TO SITE MARK UP ASB 13159KW	VB	RW	AI	
J1	09/3	MI	ECP-K1334 RE-APPROVED FOR CONSTRUCTION	JR	AB	ATH		25	02/11	JW	ECP	ECP	K1379 AS BUILT TO SITE MARK UP ASB 10238KW	VB	PWM	AI	
J0	05/3	JC	ECP-K1334 APPROVED FOR CONSTRUCTION	JR	AB	ATH		24	07/09	MH	ECP	ECP	K1328 AS BUILT TO SITE MARK UP ASB 9159KW	VB	PWM	AI	

DESIGNED	DATE	DATE	REVISION
P.A	8-3-79		1 of 1
L.H	15-3-79		
E BLUYCK	16-3-79		
R PREBBLE	16-3-79		

SHELL TODD OIL SERVICES LIMITED
 PRIVATE BAG NEW PLYMOUTH NEW ZEALAND
 SHEET NO. 1 of 1
 DRAWING NO. 941-10-00113

ITEM No.
 NAME
 SIZE
 DESIGN BARG @ eC
 OPER.
 DUTY

A-2169
 SCRAPER TRAP
 95.2 barg @ 80eC



- NOTES:
1. LOCAL MIMIC SCREEN AT WELLSITE.
 2. INJECTION FITTING & NOZZLE TO ENSURE INHIBITOR IS ATOMISED.
 3. REMOVABLE SPOOL FOR FUTURE COMPRESSOR TIE-INS.
 4. PIPELINE DESIGN PRESSURE 70 BARG.
 5. INSTRUMENT IMPULSE LINES TO BE HEAT TRACED.
 6. PRESSURE NOT TO EXCEED 5 BARG.
 7. PIPE SURFACE TEMPERATURE.
 8. SWAGelok DIELECTRIC FITTING INSTALLED TO MAINTAIN CATHODIC PROTECTION.
 9. KSW-XSV-2169A TO ALLOW ESD TESTING WITHOUT STOPPING GAS SUPPLY TO VECTOR/FONTERRA PIPELINE.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
-	-	-	-	-	-	-	-	07	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM	-	AI	-	-
-	-	-	-	-	-	-	-	06	07/09	MH	ECP	ECP K1328 AS BUILT TO SITE MARK UP ASB 9155KW	VB	PMM	-	AI	-	-
-	-	-	-	-	-	-	-	05	12/08	MH	ECP	ECP K1282 AS BUILT TO SITE MARK UP ASB 8214KW	VB	LS	-	AI	-	-
C1	07/09	VB	ECP K1328 APPROVED FOR CONSTRUCTION	MK	PMM	-	-	11	08/19	SH	ECP	ECP K1720 AS BUILT TO SITE MARK UP ASB 118006KK	JMP	AB	-	MW	-	-
CO	06/09	LMM	ECP K1328 APPROVED FOR DESIGN	MK	PMM	-	-	10	03/17	BB	ECP	ECP XK17172 AS BUILT TO SITE MARK UP ASB 17079KK	JMP	TD	-	SF	-	-
B1	6/09	MW	EMR K497 ISSUED FOR CONSTRUCTION	LP	CRP	ECT	KJE	09	04/12	LMM	ECP	ECP K1334 AS BUILT TO SITE MARK UP ASB 12058KW	VB	PB	-	ATH	-	-
B0	5/09	CSM	EMR K497 APPROVED FOR DESIGN	LMM	CRP	ECT	KJE	08	03/12	MH	ECP	ECP K1470 AS BUILT TO SITE MARK UP ASB 12049KW	VB	JS	-	AI	-	-

DESIGNED	DATE	DRAWN	CHECKED	APPROVED	SCALE	STICKFILE
G ROBERTSON	2/95	M WEST	K ALLUM	S HARVEY	-	WD100158

KAPUNI WELLSITES	
PIPING & INSTRUMENT DIAGRAM	1 of 1
GAS SCRAPER LAUNCHER A-2169	REVISION 11
KA-1&7 (KIWI PIPELINE)	DRAWING No 941-10-00118

	Todd Energy
--	--------------------

ITEM No.
NAME
SIZE
DESIGN BARG @ 6C
OPER.
DUTY


P-0136
METHANOL PUMP
0.6m³/DAY
238 @ 386C

P-0137
METHANOL PUMP
0.163m³/DAY
69 @ 386C
NOTE 3

P-0139
METHANOL PUMP
0.6m³/DAY
345 @ 386C

T-2191
METHANOL TANK
5m³
ATMOS

P-2109
METHANOL PUMP
0.3 m³ / DAY
99 @ 386C



Pumps only used during start-up (very infrequent) - section not included.

M27	KA-20 WELLHEAD	131
M24	KA-19 WELLHEAD	128/1
M29	KA-19 WELLHEAD CHOKE	128/2

M23	G/G EXCHANGER TUBE INLET	119/2
M16	CHOKE TO LTS INLET	119/1
M26	V-2852 LTS COILS INLET	119/1
M20	UNIT 7 TUBESIDE OUTLET	121/1

M5	COND V-2152	108/2	DISCONNECTED
M6	W/HT TO CLASS	108/2	DISCONNECTED
M15	LTS OFF GAS	119/1	KA-12 LTS RELOCATED
M17	LG-2853A	119/2	
M18	CLASS DUMP	119/2	
M19	SHELL INLET	121/1	
M21	LG-2852A	119/1	
M22	LTS COND (V-2852)	119/1	
M25	FUEL GAS	107/2	
M28	CLASSIFIER OFFGAS	119/2	
M8	REC'D TO FLARE	109/2	
M10	REC'D TO FLARE	108/2	DISCONNECTED
M11	REC'D TO FLARE	109/2	DISCONNECTED
M12	REC'D TO FLARE	109/2	DISCONNECTED

26_KA19_08_METTNK_L



ABANDONED IN SITU

- NOTES:
- ALL TUBING IS IMPERIAL STANDARD.
 - FUEL GAS USD WILL REQUIRE TO BE RESET TO OPERATE METHANOL PUMP P-0137, EVEN IF INJECTING METHANOL TO ANOTHER LOCATION.
 - P-0137 WILL BE LINED OUT TO THE FUEL GAS SYSTEM WHEN THE SITE IS UNMANNED. THE PUMP WILL BE SET TO MINIMUM STROKE (APPROX 0.53 L/H).
 - FUTURE CONNECTION

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

NO	DATE	BY	CHKD	APPR	CHD	APPR	NO	DATE	BY	ECP	DESCRIPTION	CHD	APPR	CHD	APPR	NUMBER	TITLE
H1	03/17	JMP	ECP	K1245 AS BUILT TO SITE MARK UP ASB 8126KW	VB	PMM	AI										
H2	10/16	JMP	ECP	PROJECT ISSUED FOR HAZOP													
G1	03/12	LMM	ECP	K1459 APPROVED FOR DESIGN	JMP	AB	MM										
F6	05/13	J-C	ECP	K1245 APPROVED FOR CONSTRUCTION	JMP	GD	KB										
J1	05/18	JMP	ECP	KA-7 FACILITIES APPR FOR CONSTRUCTION	JMP	AB	SJ										
J4	03/18	JMP	ECP	K1334 AS BUILT TO SITE MARK UP ASB 14036KW	JMP	AB	ATH										
J8	03/18	JMP	ECP	KA-7 FACILITIES ISSUED FOR HAZOP	JMP	AB	ATH										
H2	09/17	CSM	ECP	K1245 CUSP APPR FOR CONSTRUCTION	VB	PMM	AI										
H2	09/17	CSM	ECP	K1152 AS BUILT TO SITE MARK UP ASB 8198KW	VB	PMM	AI										

KAPUNI WELLSITES

PIPING & INSTRUMENT DIAGRAM

METHANOL INHIBITOR

KAPUNI WELLSITE 1 & 7

DESIGNED	K ALLUM	DATE	3/95
DRAWN	G ROBERTSON	DATE	3/95
CHECKED	M WEST	DATE	3/95
APPROVED	K ALLUM	DATE	3/95
APPROVED	S HARVEY	DATE	3/95
SCALE			
STICKLE			


SHEET NO **2** OF 3 REVISION 13

DRAWING NO **941-10-00102**

ITEM No.
 NAME
 SIZE
 DESIGN BARG @  c
 OPER.
 DUTY

P-2190
 METHANOL PUMP
 400 LITRES/DAY
 99 @ 38
 NOTE 3

P-2192
 CORROSION INHIBITOR PUMP
 10 LITRES/DAY
 99 @ 38
 NOTE 3



26_KA19_08_METTNK_L

- NOTES:
- ALL TUBING IS IMPERIAL STANDARD.
 - GRT IS SUPPLIED WITH PUMP.
 - TEXT PUMPS DESIGNED FOR PRESSURES UP TO 345 BARG. PRESSURE RESTRICTED TO 99 BARG FOR HYDROTEST REQUIREMENTS.
 - WIRELESS INSTRUMENT.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	REVISIONS	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
05/18		JMP	KA-7 FACILITIES APPR. FOR CONSTRUCTION			AI	KB	05	08/18	BB	ECP	ECP KA-7 REMEDIATION AS BUILT TO SITE MARK UP ASB T18050KW	JMP	GD		KB			
03/18		JMP	KA-7 FACILITIES ISSUED FOR HAZOP			SB	KB	03	05/16	NR	ECP	ECP XK16137 AS BUILT TO SITE MARK UP ASB 16522KW	JMP	AB		SE			
11/11		BA	ECP-K1334 ISSUED FOR HAZOP	JR	KS			02	04/14	DG	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16147KW	JMP	AB		ATH			
11/10		MH	ECP-K1334 APPROVED FOR DESIGN	KC	NS		AI	01	03/12	VB		JMP	AB		ATH				
10/10		VB	ECP-K1334 REDRAWN AS SHEET 3	KC	NS			00	10/10	VB		VB	PB		ATH				


DESIGNED	K CHANNON	DATE	10/10
DRAWN	V BRENNAN	DATE	10/10
CHECKED	K CHANNON	DATE	10/10
APPROVED	N STONER	DATE	10/10
SCALE			
STICKFILE			

KAPUNI WELLSITES	
PIPING & INSTRUMENT DIAGRAM	
KIWI CHEMICAL INJECTION	
KAPUNI WELLSITE 1 & 7 (KIWI PI)	
SHEET No	3 of 3
REVISION	05
DRAWING No	941-10-00102



Appendix 2.
P&ID Sectionalisation for KA-2

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY



- NOTES
- KA-2 STARTUP OVERRIDE WORKS ON PSL-0200A, PSL-0201A & PSL-0215A & TIMES OUT AFTER 40 MINUTES, OR ON KS-0200C DISABLE.
 - VALVES INDICATING SIZE ONLY ARE NOT GIVEN A V NUMBER AS THEY DO NOT CONFORM TO SPEC. 5.1.
 - ALL TUBING IS IMPERIAL STANDARD.
 - XSDV 0200A CLOSURES 20 SECONDS AFTER XSV-0200C AND OPENS 60 SECONDS BEFORE XSV-0200C
 - RATE OF CHANGE
 - MONOFLANGE ISOLATION (AGCO HD27)
 - FO DENOTES FIRST OUT ALARM SEQUENCE ON DCS.

- FLT DENOTES THE ANALOG INPUT FIELD LOOP IS MONITORED FOR FAULTS.
- CLOSES FLOWLINE XSV-0200A. UNIT MUST BE RESET BEFORE VALVE RE-OPENS.
- CORROSION INHIBITOR INJECTION POINT IN BACK OF SOLID BLOCK XMAS TREE
- MINIMUM DISTANCE BETWEEN XCP-0200E AND XMAS TREE IS 10m
- CORROSION PROBE IN 6 O'CLOCK POSITION
- RV-0202A HAS BEEN SIZED BASED ON A MAX CITHP OF 71 BARG. IF CITHP INCREASES AS A RESULT OF WELL INTERVENTION THE RV MAY NEED TO BE REPLACED.

This drawing and associated design is the copyright and property of TODD TARANAKI LIMITED and shall not be used for any purpose or project other than that designated without prior consent.

NO	DATE	BY	CONSTRUCTION ISSUE	CHD	APPR.	CHD	APPR.	NO	DATE	BY	EVR	DESCRIPTION	CHD	APPR.	CHD	APPR.	NUMBER	TITLE
								23	07/13	MH	ECP	ECP K1544 AS BUILT TO SITE MARK UP ASB 13134KW	JMP	AC		ATH		
								22	04/13	JC	ECP	ECP K1544 AS BUILT TO SITE MARK UP ASB 13053KW	JMP	AC		ATH		
								21	06/12	MH	ECP	ECP K1470 AS BUILT TO SITE MARK UP ASB 12111KW	VB	PB		ATH		
								20	01/12	MH	ECP	ECP K1394 AS BUILT TO SITE MARK UP ASB 12012KW	VB	JS		AI		
								26	11/18	AcB	K1816	AS BUILT - PROJECT 12115 (K1816)	GRP	MA		KB		
								25	10/16	NR	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16386KK	JMP	AB		SF		
								24	27/04	BB	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16131KW	JMP	AB		SF		

DESIGNED	DATE	KAPUNI WELLSITES	
MF/MZ	28-8-73	DRAWING No. 941-10-00201	
MB/DK	28-8-73	SHEET No. 1 of 2	
C BEATH	28-8-80	REVISION	
SCALE NONE		DRAWING No. 941-10-00201	


STICKFILE W0100010

Todd Energy

ITEM No.
 NAME
 SIZE
 DESIGN BARG @ &C
 OPER.
 DUTY

E-2210
 WELLSTREAM COOLER
 150NB HEADER & 50NB FINNED TUBES
 238 @ 85

E-2260
 WELLSTREAM COOLER
 150NB HEADER & 50NB FINNED TUBES
 238 @ 85



NOTES:
 1. RAILED CURTAINS INSTALLED ON COOLER TO CONTROL AIR FLOW.

This drawing is confidential and is the property of SHELL TODD OIL SERVICES LTD. It must not be disclosed to any third party or lent without written consent from Shell Todd Oil Services Ltd.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	EWR	REVISIONS	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE	REFERENCE DRAWINGS
AS	794	GR	K433 CONSTR. UPDATE	MW	KA	CB	SH	0	5/93	DP	K433	FIRST ISSUE								
EG	0911	VB	ECP K1394 APPROVED FOR CONSTRUCTION	AH	AP	AL	05	06/14	NR	ECP	ECP K1463 AS BUILT TO SITE MARK UP ASB 14129KW	JMP	AB	ATH						
EG	0308	HN	ECP K1154 PRELIMINARY ISSUE-CANCELLED	NS	PWM		04	01/12	MH	ECP	ECP K1394 AS BUILT TO SITE MARK UP ASB 12012KW	VB	JS	JA						
EG	0303	HNS	EWR K542 ISSUED FOR DESIGN	AH		PAA	03	05/06	HKS		ECP K1086 TEMPERATURE UPGRADE	FE	JEA	RP						
BH	0702	DS	EWR K534 APPROVED FOR CONSTRUCTION	CWM		PAA	02	08/03	HKS		K542 & K534 AS BUILT	DS	PM	MSR						
DB	0502	HNS	EWR K534 APPROVED FOR CONSTRUCTION	CWM		PAA	01	7/94	GR	K433	AS BUILT TO ASB NO 102K	MW	KA	CB	SH					

DESIGNED	DATE	DRAWN	CHECKED	APPROVED	SCALE	STICKFILE
D PARKER	5/93	M WEST	C BROWERS	5/93	NONE	

KAPUNI WELLSITES
 PIPING & INSTRUMENT DIAGRAM
 WELLSTREAM COOLERS
 WELLSITE 2

SHS SHELL TODD OIL SERVICES LIMITED
 PRIVATE BAG NEW PLYMOUTH NEW ZEALAND
 SHEET No 2 of 2 REVISION 05
 DRAWING No 941-10-00201

ITEM No.
NAME
SIZE
DESIGN OPER.
DUTY


BARG & 6c

V-201A
H.P. KNOCKOUT
686x4572
238/856c

E-201A
GAS/COND. EXCHANGER
SURFACE 45.9sqm
SHELL 62/716c TUBE 238/856c

V-204A
SECONDARY KNOCKOUT
914x3048
63/38

04_KA02_03_WSCOL1_V



05_KA02_03_WSCOL2_V

06_KA02_03_GCEXCT_V


17_KA02_03_LTSEPB_L

- NOTES
- 1500# FLANGES HAVE BEEN USED
 - THIS LINE HAS BEEN DERATED FROM SPEC 50/50A TO SPEC 15. FLANGES REMAIN AT 5000#
 - SCREWED INJECTION QUILL INSTALLED.

This drawing is confidential and is the property of SHELL TODD OIL SERVICES LTD. It must not be disclosed to any third party or lent without written consent from Shell Todd Oil Services Ltd

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	EWR	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
..	24	11/09	MH	ECP	ECP K1311 AS BUILT TO SITE MARK UP ASB 9198RW	VB	PMM	AI
..	23	08/07	MH	ECP	ECP K1201 & K1161 AS BUILT TO SITE MARK UP ASB 7117RW & 7080RW	VB	PMM	AI
..	22	05/06	HKS	..	K1086 TEMPERATURE UPGRADE	FE	JEA	RP
..
..	28	01/16	CMP	ECP	ECP K1591 AS BUILT TO SITE MARK UP ASB 15547KW	JMP	AB	ATH
..	27	02/15	NR	ECP	ECP X0213 AS BUILT TO SITE MARK UP ASB 15030KW	JMP	AB	ATH
..	26	06/12	MH	ECP	ECP K1470 AS BUILT TO SITE MARK UP ASB 12111KW	VB	PB	ATH
..	25	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM	AI

DESIGNED	DATE	KAPUNI WELLSITES
CB	21-1-80	PIPING & INSTRUMENT DIAGRAM
P HINES	27-8-80	LTS UNIT 2A (BS & B SKID)
C BEATH	28-8-80	WELLSITE 2
SCALE
STICKFILE



NOTES
 1. VOID.
 2. FOR CONTINUATION OF METHANOL INJECTION SEE DRG 941-10-210/1.
 3. FOR CONTINUATION OF CHEMICAL INJECTION SEE DRG 941-10-210/2.
 4. FOR CONTINUATION OF INSTR. AIR SEE DRG 941-10-204/1.
 5. WHEN X-OVER SELECTED, EITHER L.T.S. USD WILL SHUT THE OTHER.
 6. PCV-0212A/B SIZED TO LIMIT HP BREAKTHROUGH FOR 71 BARG UPSTREAM PRESSURE (MAX CTHP).

This drawing is confidential and is the property of SHELL TODD OIL SERVICES LTD. It must not be disclosed to any third party or lent without written consent from Shell Todd Oil Services Ltd.

NO	DATE	BY	CHKD	APPR	CHKD	APPR	NO	DATE	BY	EWR	DESCRIPTION
1	11/18	AMB	K1816	AS BUILT - PROJECT 12115 (K1816)							
2	07/16	BB	ECP	ECP KX16002 AS BUILT TO SITE MARK UP ASB 16250KK							
3	06/14	NR	ECP	ECP K1589 AS BUILT TO SITE MARK UP ASB 14061KW							
4	06/12	MH	ECP	ECP K1470 AS BUILT TO SITE MARK UP ASB 12111KW							
5	10/11	JC	ECP	ECP K1396 AS BUILT TO SITE MARK UP ASB 11232KK							
6	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW							
7	02/10	MH	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10016KW							
8	11/09	MH	ECP	ECP K1311 AS BUILT TO SITE MARK UP ASB 9198KW							


DESIGNED	CB	DATE	21-1-80
DRAWN	P HINES	DATE	27-8-80
CHECKED		DATE	28-8-80
APPROVED	C BEATH		
APPROVED			
SCALE			
STICKFILE			

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
LTS UNIT 2A (BS&B SKID)
WELLSITE 2

WM10052 SHEET No **2 of 3** REVISION **TO 30**

Todd Energy
 DRAWING No **941-10-00202**

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY



No isolation valves and no PECPR - Note: will contain the entire pipeline inventory

No isolation valves and no PECPR - Note: will contain the entire pipeline inventory

- NOTES
- PIG LAUNCHER KICK LINE REMOVED FOR PRODUCTION TESTING.
 - CLASS 1 CHECK VALVE.
 - MUST BE CLOSED WHENEVER KA-2 WELLSITE ESD OCCURS.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.


NO	DATE	BY	CHKD	APPR.	CHD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHD	APPR.	CHD	APPR.	NUMBER	TITLE
EG	0407	JMP					15	0715	BB	ECP	ECP X0213 AS BUILT TO SITE MARK UP ASB 15254KK	JMP	AB	ATH			
DO	0602	DS					14	0672	MH	ECP	ECP K1470 AS BUILT TO SITE MARK UP ASB 12111KK	VB	PB	ATH			
C2	0300	JK					13	0111	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KK	VB	LM	AI			
E1	1299	AGM					12	1010	MH	ECP	ECP K1400 AS BUILT TO SITE MARK UP ASB 10222KK	VB	AP	AI			
GO	1010	LMM					18	0819	SH	ECP	ECP XK18002 AS BUILT TO SITE MARK UP ASB T19008KK	JMP	SG	MW			
FG	0308	KN					17	0217	AMP	ECP	ECP XK17172 AS BUILT TO SITE MARK UP ASB 17004KK	JMP	AB	SF			
E4	0607	VB					16	0716	BB	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16250KK	JMP	AB	SF			

CONSTRUCTION ISSUE	CONSULTANT	TODD	REVISIONS	DESCRIPTION	CONSULTANT	TODD	REFERENCE DRAWINGS

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

V-0203A
FUEL GAS K.O POT
273 OD x 914
10.3/88

V-0205A
INST. GAS RECEIVER
168 OD x 914
10.3/88



- NOTES**
1. VALVES INDICATING SIZE ONLY ARE NOT GIVEN A V NUMBER AS THEY DO NOT CONFORM WITH SPEC. 5.1
 2. V-0203A HAS A FLOAT ARRANGEMENT WHICH SHUTS OFF FLOW TO OUTLET IF VESSEL IS FULL OF LIQUID.

This drawing is confidential and is the property of SHELL BP AND TODD OIL SERVICES LTD. It must not be disclosed to any third party or left without written consent from Shell BP and Todd Oil Services Ltd

CONSTRUCTION ISSUE										REVISIONS										REFERENCE DRAWINGS									
NO	DATE	BY	CHD	APPR.	CHD	APPR.	NO	DATE	BY	CHD	APPR.	CHD	APPR.	NO	DATE	BY	CHD	APPR.	CHD	APPR.	NUMBER	TITLE							
							07	11/09	MH	ECP	ECP K1311 AS BUILT TO SITE MARK UP ASB 9198KW	VB	PWM	AI															
							06	12/01	BRT	K988	AS BUILT TO SITE MARK UP ASB 886K	VB	AM	KJ E															
							05	07/00	RJR	K168	AS-BUILT TO SITE MARK UP	KCB	AM	KJ E															
J0	03/08	KN	ECP K1154 PRELIMINARY ISSUE CANCELLED	PWM			04	6/96	PCA	K373	AS-BUILT TO SITE MARK-UP ASB 232K			PCA	SH														
H0	03/03	DS	DRAWING CANCELLED	JT		PAA	3	3.3.93	JMC	1398	KAPUNITSA HAZOPS AS BUILT	NB	GPV	PN															
G1	12/99	AGM	EWR K168 ISSUED FOR CONSTRUCTION	AM		TAF	2	2/9/91	NB	K385	GENERAL AS BUILT																		
G0	08/99	VB	EWR K168 ISSUED FOR DESIGN	PM	AM	TAF																							
F0	4/94	GR	K373 CONSTRUCTION	MW	ME	AD-SH	08	07/16	BB	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16250KK	JMP	AB	SF															

DESIGNED	DATE	DRAWN	CHECKED	APPROVED	SCALE
CB	21-1-80	P HINES	C BEATH		NONE



STICKFILE	DESIGNED	DATE	DRAWN	CHECKED	APPROVED	SCALE
	CB	21-1-80	P HINES	C BEATH		NONE

SHEET No			REVISION		
3 of 3			08		

DRAWING No			
941-10-202			

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

T-0201
WATER STORAGE TANK
3835 O.D. X 3550 HIGH



ABANDONED IN-SITU

KA-16 WELL ABANDONED MAR '03. THE PARTIALLY COMPLETED DESIGN HAS BEEN HELD FOR USE WITH A POSSIBLE FUTURE WELL ON SKETCH 941-210-093

NOTES
THIS LINE HAS BEEN OPERATED FROM SPEC 8050K TO SPEC 15. FLANGES REMAIN AT 300#.

This drawing is confidential and is the property of SHELL TODD OIL SERVICES LTD. It must not be disclosed to any third party or lent without written consent from Shell Todd Oil Services Ltd.

NO	DATE	BY	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	EWR	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
46	03/08	NV															
60	03/03	DS															
40	1/03	TMA															
40	06/02	DS															
48	12/99	AGM															
41	12/00	LMM															
49	11/00	VB															
NO	DATE	BY	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	EWR	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
											REVISIONS						
											REFERENCE DRAWINGS						

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

T-0202
INHIBITOR TANK (SS)
8500l x 900 HIGH
AMB./ATMOS.


P-0202A
INHIBITOR PUMP

P-0202B
INHIBITOR PUMP

T-0202B
INHIBITOR TANK
(IBC)

F-0202A/B/C
STRAINER

P-0202C
INHIBITOR PUMP



- NOTES:
1. LINE NOT TO BE BLOCKED WHILE PERFORMING MAINTENANCE ON T-0202.
 2. WIRELESS INSTRUMENT.
 3. * VENDOR SUPPLIED.
 4. VOID.
 5. ELEVATION OF CALIBRATION TUBE VENT TO BE GREATER THAN TANK VENTS.
 6. STANDARD 40 MESH STRAINER
 7. VOID.
 8. TO SAFE LOCATION. TUBING DESIGN SIZE AS PER DEP & PUMP VENDOR RECOMMENDATION.
 9. CATCH PIT CONTENTS TO BE SAMPLED & CHECKED BEFORE RELEASE TO GRADE. IF CONTAMINATED, STANDARD OPERATING PROCEDURE FOR HANDLING/DISPOSING THE CONTAMINATED FLUID TO BE FOLLOWED.

20_KA02_04_FUELGS_V

BUND SHARED WITH CORROSION INHIBITOR AND METHANOL TANKS AND PUMPS (REFER DWG 941-10-210/1.)

This drawing is confidential and is the property of SHELL TODD OIL SERVICES LTD. It must not be disclosed to any third party or lent without written consent from Shell Todd Oil Services Ltd.

NO	DATE	BY	CHKD	APPR	CHD	APPR	NO	DATE	BY	EWR	DESCRIPTION	CHD	APPR	CHD	APPR	NUMBER	TITLE
CG	07/14	NR	---	---	---	---	07	01/10	MH	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10008KW	VB	PMM	AI	---	---	---
FG	06/11	VB	---	---	---	---	06	06/09	JL	ECP	ECP K1256 AS BUILT TO SITE MARK UP ASB 9128KW	VB	PMM	AI	---	---	---
E1	12/08	LMM	---	---	---	---	05	08/03	JPJ	MULTI	EWR K534 & K542 AS BUILT TO SITE MARK UP	BB	PM	MSR	---	---	---
EB	11/08	VB	---	---	---	---	04	04/03	AMH	K534	AS BUILT TO SITE MARK UP	DS	---	MSR	---	---	---
DO	03/08	NR	---	---	---	---	---	---	---	---	---	JMP	TD	SF	---	---	---
CO	03/03	DS	---	---	---	---	10	03/17	BB	ECP	ECP XK17172 AS BUILT TO SITE MARK UP ASB 17070KK	JMP	AB	ATH	---	---	---
BO	07/02	DS	---	---	---	---	09	01/15	NR	ECP	ECP K1575 AS BUILT TO SITE MARK UP ASB 15017KW	JMP	AB	ATH	---	---	---
AG	04/14	MW	---	---	---	---	08	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM	AI	---	---	---
NO	DATE	BY	CHKD	APPR	CHD	APPR	NO	DATE	BY	EWR	DESCRIPTION	CHD	APPR	CHD	APPR	NUMBER	TITLE
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

NOTE 9 TO GRADE

DESIGNED: N BAILEY DATE: 2/9/11

DRAWN: N BAILEY DATE: 2/9/11

CHECKED:

APPROVED:

SCALE:

STICKFILE:

W0100134 SHEET No: 2 of 2 REVISION: 10


DRAWING No: 941-10-00210

SHELL TODD OIL SERVICES LIMITED
PRIVATE BAG NEW PLYMOUTH NEW ZEALAND

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

T-0203
METHANOL TANK (SS)
1530 OD x 1220 HIGH
AMB./ATMOS.

P-0203
METHANOL PUMP



23_KA02_05_METTNK_L

24_KA02_05_METPMP_L

20_KA02_04_FUELGS_V

Methanol pump only used during start-up (infrequent) - not included

5

BUND SHARED WITH CORROSION INHIBITOR AND METHANOL TANKS AND PUMPS. REFER DWG 941-10-2102

- NOTES
- VOID.
 - * VENDOR SUPPLIED
 - VOID.
 - LEVEL GAUGE VISIBLE FROM FILLING POINT/CONNECTION TO TRUCK.
 - VALVE TO REMAIN CLOSED UNLESS INJECTING TO DOWNSTREAM INJECTION POINTS. VALVES 15V77 AND 10V77 MUST BE CLOSED BEFORE 15V82 IS OPENED

This drawing and associated design is the copyright and property of TODD TARANAKI LIMITED and shall not be used for any purpose or project other than that designated without prior consent.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
-	-	-	-	-	-	-	-	15	11/18	ABB	K1816	AS BUILT PER SITE MARK UP	GRP	MA	-	SF	-
-	-	-	-	-	-	-	-	14	02/17	AMP	ECP	ECP XX17172 AS BUILT TO SITE MARK UP ASB 17004KK	JMP	AB	-	SF	-
-	-	-	-	-	-	-	-	13	10/16	NR	ECP	ECP XX16002 AS BUILT TO SITE MARK UP ASB 16386KK	JMP	AB	-	SF	-
-	-	-	-	-	-	-	-	12	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM	-	AI	-
-	-	-	-	-	-	-	-	11	02/10	MH	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10016KW	VB	PWM	-	AI	-
-	-	-	-	-	-	-	-	10	06/09	JL	ECP	ECP K1256 AS BUILT TO SITE MARK UP ASB 9124KW	VB	PWM	-	AI	-
-	-	-	-	-	-	-	-	09	08/03	JFJ	MULTI	EWR KS34 & KS42 AS BUILT TO SITE MARK UP	BB	PM	-	MSR	-
-	-	-	-	-	-	-	-	08	04/03	AMH	KS34	AS BUILT TO SITE MARK UP	DS	-	-	MSR	-
G1	12/08	LMM	ECP-K1256 APPROVED FOR DESIGN	MK	LS	-	-	-	-	-	-	-	-	-	-	-	-

DESIGNED	DATE	DRAWN	DATE	CHECKED	DATE	APPROVED	DATE	SCALE	STICKFILE
N BAILEY	2/9/91								

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

DESIGNED	DATE	DRAWN	DATE	CHECKED	DATE	APPROVED	DATE	SCALE	STICKFILE
N BAILEY	2/9/91								


NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	

Appendix 3.
P&ID Sectionalisation for KA-4 and KA-14

ITEM No. NAME SIZE DESIGN BAR(G) @ 6c OPER. DUTY

KA-4 WELLHEAD MAX. SHUT IN PRESSURE 80 BARG
P-2446 WELLHEAD CELLAR PUMP

HYDRAULIC CONTROL UNIT WELLHEAD CELLAR PUMP



07_KA04_06_KA4FLW_V

01_KA04_01_KA4WHD_V


- NOTES:
- REFER TO DWG 941-10-00409 FOR INJECTION SYSTEM
 - VALVE IS SS SUITABLE FOR LOW TEMP OF -90c.
 - THIS LINE HAS BEEN DERATED FROM SPEC 50/50A TO SPEC 15. FLANGES REMAIN 5000#
 - SAFETY CRITICAL HEAT TRACING.
 - LOCAL MIMIC SCREEN AT WELLSITE.
 - CUSHION TEE.
 - 50mm RCS ACCESS FITTING.
 - BACK PRESSURE REGULATOR STOPS CELLAR PUMP FROM OPERATING BELOW 7.5 BARG AIR PRESSURE.
 - WHERE 'NS' (NON SPEC) IS USED IN THE LINE NUMBER REFER TO ISOMETRIC FOR SPOOL MATERIALS.
 - MeOH USED FOR START UP.
 - EXISTING VALVE REPLACED WITH BLINDED DUMMY SPOOL.
 - USED FOR START UP. WIDE OPEN IN NORMAL OPERATION.
 - SAND PROBE
 - 2 NON RETURN VALVES OF DISSIMILAR TYPE REQUIRED.
 - FLOWLINE CHOKE TO BE RAMPED CLOSED UNDER USD OR ALL KPS INLET VALVES CLOSED (CONDENSATE).
 - TARGET TEE.
 - VALVE USED FOR DEPRESSURISATION DOWN STREAM OF NRV THROUGH WELLSITE HEAD.
 - MONOBLOCK CW INTEGRAL CHECK VALVE.
 - 5000 PSI DOUBLE BLOCK & BLEED VALVES & CHECK VALVES FITTED DIRECTLY TO INSTRUMENT FLANGE BETWEEN KILL WING VALVES.
 - MONOBLOCK & BLEED CW INJECTION QUILL.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.



KAPUNI WELLSITES																																																
PIPING & INSTRUMENT DIAGRAM																																																
WELLHEAD KA-4																																																
WELLSITE 4 & 14																																																
<table border="0"> <tr> <td>DESIGNED</td><td>DATE</td><td colspan="3">KAPUNI WELLSITES</td> </tr> <tr> <td>DRAWN</td><td>MFWZ</td><td>28-8-73</td><td colspan="2">PIPING & INSTRUMENT DIAGRAM</td> </tr> <tr> <td>CHECKED</td><td>MB/DK</td><td>28-8-73</td><td colspan="2">WELLHEAD KA-4</td> </tr> <tr> <td>APPROVED</td><td>C BEATH</td><td>28-8-80</td><td colspan="2">WELLSITE 4 & 14</td> </tr> <tr> <td>APPROVED</td><td></td><td></td><td colspan="2"></td> </tr> <tr> <td>SCALE</td><td>NONE</td><td></td><td colspan="2"></td> </tr> </table>										DESIGNED	DATE	KAPUNI WELLSITES			DRAWN	MFWZ	28-8-73	PIPING & INSTRUMENT DIAGRAM		CHECKED	MB/DK	28-8-73	WELLHEAD KA-4		APPROVED	C BEATH	28-8-80	WELLSITE 4 & 14		APPROVED					SCALE	NONE				<p>1 of 1 37</p>								
DESIGNED	DATE	KAPUNI WELLSITES																																														
DRAWN	MFWZ	28-8-73	PIPING & INSTRUMENT DIAGRAM																																													
CHECKED	MB/DK	28-8-73	WELLHEAD KA-4																																													
APPROVED	C BEATH	28-8-80	WELLSITE 4 & 14																																													
APPROVED																																																
SCALE	NONE																																															
<p style="text-align: center;">Todd Energy</p>																																																
<table border="0"> <tr> <td>NO</td><td>DATE</td><td>BY</td><td>CHKD</td><td>APPR.</td><td>NO</td><td>DATE</td><td>BY</td><td>DESCRIPTION</td><td>NO</td><td>DATE</td><td>BY</td><td>DESCRIPTION</td> </tr> <tr> <td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td> </tr> </table>										NO	DATE	BY	CHKD	APPR.	NO	DATE	BY	DESCRIPTION	NO	DATE	BY	DESCRIPTION														<table border="0"> <tr> <td>NO</td><td>DATE</td><td>BY</td><td>DESCRIPTION</td> </tr> <tr> <td></td><td></td><td></td><td></td> </tr> </table>					NO	DATE	BY	DESCRIPTION				
NO	DATE	BY	CHKD	APPR.	NO	DATE	BY	DESCRIPTION	NO	DATE	BY	DESCRIPTION																																				
NO	DATE	BY	DESCRIPTION																																													

ITEM No.
NAME
SIZE
DESIGN BAR(G) @ €
OPER.
DUTY

TO WELLSITE ESD
941-10-00401/1



- NOTES:
1. WIRELESS SIGNAL.
 2. VALVE IS SS SUITABLE FOR LOW TEMP OF -90°C
 3. XSV-2430A AND SDV-2430F ARE FITTED WITH A QUICK VENT WHICH RELIEVES BACK TO THE HYDRAULIC TANK T-2430. THE QUICK VENT RETURN FROM SDV-2430F HAS TWO LO VALVES.
 4. LOCAL MIMIC AT WELLSITE.
 5. BACK PRESSURE REGULATOR STOPS CELLAR PUMP FROM OPERATING BELOW 7.5 BARG AIR PRESSURE.
 6. CRITICAL HEAT TRACING VOID.
 7. VOID.
 8. XCV-2430A/B/C OVER RIDE STEM LOCKED OPEN.
 9. REFER TO DEPRESSURING PROCEDURE FOR CONTROL OF LOW TEMPERATURE CONCERNS DURING DEPRESSURISATION.
 10. CONNECTION POINT FOR PPD SKID IF REQUIRED.



ABANDONED
IN SITU

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
NR	09/17	RR	K1729 CUSP APPR. FOR CONSTRUCTION	ML	GD	SF		26	05/18	CSM	ECP	ECP K1729 AS BUILT TO SITE MARK UP AS B 18001KW	JMP	GD	KB			
NR	05/17	JMP	ECP K1729 RE ISSUED AFC	ML	SG	SF		25	05/17	RR	ECP	ECP K1708 AS BUILT TO SITE MARK UP AS B 17177KW	JMP	TD	SF			
NR	02/17	JMP	ECP K1729 APPROVED FOR DESIGN	ML	NS	SF		24	03/16	BB	ECP	ECP K16002 AS BUILT TO SITE MARK UP AS B 16099KW	JMP	AB	S			
NR	10/16	AMP	CUSP PROJECT ISSUED FOR HAZOP	SG	ML			23	11/15	BB	ECP	ECP K1630 AS BUILT TO SITE MARK UP AS B 15429KW	JMP	AB	ATH			
NR	07/13	JC	ECP K1334 RE ISSUED AFC	AH	AC	ATH		22	10/15	BB	ECP	ECP X0213 AS BUILT TO SITE MARK UP AS B 15429KW	JMP	AB	ATH			
NR	11/12	MH	ECP K1334 RE ISSUED AFC	AKH	MK	ATH		21	07/15	NR	ECP	ECP K1481 AS BUILT TO SITE MARK UP AS B 15159KW	JMP	AB	ATH			

DESIGNED: MSASSMAN DATE: 6-87
 DRAWN: MSASSMAN DATE: 6-87
 CHECKED: G HENULT DATE: 6-87
 APPROVED: G HENULT DATE: 6-87
 APPROVED: BF DATE: 8-87
 SCALE: NTS


KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
WELLHEAD KA-14
WELLSITE KA-4 & 14

STICKFILE: WK100017 SHEET No: 1 of 2 REVISION: 26
 DRAWING No: 941-10-00403

Todd Energy

ITEM No.
NAME
SIZE
DESIGN BAR(G) @ 6C
OPER.
DUTY

SITE ESD
941-10-00401/1



05_KA04_05_KA14FW_V

06_KA04_06_KA14CK_V

07_KA04_06_KA4FLW_V


08_KA04_06_MIXFLW_V

NOTES:

1. METHANOL INJECTION LINES TO BE 1 1/2" SS BY INSTRUMENTS. SEE DWG 941-10-409/2 FOR METHANOL INJECTION SYSTEM.
2. CLAMP ON SAND FILTER MONITOR.
3. ALL TUBING IS IMPERIAL STANDARD.
4. TARGET TEE INCLUDED FOR POTENTIAL SAND PRODUCTION.
5. VOID.
6. ANTI-TAMPER MANUAL RESET SOLENOIDS, CANNOT BE RESET UNTIL PAHH SYSTEM IS RESET.
7. VOID.
8. REMOVEABLE INSULATION ON MONOBLOCKS.
9. 50mm RCS ACCESS FITTING WITH CORROSION PROBE. ELASTOMERS IN ACCESS FITTING ONLY SUITABLE FOR -34°C.
10. VALVE OPENING TO BE CONTROLLED AND SET BY OPERATOR.
11. TWO PHASE AND/OR SLUG FLOW.
12. COTTON REEL SPOOL INSTALLED BETWEEN 100V93 VALVES.
13. VOID.
14. C3 TO BE INSTALLED AT LEAST 2m FROM CHOKE VALVE.
15. LOCAL MIMIC SCREEN AT WELLSITE.
16. FLOWLINE CHOKE CONTROL SWITCHED TO MANUAL AND FULLY CLOSED (0%) UPON USD, OR ALL KPS INLET VALVES CLOSED.
17. VOID.
18. AXIAL FLOW SHUT OFF VALVE.
19. CONNECTIONS FOR PORTABLE WELL TESTING SEPARATOR.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE	DESIGNED	DATE	DATE	KAPUNI WELLSITES	
E4	09/17	JMP	K1729 EUSP APPR. FOR CONSTRUCTION	M	GD		SF												MSASSMAN	6-87	6-87	PIPING & INSTRUMENT DIAGRAM	
E3	05/17	JMP	ECP K1289 PRE APPROVED FOR DESIGN	M	SG		SF												G HENEULT	6-87	6-87	WELLHEAD KA-14	
E2	02/17	JMP	ECP K1729 APPROVED FOR DESIGN	M	NS		SF												G HENEULT	6-87	6-87	WELLSITE KA-4 & 14	
E1	08/16	AMP	EUSP PROJECT ISSUED FOR HAZOP	SG	ML			04	05/18	CSM	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB T19011KK	JMP	GD					BF	8-87	8-87		
E0	08/16	AW	EUSP PROJ. ISSUED FOR REVIEW	M	SG			03	05/17	RR	ECP	ECP K1708 AS BUILT TO SITE MARK UP ASB 17177KW	JMP	TD									
B1	08/14	NR	ECP KA-14 REMEDIATION AFC					02	09/15	NR	ECP	ECP K1334 AS BUILT TO SITE MARK UP ASB 15314KW	JMP	AB									
B0	07/14	JMP	KA-14 REMEDIATION FOR HAZOP	M	AB			01	03/14	MH	ECP	ECP K1334 AS BUILT TO SITE MARK UP ASB 14036KW	JMP	AB									



- NOTES:
1. PIPE CLAMP SENSOR
 2. WIRELESS INSTRUMENT.
 3. LOCAL MIMIC SCREEN AT WELLSITE.
 4. THIS ROUTE PROVIDES VENT ROUTE FOR US PIPING.
 5. CRITICAL HEAT TRACING - PROTECTS SAFEGUARDING INSTRUMENT FROM WAX BLOCKAGES.
 6. FOR BLEEDING DRY GAS LINE INTO MULTIPHASE LINE FOR PIGGING.
 7. COTTON REEL SPOOL.
 8. VOID.
 9. VOID.
 10. VOID.
 11. VOID.
 12. BARRED TEE REQUIRED AT BLEED OF DB&B.
 13. RE-PRESSURISATION VALVE.
- NOTE 4
TO PIG LAUNCHER
A-2440
- WET GAS PIPELINE FROM
KA-1 & 7 & KPS
A-2165
- GAS PIPELINE TO
KPS RECEIVER A-502D
- MULTIPHASE PIPELINE
TO KPS A-501C
- COND PIPELINE TO
KA-1 & 7 & KPS
(A-501B)


NO	DATE	BY	CONSTRUCTION ISSUE	CONSULTANT	TODD	NO	DATE	BY	DESCRIPTION	CONSULTANT	TODD	NO	DATE	BY	DESCRIPTION	CONSULTANT	TODD	NUMBER	TITLE
54	09/17	JMP	K1729 EUSP APPR. FOR CONSTRUCTION	M	GD	23	05/18	CSM	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB 18001KW	JMP	GD	KB						
53	05/17	JMP	K1729 RE-APPROVED FOR DESIGN	M	SG	21	08/13	AMP	ECP	ECP KX17172 AS BUILT TO SITE MARK UP ASB 17181KK	JMP	TD	SF						
52	02/17	JMP	ECP K1729 APPROVED FOR DESIGN	M	NE	20	10/12	JC	ECP	ECPs K1334-05 & K1334 AS BUILT TO SITE MARK UP ASB: 13184KW & 14036KW	JMP	AC	ATH						
51	10/16	AMP	EUSP PROJECT ISSUED FOR HAZOP	SG	M	19	03/12	LMM	ECP	ECP K1470 & K1324 AS BUILT TO SITE MARK UP ASB 12213KW & 12288KW	DBM	AC	ATH						
NI	10/13	JC	ECP K1334-05 APPROVED FOR CONST.	AKH	M	18	01/11	KP	ECP	ECP K1334 AS BUILT TO SITE MARK UP ASB 12058KW	VB	PB	ATH						
NI	09/13	MH	ECP K1334-05 ISSUED FOR HAZOP	AKH	M					ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM	AI						
19	10/10	LMM	ECP K1320 APPROVED FOR DESIGN	DI	AP	24	11/19	CL	ECP	ECP KX18002 AS BUILT TO SITE MARK UP ASB T19007KK	JMP	SG	MW						

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.



ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

A-2440
SCRAPER LAUNCHER



11_KA04_08_GASPIG_V


10_KA04_08_GASPL_V

14_KA04_11_GASKA7_V

- NOTES
1. AVOID USING PIG TRAP VENT LINE FOR DEPRESSURISING KA-1/7 TO KA-4/14 FLOWLINE.
 2. 250NB SCH 30 ERW API 5L X46 MDPE COATED CLASS 600 FLANGES 94.5 BARG @ 60°C TO NZS 5223: PART 1 1986

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

REVISIONS										DESIGNED				DATE				KAPUNI WELLSITES												
NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR	CHKD	APPR	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR	CHKD	APPR	NUMBER	TITLE	SCALE	NTS	STICKFILE	WM100150	SHEET No	2	OF	2	REVISION	08	DRAWING No	941-10-00407
G4	08/11	LMM	ECP K1334 UNIT A RE-BS APPR. FOR DESIGN	ML	KS		AI	07	04/12	LMM	ECP	ECP K1334 AS BUILT TO SITE MARK UP ASB 12058KW	VB	PB		ATH														
								06	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM		AI														
HM	09/17	RR	K1729 EUSP APPR. FOR CONSTRUCTION	ML	GD		SF	05	12/08	DW	ECP	ECP K1152 AS BUILT TO SITE MARK UP ASB 8198KW	VB	PWN		AI														
HB	05/17	JMP	ECP K1729 RE APPROVED FOR DESIGN	ML	SG		SF	04	05/06	DW	ECP	ECP K11041 AS BUILT TO SITE MARK UP ASB 6063KW	VB	PWN		AI														
HD	02/17	JMP	ECP K1729 APPROVED FOR DESIGN	ML	NS		SF	03	05/07	JMP	ECP	ECP K11004 AS BUILT TO SITE MARK UP ASB 5052KW	VB	JA		RP														
HI	10/16	AMP	EUSP PROJECT ISSUED FOR HAZOP	SG	ML			02	06/04	SK	K546	AS BUILT TO SITE MARK UPS																		
HD	08/16	AME	EUSP PROJECT ISSUED FOR REVIEW	ML	SG																									
GS	12/11	SG	ECP K1334 CWS-10005 AFC	KS	AP		AI	08	05/18	CSM	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB 18001KW	JMP	GD		KB														



Pumps only used during start-up (very infrequent) - section not included.

- NOTES:
1. VOID.
 2. VOID.
 3. FLAME ARRESTOR SUPPLIED WITH TANK.
 4. VOID.
 5. VOID.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CHKD	APPR.	CHD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHD	APPR.	NUMBER	TITLE			
LG	06/13	MI	ECP	K1405	APPROVED FOR CONSTRUCTION	AB	AC	ATH	23	12/13	JC	ECP	ECP	K1495	AS BUILT TO SITE MARK UP ASB 13281KW	JMP	AB	ATH		
K7	05/13	JC	ECP	K1334	APPROVED FOR CONSTRUCTION	JR	AB	ATH	22	10/13	JJS	ECP	ECP	K1568	AS BUILT TO SITE MARK UP ASB 13226KW	JMP	AC	ATH		
KG	04/13	MI	ECP	K1334	APPROVED FOR DESIGN	JR	AB	ATH	21	10/13	JJS	ECP	ECP	K1544	AS BUILT TO SITE MARK UP ASB 13225KW	JMP	AC	ATH		
									20	01/11	KP	ECP	ECP	K1379	AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM	AI		
MB	02/18	CSM	K1729	CLSP	RE-APPR. FOR CONSTRUCTION	GD	SG	SF												
MB	09/17	JMP	K1729	CLSP	APPR. FOR CONSTRUCTION	ML	GD	SF	26	05/18	CSM	ECP	ECP	K1729	AS BUILT TO SITE MARK UP ASB 18001KW	JMP	GD	KB		
MB	02/17	JMP	ECP	K1729	APPROVED FOR DESIGN	ML	NG	SF	25	01/18	LS	ECP	ECP	KX17172	AS BUILT TO SITE MARK UP ASB 1171202	JMP	TD	KB		
MB	10/16	AMP	CLSP	PROJECT	ISSUED FOR HAZOP	SG	ML		24	09/15	NR	ECP	ECP	K1334	AS BUILT TO SITE MARK UP ASB 15314KW	JMP	AB	ATH		


DESIGNED: MSASSMAN DATE: 6-87
 DRAWN: T HEWETT DATE: 8-87
 CHECKED: T HEWETT DATE: 8-87
 APPROVED: T HEWETT DATE: 8-87
 APPROVED: BG DATE: 8-87
 SCALE: .
 STICKFILE: .

WV100023 SHEET No: 1 of 3 REVISION: 26
 DRAWING No: 941-10-00409

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
METHANOL KA-4 & 14
WELLSITE KA-4 & 14

Todd Energy

Appendix 4.
P&ID Sectionalisation for KA-5 and KA-10



01_KA05_01_WLHEAD_L

02_KA05_02_FLWLNE_L

03_KA05_02_DESAND_L

07_KA05_04_METHPM_L

- NOTES:
- FOR CONTINUATION OF CORROSION INHIBITOR SEE DWG 941-10-503/1
 - FOR CONTINUATION OF METHANOL INJECTION SEE DWG 941-10-503/1
 - CORROSION PROBE IN 6 O'CLOCK POSITION
 - CLAMP ON SAND MONITOR. NOT ALL FUNCTIONS SHOWN
 - RATE OF CHANGE ALARM
 - VOID
 - THIS LINE HAS BEEN DERATED FROM SPEC 5050A TO SPEC 15. FLANGES REMAIN AT 5000#
 - VOID
 - VOID
 - TARGET TEE

This drawing is confidential and is the property of SHELL TODD OIL SERVICES LTD. It must not be disclosed to any third party or lent without written consent from Shell Todd Oil Services Ltd

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHD	APPR.	NO	DATE	BY	EWR	DESCRIPTION	CHD	APPR.	CHD	APPR.	NUMBER	TITLE
K1	03/17	JMP	ECP-K1709(PHASE-2) APRR. FOR CONST.	AB	TD	SF	29	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM	AI				
J6	12/16	JMP	ECP-K1709 STAGE 2 RE APRR. FOR DESIGN	AB	TD	SF	28	05/08	MH	ECP	ECP K1278 AS BUILT TO SITE MARK UP ASB 8083KW - CANCELLED	VB	PMM	AI				
J5	10/16	BB	ECP-K1709 RE ISSUED FOR HAZOP	AB	OCK													
M8	03/16	JMP	ECP-K1709 PHASE 2 APPROVED FOR DESIGN	AB	TD	SF	34	07/17	BB	ECP	ECP K1709 AS BUILT TO SITE MARK UP ASB 17222KW	JMP	ATD	SF				
J4	08/16	JMP	ECP-K1709(PHASE-1) RE-AFC	AB	TD	AF	33	03/16	BB	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16080KW	JMP	AB	SF				
K3	05/17	JMP	ECP-K1709(PHASE-2) RE APRR. FOR CONST.	AB	TD	SF	31	06/12	MH	ECP	ECP K1544 AS BUILT TO SITE MARK UP ASB 13134KW	VB	PB	ATH				
K2	03/17	JMP	ECP-K1709(PHASE-2) RE APRR. FOR CONST.	AB	TD	SF	30	01/12	MH	ECP	ECP K1394 AS BUILT TO SITE MARK UP ASB 12012KW	VB	JS	AI				

SHEET 2 NOW OBSOLETE EWR 1065


KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
WELLHEAD 5
WELLSITE 5 & 10

SHEET No 1 of 1 REVISION 34
 DRAWING No 941-10-00501

SHELL TODD OIL SERVICES LIMITED
 PRIVATE BAG NEW PLYMOUTH NEW ZEALAND

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

FL-0501
VENT



This drawing is confidential and is the property of SHELL TODD OIL SERVICES LTD. It must not be disclosed to any third party or lent without written consent from Shell Todd Oil Services Ltd.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	EWR	REVISIONS	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE	REFERENCE DRAWINGS
P1	05/16	NR	ECP K1709 (PHASE 1) APPR. FOR DESIGN	AB	AB			42	10/15	BB	ECP	ECP K1665 AS BUILT TO SITE MARK UP ASB 15412KW	JMP	AB	ATH					
R3	03/17	JMP	ECP K1709 (PHASE 2) RE APPR. FOR CONST.	AB	TD			41	10/14	NR	ECP	ECP K1589 AS BUILT TO SITE MARK UP ASB 14218KW	JMP	AB	ATH					
R2	02/17	JMP	ECP K1709 (PHASE 2) APPR. FOR CONST.	AB	TD			40	11/12	MH	ECP	ECP K1324 AS BUILT TO SITE MARK UP ASB 12288KW	JMP	AC	ATH					
R1	12/16	JMP	ECP K1709 STAGE 2 RE APPR. FOR DESIGN	AB	TD			39	06/12	MH	ECP	ECP K1470 AS BUILT TO SITE MARK UP ASB 12112KW	VB	PB	ATH					
R0	09/16	JMP	ECP K1709 PHASE 2 APPROVED FOR DESIGN	AB	TD			38	03/12	MH	ECP	ECP K1467 AS BUILT TO SITE MARK UP ASB 12050KW	VB	JS	AI					
P2	07/16	JMP	ECP K1709 APPROVED FOR CONSTRUCTION	AB	TD			37	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM	AI					
P1	07/16	JMP	ECP K1709 (PHASE 1) APPR. FOR DESIGN	AB	TD			43	07/17	BB	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB 17222KW	JMP	TD	SF					

KAPUNI WELLSITES

PIPING & INSTRUMENT DIAGRAM

GATHERING LINES

WELLSITE 5 & 10

DESIGNED: B MORE
DATE: 6.1.82
DRAWN: MSHWER
CHECKED: MSHWER
APPROVED: MSHWER
SCALE: 16.2.82
APPROVED: C BEATH

SHEET No. 1 of 1
REVISION 43
DRAWING No. 941-10-00506

SHELL TODD OIL SERVICES LIMITED
PRIVATE BAG
NEW PLYMOUTH
NEW ZEALAND

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

T-0509
METHANOL TANK
858d X 914mm HIGH

P-0509
METHANOL PUMP

P-0508
INHIBITOR PUMP

T-0508
INHIBITOR TANK
1530d X 1220 HIGH

P-0507
INHIBITOR PUMP

V-0521
AIR ACCUMULATOR
774d X 1700
900 LITRE
10 BARG/-3 TO 50&C

P-0510
INHIBITOR PUMP

K-0501 AIR
COMPRESSOR FAULT/PRESS LOW
941-10-00519/1

KA-5 USD
941-10-00506/1

KA-5 HEATER METHANOL INJECTION
M6 FUEL GAS V-0561 505/3

WELLHEAD METHANOL INJECTION
M1 WELLHEAD 941-10-501/1

KA-5 WELLHEAD
CORR. INHIB. INJECTION
C1 WELLHEAD 5 501/1

05_KA05_03_METHTK_L

06_KA05_03_METHPM_L

Only used during start up (infrequent) - not included

INSTRUMENT AIR FROM K-0501
941-10-00519/1

25CA-1W-2502

CHEMICAL INJECTION PAD

NOTES

1. LG HAS A.S.V (AUTOMATICALLY SAFETY VALVE) FITTED.
2. *VENDOR SUPPLY
3. VOID
4. ELEVATION OF CALIBRATION TUBE VENT TO BE GREATER THAN TANK VENT.
5. CALIBRATION TUBE ELEVATION & TUBING ARRANGEMENT SUITABLE FOR GRAVITY FILLING FROM T-0508. MINIMIZE TUBING LENGTH.
6. WIRELESS INSTRUMENT.

This drawing is confidential and is the property of SHELL TODD OIL SERVICES LTD. It must not be disclosed to any third party or lent without written consent from Shell Todd Oil Services Ltd

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	EWR	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE	REFERENCE DRAWINGS
CG	07/04	NR	ECP K1375 APPROVED FOR CONSTRUCTION	AB	ML		ATH	26	11/12	MH	ECP	ECP K1324 AS BUILT TO SITE MARK UP ASB 12288KW	JMP	AC	ATH				
F1	11/11	LMM	ECP K1324 APPROVED FOR CONSTRUCTION	GO	AP		AL	25	02/12	MH	ECP	ECP K1353 AS BUILT TO SITE MARK UP ASB 12026KW	VB	JS	AI				
FO	06/11	VB	ECP K1324 APPROVED FOR DESIGN	AKH	PW		AL	24	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM	AI				
EA	07/09	VB	ECP K1324 RE-ISSUED APP FOR CONST.	GH	PMM		AL												
J0	09/16	JMP	ECP K1709 PHASE 2 APPROVED FOR DESIGN	AB	TD		SE	29	11/16	BB	ECP	ECP K1709 AS BUILT TO SITE MARK UP ASB 17222KW	JMP	TD	SF				
BB	07/16	JMP	ECP K1743 AS BUILT TO SITE MARK UP ASB 16461KW	BB	ECP		SF	28	07/16	NR	ECP	ECP K1743 AS BUILT TO SITE MARK UP ASB 16261KW	JMP	AB	SF				
NR	07/16	JMP	ECP K1709 APPROVED FOR CONSTRUCTION	AB	TD		SF	27	01/15	NR	ECP	ECP K1575 AS BUILT TO SITE MARK UP ASB 15017KW	JMP	AB	ATH				
NR	04/16	JMP	ECP K1209 ISSUED FOR FEED				SF												

DESIGNED	DATE	DRAWN	CHECKED	APPROVED	APPROVED	SCALE	STICKFILE
		L MINTOSH	J CARLEY	M SHMER			
	19.7.84		25.8.84	11.10.84			

KAPUNI WELLSITES			
PIPING & INSTRUMENT DIAGRAM			
CHEMICAL INJECTION (WELLSITE AREA)			
WELLSITE 5 & 10			
SHEET No	1 of 1	REVISION	30
DRAWING No	941-10-00503		
SHELL TODD OIL SERVICES LIMITED			
PRIVATE BAG	NEW PLYMOUTH	NEW ZEALAND	

Appendix 5.
P&ID Sectionalisation for KA-6 and KA-17

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

P-2646
WELLHEAD CELLAR PUMP

KA-6
WELLHEAD 6
API 10,000#

PY-2600A
AIR BOOSTER

P-2649
HYDRAULIC FLUID PUMP

V-2601
KA-6 DESANDER
STEELHEAD MODEL 21615
94.8 BARG @ 85°C/316°C



T-2649
HYDRAULIC FLUID RESERVOIR
270d x 635L

13_KA06_04_MTPUMP_L

13_KA06_04_MTPUMP_L

03_KA06_03_DESAND_V

01_KA06_01_WLHEAD_V



- NOTES CONT
- 9. FOR CONTINUATION OF METHANOL INJECTION LINES SEE DRG. 941-10-6102.
 - 10. VALVE USED FOR REPRESSURISATION & ALLOWED FOR DEPRESSURING THE SYSTEM VIA WELLHEAD VENT FACILITY.
 - 11. FLOWLINE CHOKES TO BE RAMPED CLOSED UNDER USD, ESD, KPS ESD OR ALL KPS INLET VALVES CLOSED (CONDENSATE TRAINS).
 - 12. PI TO BE LOCATED CLOSE TO GLOBE VALVE.
 - 13. GATE VALVE TO BE ACCESSIBLE FROM OUTSIDE CELLAR.
 - 14. FILTER PROVIDED DUE TO EXPECTED SCALE ISSUE FROM REUSED INSTRUMENT GAS LINE.
 - 15. AS BUILT HCU REPRESENTATION INDICATIVE ONLY. DETAILED AS-BUILDING TO BE COMPLETED DURING DISCOVERY AS-BUILDING.
 - 16. 5000# GATE VALVE WILL BE SUPPLIED BY WELL SERVICES.
 - 17. MOS CAN BE APPLIED TO PALL-2600A. MOS ACTIVE TIMEOUT ALARMS AFTER 4 HOURS AND AGAIN EVERY 4 HOURS THEREAFTER.
 - 18. TI MEASURES WALL TEMPERATURE. MUST BE LOCATED IMMEDIATELY DOWNSTREAM OF GLOBE VALVE.
 - 19. NORMALLY "DISABLED". PROGRAMMED TO "ENABLED" UNDER WORK PERMIT WHEN REQUIRED. EG WELL DE-PRESSURISED.

- NOTES.
- 150x100 DOUBLE STUDDED ADAPTER FLANGE
 - STARTUP OVERRIDE OVERRIDES THE FOLLOWING ESD SIGNALS: PSHL-2600A
 - 20 SECOND DELAY ON SV-2601A ON CLOSING
 - 20 SECOND DELAY ON SV-2600 ON OPENING
 - KSW-2600A OPERATES A SOFTWARE TIMER.
 - SITE AS BUILT ONLY. NOT AS BUILT ACCORDING TO ECP K1320 DESIGN REQUIREMENTS.
 - 25CP-15-2671A REPLACED WITH 1/2" SS TUBING UNDER K1618. MIN. THICKNESS OF 1/2" SECTION REQ'D 0.049".
 - SPARE 1/2" SS TUBING INSTALLED UNDER K1618. MIN. REQ'D THICKNESS OF BURIED SECTION IS 0.049". TUBING MAY BE USED FOR INST. AIR IN FUTURE.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CONSULTANT	TODD	NO	DATE	BY	ECP	DESCRIPTION	CONSULTANT	TODD	NUMBER	REFERENCE DRAWINGS
K1	09/12	JJS	ECP K1459 NOT REQUIRED	JR	JFC	33	04/16	BB	ECP	ECP K116002 AS BUILT TO SITE MARK UP ASB 16131KK & ASB 16159KK	JMP	AB	SF	
K6	07/12	VB	ECP K1459 ISSUED FOR HAZOP	JR	JA	32	01/16	DG	ECP	ECP K1618 AS BUILT TO SITE MARK UP ASB 15583KW	JMP	AB	ATH	
						31	07/13	MH	ECP	ECP K1544 AS BUILT TO SITE MARK UP ASB 13134KW	JMP	AC	ATH	
L4	03/18	CSM	K1729 EUSP RE-APPR. FOR CONSTRUCTION	GD	SJG	30	08/12	MH	ECP	ECP K1470 AS BUILT TO SITE MARK UP ASB 12180KW	DBM	AC	ATH	
L3	11/17	CSM	K1729 EUSP RE-APPR. FOR CONSTRUCTION	ML	GD	29	06/12	MH	ECP	ECP K1470 AS BUILT TO SITE MARK UP ASB 12113KW	VB	PB	ATH	
L2	09/17	JMP	K1729 EUSP APPROVED FOR DESIGN	ML	GD	30	08/12	MH	ECP	ECP K1470 AS BUILT TO SITE MARK UP ASB 12113KW	VB	PB	ATH	
L1	10/16	AMP	EUSP PROJECT ISSUED FOR HAZOP	SG	ML	35	08/18	NR	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB 118031KW	JMP	GD	KB	
L0	09/16	AME	EUSP PROJECT ISSUED FOR REVIEW	ML	SG	34	01/18	LS	ECP	ECP KX17172 AS BUILT TO SITE MARK UP ASB T171202	JMP	TD	KB	

DESIGNED: DATE: KAPUNI WELLSITES
 DRAWN: D WHITELAW 3-12-73
 CHECKED: DB 29-2-74
 APPROVED: C BEATH 28-8-80
 SCALE: NONE
 SHEET No: 1 of 2
 REVISION: 35
 DRAWING No: 941-10-00601
Todd Energy

ITEM No.
NAME
SIZE
DESIGN BAR(G) @ EC
OPER.
DUTY


W-2680 KA-17
WELLHEAD

P-2686
WELLHEAD CELLAR PUMP

P-2687A/B
HYDRAULIC FLUID PUMPS

V-2682
KA-17 DESANDER
STEELHEAD MODEL 21615
94.8 BARG @ 856C/316C

T-2688
HYDRAULIC FLUID RESERVOIR
220d x 560LG




- NOTES:
- METHANOL INJECTION LINES TO BE 6mmSS BY INSTRUMENTS SEE DWG NUMBER 941-10-006102 FOR INJECTION SYSTEM
 - FO DENOTES FIRST OUT ALARM SEQUENCE ON DCS.
 - ALL TUBING IS IMPERIAL STANDARD.
 - TI MEASURES WALL TEMP. MUST BE LOCATED IMMEDIATELY DOWNSTREAM OF GLOBE VALVE.
 - FLT DENOTES THE ANALOG INPUT FIELD LOOP IS MONITORED FOR FAULTS.
 - VOID.
 - 50mmRCS ACCESS FITTING.
 - BACK PRESSURE REGULATOR STOPS CELLAR PUMP & PPD SKID FROM OPERATING BELOW 7 BARG AIR PRESSURE.
 - XSDV-2680A CLOSING 20 SECONDS AFTER XSV-2680A. WELL VALVE OPEN SEQUENCE IS MANUALLY CONTROLLED (NO TIMERS).
 - SECOND CONNECTION POINT FOR XCP-2680A.
 - VALVE CLOSED TO PREVENT CROSS-CONTAMINATION & TANK OVERFILL OF T-2609 DUE TO REVERSE FLOW FROM P-2608A.
 - PROVISION FOR CHOKE VALVE AND FLOW METER INSTALLATION IN FUTURE.
 - TWO PHASE AND/OR SLUG FLOW.
 - TARGET TEE INCLUDED FOR POTENTIAL SAND PRODUCTION.
 - TUBING IS 1/2" OD AND 0.049" WALL THICKNESS, AND HAS A PRESSURE RATING OF 254 BAR.
 - PI TO BE LOCATED CLOSE TO GLOBE VALVE.
 - GATE VALVE TO BE ACCESSIBLE FROM OUTSIDE CELLAR.
 - 5000# GATE VALVE SUPPLIED BY WELL SERVICES.
 - DISCREPANCY BETWEEN PIT-2680C & PIT-2680D ARMED.
 - STARTUP OVERRIDE OVERRIDES THE FOLLOWING ESD SIGNALS: PIT-2680D.
 - KSW-2680A OPERATES A SOFTWARE TIMER.
 - MOS CAN BE APPLIED TO PIT-2680D. OPERATOR TO MONITOR PIT-2680C WHILE MOS IS ACTIVE. MOS ACTIVE TIMEOUT ALARMS AFTER 4 HOURS AND AGAIN EVERY 4 HOURS THEREAFTER.
 - NORMALLY "DISABLED". PROGRAMMED TO "ENABLED" UNDER WORK PERMIT WHEN REQUIRED, E.G. WELL DE-PRESSURISED.
 - SITE AS BUILT ONLY. NOT AS BUILT ACCORDING TO ECP K1320 DESIGN REQUIREMENTS.
 - VOID.
 - VOID.
 - VOID.
 - TUBING RATED FOR 280 BARG OR MORE.
 - VOID.
 - HV-2680A IS STAINLESS STEEL, EXTENDED BONNET 2500# VALVE.
 - PAHH-2680D STARTS TIMER IN SIS WHICH CLOSES SUBSURFACE SAFETY VALVE IF >236BARG FOR 50 HOURS PER EVENT OR 500 HOURS A YEAR.
 - CRITICAL TRACE HEATING 406C FOR WAX PREVENTION.
 - VOID.
 - PIPING TO FIRST ELBOW IS SCH 40S FOR PIPE STRESSING.
 - LINE CONTAINS CLASS 150 FITTINGS AND SHOULD NOT BE PRESSURED ABOVE 19 BARG.

02_KA17_02_WLHEAD_V

04_KA17_03_DESAND_V

NO	DATE	BY	CHKD	APPR.	CHD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHD	APPR.	NUMBER	TITLE
D0	07/16	ANC					07	07/16	BB	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16250K	JMP	AB	SF			
C7	10/13	MH					06	05/16	BB	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16131KW	JMP	AB	SF			
C6	08/13	JMP					05	08/14	NR	ECP	EDP K1589 AS BUILT TO SITE MARK UP ASB 14211KW	JMP	AB	ATH			
D3	03/18	CSM					04	12/14	MH	ECP	ECP K1459 AS BUILT TO SITE MARK UP ASB 13289KW	JMP	AB	ATH			
D3	11/17	CSM					03	07/13	MH	ECP	ECP K1544 AS BUILT TO SITE MARK UP ASB 13134KW	JMP	AC	ATH			
D2	08/17	JMP					09	08/18	NR	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB 18031KW	JMP	GD	KB			
D1	10/16	AMP					08	01/17	CB	ECP	ECP XK16137 AS BUILT TO SITE MARK UP ASB 16522KW	JMP	AB	SF			



13_KA06_04_MTPUMP_L

03_KA06_03_DESAND_V

04_KA17_03_DESAND_V

07_KA06_03_GASPLN_V

06_KA06_03_WSCOOOL_V

07_KA06_03_GASPLN_V

08_KA06_03_CONPLN_L (12339)

PROJECT MASTER

01 OCT 2020

ESD DAY CONSTRUCTION SHOWN IN RED CLOUDS

NEW WORK SHOWN (12339)

- NOTES**
- V-2654 & E-2651 & ASSOCIATED LINES/INSTRUMENTS RELOCATED FROM P&ID 941-10-00604/1 & 2.
 - VOID.
 - DROP OUT SPOOL FOR FUTURE MULTI PHASE OPERATION WHERE V-2654 IS BYPASSED.
 - FLOWLINE CHOKE TO BE RAMPED CLOSED UNDER USD. ESD, KPS ESD.
 - VALVE USED FOR REPRESSURISATION.
 - MAXIMUM ALLOWABLE OPERATING PRESSURE OF THE SYSTEM IS LIMITED TO 89.4 BARG @ 85°C BY THE LSHH/LSL INSTRUMENTS.
 - PRODUCTION TESTING TIE-INS.
 - LSLL-2654D SUSPENDED IN PLACE.

NO	DATE	BY	CONSTRUCTION ISSUE	CONSULTANT	TCCO	REV	DESCRIPTION	DATE	BY	DESCRIPTION
CS	09/20	GRP	ESD DAY ISSD FOR CORRECT PCR_3_2020_81	MAV	TS	ZA	NB			
CL	09/20	EB	ISSUED FOR DETAIL DESIGN PCR_3_2020_81	GRP	TS	ZA	NB			
C3	09/20	KC	RE-ISSUED FOR HAZOP - XXXX (12339)	GRP	TS	-	-			
C2	12/19	GRP	ISSUED FOR HAZOP - XXXX (12339)	CSM	JMT	-	-			
C1	11/19	EBT	ISSUED FOR DESIGN REVIEW - XXXX (12339)	CSM	TS	-	-	01	08/18	IR
CO	10/19	EBT	ISSUED FOR REVIEW - PCR_XXXX (12339)	GRP	TS	-	-	00	06/16	JSP


DESIGNED: J POTROZ DATE: 06/16
 DRAWN: MONTREE DATE: 06/16
 CHECKED: S GUNN DATE: 06/16
 APPROVED: S GUNN
 SCALE: NONE
 SHEET: 1 of 1 | C5 | 01
 PROJECT: KAPUNI WELLSITES
 PIPING & INSTRUMENT DIAGRAM
 HPKO
 WELLSITE KA-6, 11 & 17
Todd Energy
 941-10-00616(X)

ITEM No. P-2608A/B/C
 NAME CORROSION INHIBITOR PUMPS
 SIZE DESIGN PRESSURE 255 bar
 DESIGN OPER. DESIGN TEMP. -5/32°C (ALL HEADS)
 DUTY

P-2612A/B/C
 CORROSION INHIBITOR PUMPS
 DESIGN PRESSURE 255 bar
 DESIGN TEMP. -5/32°C (ALL HEADS)

T-2608A
 CORROSION INHIBITOR TANK
 1980 OD x 1642 HIGH C/STEEL


T-2608B
 METHANOL TANK
 1525 OD x 1219 HIGH S/STEEL



T-2608B is empty and isolated - section not included.

11_KA06_04_METNK1_L

- NOTES
- SITE AS BUILT ONLY. NOT AS BUILT ACCORDING TO ECP K1320 DESIGN REQUIREMENTS.
 - WIRELESS INSTRUMENT.
 - STANDARD 90 MICRON T TYPE SWAGelok FILTER (STRAINER) TO PROTECT FLOWMETER FROM BLOCKAGE.
 - ELEVATION OF CALIBRATION TUBE VENT TO BE GREATER THAN TANK VENT.
 - CALIBRATION TUBE ELEVATION & TUBING ARRANGEMENT SUITABLE FOR GRAVITY FILLING FROM T-2608A/T-2608B. MINIMISE TUBING LENGTH.
 - 25NB BLINDED FG CONNECTION SITUATED AT EDGE OLD KA-6 SKID.
 - STRAINER & FLOW METER LOCATION WILL BE REVIEWED ON THE BASIS OF FLOW METER PERFORMANCE AT KA-02 SITE.
 - VOID
 - VOID
 - BOTH TANK TOPS TO BE AT THE SAME ELEVATION. ALL LEVEL GAUGE VENTS TO BE AT HIGHER ELEVATION THAN TANK TOPS.
 - BUND SHARED WITH CORROSION INHIBITOR AND METHANOL TANKS (REFER DWG 941-10-610/2)
 - BURIED TUBING IS 1/2 OD & 0.049" WALL THICKNESS AND HAS PRESSURE RATING OF 254 BAR.
 - MINIMISE POTENTIAL FOR AIR LOCK TO PREVENT DAMAGE TO FLOW METERS.
 - 25CP-15-2671A REPLACED WITH 1/2" SS TUBING UNDER K1618. MIN. TUBING THICKNESS REQ'D 0.049".
 - 25CP-15-2671B HAS BEEN ABANDONED IN SITU UNDER K1716



ABANDONED IN SITU

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
#2	0917	JMP	K1729 EUSP APPROVED FOR DESIGN	M	GD		SF											
#4	1016	JMP	EUSP PROJECT ISSUED FOR HAZOP	SG	ML													
#6	0716	AME	EUSP PROJECT ISSUED FOR REVIEW	ML	SG													
#4	1012	LMM	ECP K1460 AFE	JR	AJC		ATH											
#3	0712	VB	ECP K1450 RE ISSUED FOR HAZOP	JR	JA													
#4	0318	CSM	K1729 EUSP RE-APPR. FOR CONSTRUCTION	GD	SHG		SF	18	06/16	NR	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB 18031KW	JMP	GD			KB	
#3	1117	CSM	K1729 EUSP APPR. FOR CONSTRUCTION	ML	GD		SF	17	03/16	BB	ECP	ECP K1666 AS BUILT TO SITE MARK UP ASB 16315KW	JMP	AB			SF	
#3	1117	CSM	K1729 EUSP APPR. FOR CONSTRUCTION	ML	GD		SF	17	03/16	BB	ECP	ECP K1716 AS BUILT TO SITE MARK UP ASB 16208KW	JMP	AB			SF	
#3	1117	CSM	K1729 EUSP APPR. FOR CONSTRUCTION	ML	GD		SF	17	03/16	BB	ECP	ECP XX16002 AS BUILT TO SITE MARK UP ASB 16080KW	JMP	AB			SF	

DESIGNED: J TERRILL DATE: 6/91
 DRAWN: G VINCENT DATE: 9/91
 CHECKED: M WEST DATE: 9/91
 APPROVED: DM STEWART DATE: 9/91
 SCALE: STICKLE
 SHEET No. 1 of 2 REVISION 20
 DRAWING No. 941-10-00610

KAPUNI WELLSITES
 PIPING & INSTRUMENT DIAGRAM
 CORROSION INHIBITOR
 WELLSITE 6 & 11

Todd Energy

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

T-2609
METHANOL TANK
1525 OD x 1219 HIGH S/STEEL

P-2609A
METHANOL PUMP
255 bar
-5/32&C

P-2609B
METHANOL PUMP
69 barg
-5/32

P-2609C
METHANOL PUMP
280 barg
-5/32

METHANOL INJECTION		
M1	HCV-2601A	17
M4	KA6 WHEAD	601/1
M5	HCV-2682A	610/1
M7	KA17 WELLHEAD	614

NOTE 3


KA-6/11 WELLSITE ESD
941-10-00601/2

Tank is always full and connected to the pump (as per discussion on 31 July 2020 with operators).

13_KA06_04_MTPUMP_L

12_KA06_04_METNK2_L

11_KA06_04_METNK1_L



Pumps only used during start-up (very infrequent) - section not included.

ABANDONED IN SITU

- NOTES:
- SITE AS BUILT ONLY. NOT AS BUILT ACCORDING TO ECP K1320 DESIGN REQUIREMENTS.
 - VOID.
 - BURIED METHANOL TUBING IS 14" WITH WALL THICKNESS 0.035" AND HAS A PRESSURE RATING OF 351 BAR.
 - BUND SHARED WITH CORROSION INHIBITOR AND METHANOL TANKS AND PUMPS. (REFER DWG 941-10-610/1)
 - LEVEL GAUGE VENT TO BE AT HIGHER ELEVATION THAN TANK TOP.
 - EXISTING PI-2609B IS REUSED AS PI-2609C.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.


NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
02/18		CSM	K1729 CLSP-RE-APPR-FOR CONSTRUCTION	GD	SJG		SF	15	02/17	AMP	ECP	ECP XK17172 AS BUILT TO SITE MARK UP ASB 1700&KW	JMP	AB		SF		
11/17		CSM	K1729 CLSP-APPR-FOR CONSTRUCTION	ML	GD		SF	14	05/16	NR	ECP	ECP K1716 AS BUILT TO SITE MARK UP ASB 1630&KW	JMP	AB		SF		
08/17		JMP	K1729 CLSP-APPROVED FOR DESIGN	ML	GD		SF	13	01/16	BB	ECP	ECP X0213 AS BUILT TO SITE MARK UP ASB 1558&KW	JMP	AB		ATH		
10/16		JMP	CLSP-PROJECT ISSUED FOR HAZOP	SG	ML			12	12/13	MH	ECP	ECP K1489 AS BUILT TO SITE MARK UP ASB 1328&KW	JMP	AB		ATH		
07/16		AME	CLSP-PROJECT ISSUED FOR REVIEW	ML	SG			11	11/13	MH	ECP	ECP K1371 AS BUILT TO SITE MARK UP ASB 1325&KW	JMP	AB		ATH		
07/13		JC	ECP K1371 RE-ISSUED FOR CONSTRUCTION	AB	AC		ATH											
06/13		MH	ECP K1489 RE-ISSUED FOR AFC	JR	AB		ATH	17	08/18	NR	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB 1803&KW	JMP	GD		KB		
								16	04/17	BB	ECP	ECP XK17172 AS BUILT TO SITE MARK UP ASB 1712&KW	JMP	TD		SF		

DESIGNED	DATE	DATE	<p>KAPUNI WELLSITES PIPING & INSTRUMENT DIAGRAM METHANOL INJECTION WELLSITE 6 & 11</p>
DRAWN	J. TERRILL	6/91	
CHECKED	G. VINCENT	9/91	
APPROVED	M. WEST	9/91	
APPROVED	D.M. STEWERT	9/91	
SCALE			
STICKLE			




Todd Energy
 SHEET No. 2 of 2 REVISION 17
 DRAWING No. 941-10-00610

Appendix 6.
P&ID Sectionalisation for KA-8 and KA-18

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY



- NOTES:
1. MOVED FROM 941-10-00808/3.
 2. 150x100 DOUBLE STUDDED FLANGE ADAPTOR.
 3. START UP OVERRIDE XS-2820A ACTS ON PSSL-2820.
 4. SUBSURFACE SAFETY VALVE CLOSES 20 SEC. AFTER SURFACE SAFETY VALVE.
 5. THIS LINE HAS BEEN DERATED FROM SPEC 50/50A TO SPEC 15. FLANGES REMAIN AT 5000#. NOTE 5
 6. REMOVEABLE SPOOL FOR FUTURE SAND FILTER/WELLSTREAM COOLER TIE-IN/DROP OUT ISOLATION SPOOL.
 7. PCV-2846B BACK PRESSURE REGULATOR TO SHUT DOWN P-2846 BELOW 8.0 BARG SUPPLY AIR PRESSURE.
 8. DROP OUT ISOLATION SPOOL.
 9. RATE OF CHANGE.
 10. VOID.



NO	DATE	BY	CHKD	APPR.	NO	DATE	BY	CHKD	APPR.	NO	DATE	BY	CHKD	APPR.	DESCRIPTION
J1	06/14	NR	ECP	K1501 ISSUED FOR HAZOP (NOT AS BUILT)	ML	AB				36	10/15	NR	ECP		ECP K1567 AS BUILT TO SITE MARK UP ASB 15413KW
J8	05/14	LPR	ECP	K1501 ISSUED FOR REVIEW	GD	ML				35	07/14	NR	ECP		ECP K1589 AS BUILT TO SITE MARK UP ASB 14064KW
HD	05/10	VB	ECP	K1214 APPROVED FOR CONSTRUCTION	AC	AP				41					
K3	02/18	CSM	ECP	K1729 CUSP RE-APPR. FOR CONSTRUCTION	GD	SG				40	05/18	LS	ECP		ECP K1729 AS BUILT TO SITE MARK UP ASB T18025KW
K2	10/17	CSM	ECP	K1729 CUSP RE-APPR. FOR CONSTRUCTION	ML	GD				39	01/17	CB	ECP		ECP KX16002 AS BUILT TO SITE MARK UP ASB T171202
K1	07/17	NR	ECP	K1729 APPROVED FOR DESIGN	ML	GD				38	05/16	BB	ECP		ECP KX16002 AS BUILT TO SITE MARK UP ASB 16526KK
HD	10/16	JMP	ECP	CLSP PROJECT ISSUED FOR HAZOP	SG	ML				37	03/16	BB	ECP		ECP KX16002 AS BUILT TO SITE MARK UP ASB 16095KW

DESIGNED: _____ DATE: _____

DRAWN: R SHEARSTON 23/10/82

CHECKED: MSHMER 23/10/82

APPROVED: MSHMER 23/10/82

APPROVED: P BARON 26/10/82

SCALE: NONE

STICKLE: _____

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
WELLHEAD KA-8
WELLSITE 8, 12 & 15

Todd Energy

SHEET No: 1 of 5 REVISION: 41
DRAWING No: 941-10-00801

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.


ITEM No.
NAME
SIZE
DESIGN BAR(G) @ eC
OPER.
DUTY

W-2850 KA-18
WELLHEAD

P-2852
WELLHEAD CELLAR PUMP

P-2851A/B
HYDRAULIC FLUID PUMPS

T-2851
HYDRAULIC FLUID RESERVOIR
220d x 560LG




- NOTES.**
1. METHANOL INJECTION LINES TO BE 6mmSS BY INSTRUMENTS. SEE DWG 941-10-806/2 FOR INJECTION SYSTEM
 2. FO DENOTES FIRST OUT ALARM SEQUENCE ON DCS
 3. ALL TUBING IS IMPERIAL STANDARD.
 4. FLT DENOTES THE ANALOG INPUT FIELD LOOP IS MONITORED FOR FAULTS.
 5. TEMPORARY SANDCATCHER
 6. 50mmRCS CORROSION PROBE SOCKET
 7. BACK PRESSURE REGULATOR STOPS CELLAR PUMP FROM OPERATING BELOW 7.5 BARG AIR PRESSURE.
 8. XSDV-2850A CLOSURES 20 SECONDS AFTER XSV-2850B. WELL VALVE OPEN SEQUENCE IS MANUALLY CONTROLLED (NO TIMERS)
 9. 50KW-15-4031 TO BE FILLED WITH INHIBITED WATER & BLINDED OFF.
 10. PP FOR FLOWING FLUID TEMPERATURE OF 75°C.
 11. PROVISION FOR FLOW METER INSTALLATION IN FUTURE. US, DS LENGTH FOR FLOWMETER AS PER VENDOR.
 12. TWO PHASE AND/OR SLUG FLOW.
 13. TARGET TEE INCLUDED FOR POTENTIAL SAND PRODUCTION
 14. VALVE OPENING TO BE CONTROLLED AND SET BY OPERATOR.
 15. 50mmRCS ACCESS FITTING WITH CORROSION PROBE ON OUTSIDE OF ELBOW.
 16. CHOKE VALVE FOR WELL STARTUP, WVC CAN BE USED IF KA-18 FLOWS TO KA-8 LTS ONLY.
 17. LOCATE CLOSE TO DEPRESSURISATION KO POT (50FL-1KT-2180B)
 18. START UP OVER-RIDE ACTS ON PALL-2850E
 19. RV-2850A SIZE DETERMINED BY HCV-2850B TRIM. ADD RED TAG AT INSTALLED VALVE.
 20. ACCESS POINT FOR ER PROBE ONCE FLOW REGIME IS STRATIFIED.
 21. VALVE IS SS FOR LOW TEMP OF -70°C TO -90°C.
 22. LOCATE CLOSE TO 50D SPEC BREAK.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CHKD	APPR.	NO	DATE	BY	CHKD	APPR.	DESCRIPTION										
A7	06/10	LMM	ECP	K1326	APPROVED FOR CONSTRUCTION	CRP	AP			07	02/16	NR	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16048KW	JMP	AB		ATH		
EG	10/18	DG	ECP	K2838	APPROVED FOR CONSTRUCTION	CRP	AP			06	07/13	MH	ECP	ECP K1544 AS BUILT TO SITE MARK UP ASB 13134KW	JMP	AC		ATH		
D2	02/18	CSM	K1729	CLSP	RE-APPR. FOR CONSTRUCTION	GD	SJG													
DT	10/17	CSM	K1729	CLSP	APPR. FOR CONSTRUCTION	ML	GD			12	09/19	SH	ECP	ECP XK18002 AS BUILT TO SITE MARK UP ASB T19011KW	JMP	AB		MMV		
DO	07/17	NR	ECP	K1729	APPROVED FOR DESIGN	ML	GD			11	05/18	CSM	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB T18025KW	JMP	GD		KB		
E1	10/12	LMM	ECP	K1517	APPROVED FOR CONSTRUCTION	CB	AJC			10	03/17	BB	ECP	ECP K1746 AS BUILT TO SITE MARK UP ASB 17071KW	JMP	TD		SF		
EG	09/12	SG	ECP	K1517	ISSUED FOR WAZOP	CB	AC			09	06/16	BB	ECP	ECP K1702 AS BUILT TO SITE MARK UP ASB 16245KW	JMP	AB		SF		
BB	06/11	VB	ECP	K1326	APPROVED FOR CONSTRUCTION	AP	RW			08	04/16	BB	ECP	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16131KW	JMP	AB		ATH		

DESIGNED: DATE: KAPUNI WELLSITES
 DRAWN: D WATEMBURG 07/09
 CHECKED: G DAVIDSON 07/09
 APPROVED: P MINCHIN 07/09
 APPROVED: A INWOOD 07/09
 SCALE: NONE
 SHEET No: 4 of 5
 REVISION: 12
 DRAWING No: 941-10-00801

Todd Energy



- NOTES:**
- SPEC 15 WELLSTREAM FLUID LINES DERATED TO:
 - DESIGN PRESSURE 180BARG. (DESIGN PRESSURE LIMITED BY 200WF-15-2810 LINE TO COOLERS).
 - DESIGN TEMPERATURE -10/80°C.
 - HYDROTEST PRESSURE 270 BARG.
 - VALVES MARKED * ARE SPEC. 50A ITEMS.
 - REMOVEABLE SPOOL FOR FUTURE SAND FILTER TIE-IN/DROP OUT ISOLATION SPOOL.
 - DROP OUT ISOLATION SPOOL.
 - ADD LOW TEMP DESIGN CASE -26°C @ 28 BARG.
 - SCH.160 PIPE WAS USED INSTEAD OF XXS PIPE (REQUIRED AS PER SPEC. 15). THE DESIGN PRESSURE HAS BEEN SET TO 237 BARG (COINCIDENT WITH MAXIMUM FLANGE RATING FOR 1500# @ 85°C). FOR HIGHER DESIGN PRESSURE A RE-CHECK IS REQUIRED. DESIGN PRESSURE BASED ON ACTUAL WALL THICKNESS ('0' MILL TOLERANCE). THE HYDROTEST PRESSURE TO BE USED IS 383 BARG @ 36°C. DESIGN PRESSURE BASED ON ACTUAL THICKNESS ('0' MILL TOLERANCE).
 - 150V164 ONLY TO BE OPENED IF KA-18 IS FLOWING NATURALLY TO LTS-15, IF 150V164 IS OPEN & EITHER COMPRESSOR RUNNING, NOTE 8 VALVE MUST BE CLOSED.
 - 100V71 PASSES FROM RIGHT TO LEFT WITH GREATER THAN 5 BAR DIFFERENTIAL. IT HOLDS FULL PRESSURE OF SYSTEM FROM OTHER SIDE.

REV	DATE	BY	DESCRIPTION	APP'D	DATE	BY	DESCRIPTION	APP'D	DATE	BY	DESCRIPTION
B1	10/20	GFP	ESD DAY ISSD FOR CONSTRUCTION PCR_3_2020_81								
B3	09/20	EB	ISSUED FOR DETAIL DESIGN PCR_3_2020_81								
B3	09/20	EB	ISSUED FOR DETAIL DESIGN PCR_3_2020_81								
E2	05/20	IC	RE-ASSIGNED FOR HAZOP-PCR_XXXX (12339)								
B1	12/19	EBT	ISSUED FOR HAZOP-PCR_XXXX (12339)								
E0	11/19	EBT	ISSUED FOR DESIGN REVIEW-PCR_XXXX (12339)								
I/D			CONSTRUCTION ISSUE								

DESIGNED	DATE	CHECKED	DATE	APPROVED	DATE	SCALE
OSMAN J POTROZ	07/17	MONTRIE	07/17			

KAPUNI WELLSITES
 PIPING & INSTRUMENT DIAGRAM
 INTERCONNECTING LINES
 WELLSITE 8, 12 & 15

12339 WF-801
 100-PL-08L1-28065
 WELLSTREAM FLUID TO SLUG CATCHER
 941-10-00829/1

ESD DAY CONSTRUCTION SHOWN IN RED CLOUDS
 NEW WORK SHOWN PCR_3_2020_81 (12339)

Todd Energy
 SHEET 5 OF 5
 REVISION B4 | 01
 DRAWING NO 941-10-00801(X)

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

BARG @ 6C


E-2800
CONDENSATE EXCHANGER
325mm O.D. x 7315mm LONG
SHELL 62 @ 71
TUBE 238 @ 856C

F-2817
FILTER
50NB 1500#

V-2803
H.P. KNOCKOUT DRUM
685mm I.D. x 4570mm S.M.S.M
236 @ 85

E-2801
K.O. FEEDSALES GAS EXCHANGER
325mm O.D. x 9750mm LONG
SHELL 62 @ 71
TUBE 238 @ 856C

E-2802
K.O. FEEDSALES GAS EXCHANGER
325mm O.D. x 3660mm LONG
SHELL 62 @ 71
TUBE 238 @ 856C



- NOTES
- REFER DWG. 941-10-8062 FOR INJECTION SYSTEM
 - CLOSES UNIT INLET XSV-2800. UNIT MUST BE RESET BEFORE VALVE RE-OPENS.
 - INJECTION QUILL.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

NO	DATE	BY	CHKD	APPR.	CHD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHD	APPR.	NUMBER	TITLE
J4	01/10	LMM	ECP	K1326	APPROVED FOR DESIGN	ML	PWM										
J3	12/09	MH	ECP	K1326	RE ISSUED FOR HAZOP	ML	PWM										
J2	09/09	VB	ECP	K1326	ISSUED FOR FEED	ML	PWM										
K2	02/18	CSM	K1729	CLSP	RE-APPR. FOR CONSTRUCTION	GD	5JG		36	10/15	NR	ECP	K1647	AS BUILT TO SITE MARK UP ASB 15326KW	JMP	AB	ATH
K4	10/17	CSM	K1729	CLSP	APPR. FOR CONSTRUCTION	ML	GD		35	07/13	MH	ECP	K1544	AS BUILT TO SITE MARK UP ASB 13134KW	JMP	AC	ATH
K6	07/17	JMP	ECP	K1729	APPROVED FOR DESIGN	ML	GD		34	05/13	JC	ECP	K1477	AS BUILT TO SITE MARK UP ASB 13112KW	JMP	AC	ATH
J5	04/10	VB	ECP	K1326	APPROVED FOR CONSTRUCTION	GNP	AP		33	05/11	JC	ECP	K1326	AS BUILT TO SITE MARK UP 11083KW	VB	AP	AI

DESIGNED: G.MCKIE DATE: 20-9-76
 DRAWN: G.MCKIE DATE: 20-9-76
 CHECKED: L.HAZLETT DATE: 3-10-76
 APPROVED: L.HAZLETT DATE: 3-10-76
 APPROVED: C.BEATH DATE: 28-8-80
 SCALE: _____
 STICKFILE: _____

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
 LTS UNIT 8 (HIGH PRESSURE)
 WELLSITE 8, 12 & 15


SHEET No: 1 of 1 REVISION: 39
 DRAWING No: 941-10-00802

Todd Energy

ITEM No.
NAME
SIZE
DESIGN BARG @ €
OPER.
DUTY

V-2804
LOW TEMPERATURE SEPARATOR
1220mm ID x 3810mm SMSM
SHELL G3 @ 38°C TUBE 238 @ 85°C

V-2805
SECONDARY K.O DRUM
915mm ID x 3050mm SMSM
G3 @ 38°C



- NOTES:
- REFER TO DWG. 941-10-806/2 FOR INJECTION SYSTEM
 - ALARMS SHOWN IN BOXES ANNUNCIATE KPS S.E.M & GROUP ALARMS.
 - SHUT-DOWN LOGIC SHOWN FOR NORMAL FLOWMODE i.e. WELLHEAD KA-8 FLOWING THROUGH LTS 8 & WELLHEAD KA-12 FLOWING THROUGH LTS 12. CROSSOVER:- ANY COMBINATION OF WELLHEAD AND LTS UNITS.
 - TRAVEL STOP INSTALLED TO REDUCE CV TO 60 TO LIMIT FLOW TO RV-2804A.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHD	APPR.	NUMBER	TITLE
G1	02/10	CSM	K1729 EUSP RE-APPR FOR CONSTRUCTION	GD	SJG			32	05/11	JC	ECP	ECP K1326 AS BUILT TO SITE MARK UP ASB 11083KW	VB	AP		AI		
G0	10/17	CSM	K1729 EUSP RE-APPR FOR CONSTRUCTION	ML	GD			31	06/10	BA	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM		AI		
F3	11/12	M1	ECP K1517 RE-ISSUED FOR A/C		ATH			30				ECP K1379 AS BUILT TO SITE MARK UP ASB 10131KW	VB	AP		AI		
F2	10/12	LMM	ECP K1517 APPROVED FOR CONSTRUCTION	CB	AJC													
F1	09/12	SG	ECP K1517 ISSUED FOR HAZOP	CB	AE			36	05/18	CSM	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB 118025KW	JMP	GD		KB		
E6	06/10	VB	ECP K1326 RE-ISSUED APPR FOR CONST.	ENR	AP			34	04/13	MH	ECP	ECP KX16002 AS BUILT TO SITE MARK UP ASB 16048KW	JMP	AB		ATH		
E5	04/10	VB	ECP K1326 APPROVED FOR CONSTRUCTION	GW	AP			33	12/12	CG	ECP	ECP K1517 AS BUILT TO SITE MARK UP ASB 130076KW	JMP	AC		ATH		
								33	12/12	CG	ECP	ECP K1426 AS BUILT TO SITE MARK UP ASB 11270KW	JMP	AC		ATH		

DESIGNED: DATE: KAPUNI WELLSITES
 DRAWN: G MCKIE 21-9-76 PIPING & INSTRUMENT DIAGRAM
 CHECKED: L HAZLETT 3-10-76 L.T.S UNIT KA-8
 APPROVED: L HAZLETT 3-10-76 KAPUNI WELLSITE KA-8, 12 & 15
 APPROVED: C BEATH 28-8-80
 SCALE: NONE
 STICKLE: NONE
 SHEET NO: 1 of 1 REVISION: 36
 DRAWING NO: 941-10-00803
Todd Energy

ITEM No.
NAME
SIZE
DESIGN BAR(G) @ °C
OPER.
DUTY


A-2863
GAS SCRAPER LAUNCHER
300mm DIA. x 1067mm LONG.

A-2813
GAS SCRAPER LAUNCHER
200mm DIA. x 890mm LONG

A-2814
CONDENSATE SCRAPER LAUNCHER
150mm DIA. x 900mm LONG

A-2864
CONDENSATE SCRAPER LAUNCHER
150mm DIA. x 964mm LONG.

PROJECT MASTER
02 NOV 2020 08



Material is mainly water, not flammable - not included.

Material is mainly water, not flammable - not included.

CONSTRUCTION NOTES
C1. INSTRUMENTS & VALVES TO BE REUSED.

NEW WORK SHOWN
EQUIPMENT CONSTRUCTION
SHOWN IN RED CLOUDS

NEW WORK SHOWN
PCR_3_2020_81 (12339)

NEW WORK SHOWN
PROJECT K1706 (11730)


- NOTES:
- MANUAL SHUTDOWN OF ALL KA-8, KA-12 & KA-15 WELLS/LTS UNITS FROM KPS UNITS FROM KPS BY OPERATOR REQUIRED AFTER VERIFICATION OF ALARMS ABOVE OR PAL-2166A OR PAL-2114A BY PR-2804 OR PR-2852A OR PR-2814 OR PR-500A (FROM KPS INLET) OR PR-2114A (FROM KA-17).
 - REFER TO DWG 941-10-808 FOR INJECTION SYSTEM.
 - PIG LAUNCHER KICK LINE REMOVED FOR PRODUCTION TESTING.
 - COTTON REEL SPOOL.
 - CLAMP ON TYPE PIG SIGNALLER.

NO	DATE	BY	CHKD	APPR	CHD	APPR	NO	DATE	BY	CHKD	APPR	NO	DATE	BY	CHKD	APPR	NO	DATE	BY	CHKD	APPR	NO	DATE	BY	CHKD	APPR
111	10/20	GFP	ISSUED FOR CONSTRUCTION PCR_3_2020_81	JA	AS	AS	28	01/13	JA	AS	AS	28	01/13	JA	AS	AS	28	01/13	JA	AS	AS	28	01/13	JA	AS	AS
112	09/20	DO	ISSUED FOR DESIGN PCR_3_2020_81 (12339)	JA	AS	AS	27	05/11	JA	AS	AS	27	05/11	JA	AS	AS	27	05/11	JA	AS	AS	27	05/11	JA	AS	AS
113	09/20	DO	RE ISSUED FOR DESIGN - PCR_3_2020_81 (12339)	JA	AS	AS	27	05/11	JA	AS	AS	27	05/11	JA	AS	AS	27	05/11	JA	AS	AS	27	05/11	JA	AS	AS
114	12/19	ASB	ISSUED FOR HAZOP - PCR_3_2020_81 (12339)	JA	AS	AS	33	09/19	JA	AS	AS	33	09/19	JA	AS	AS	33	09/19	JA	AS	AS	33	09/19	JA	AS	AS
115	09/20	GFP	RE ISSUED FOR CONSTRUCTION - K1706 (11730)	JA	AS	AS	32	05/18	JA	AS	AS	32	05/18	JA	AS	AS	32	05/18	JA	AS	AS	32	05/18	JA	AS	AS
116	11/19	GFP	ISSUED FOR CONSTRUCTION - K1706 (11730)	JA	AS	AS	31	10/16	JA	AS	AS	31	10/16	JA	AS	AS	31	10/16	JA	AS	AS	31	10/16	JA	AS	AS
117	10/19	ASB	ISSUED FOR CONSTRUCTION - K1706 (11730)	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS
118	10/19	ASB	ISSUED FOR CONSTRUCTION - K1706 (11730)	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS
119	10/19	ASB	ISSUED FOR CONSTRUCTION - K1706 (11730)	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS
120	10/19	ASB	ISSUED FOR CONSTRUCTION - K1706 (11730)	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS	29	09/18	JA	AS	AS

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

T-2866
METHANOL TANK
1974mmID x 1525mmHIGH
ATMOS

P-2884A/2876/P-2877/P-2878
METHANOL PUMPS
0.3m³/DAY



- NOTES.**
1. FLAME ARRESTOR SUPPLIED WITH TANK.
 2. VOID.
 3. P-2876, P-2877 & P-2878 EXISTING PUMPS RETAGGED AND RELOCATED.
 4. VOID
 5. EXISTING SP RETAINED.
 6. STANDARD 40 MESH T TYPE SWAGELOCK FILTER (STRAINER)

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
65	06/10	VB	ECP K1326 APPROVED FOR CONSTRUCTION	CRP	AP			15	05/18	CSM	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB T18029KW	JMP	GD		KB		
64	01/10	LMM	ECP K1326 APPROVED FOR DESIGN	MR	PWM			14	01/17	CB	ECP	ECP KX16002 AS BUILT TO SITE MARK UP ASB 16526KK	JMP	AB		SF		
								13	12/15	NR	ECP	ECP K1326 AS BUILT TO SITE MARK UP ASB 14051RW	JMP	AB		ATH		
2	02/18	CSM	RE-APPR FOR CONSTRUCTION	GD	SJG			12	05/11	JC	ECP	ECP K1326 AS BUILT TO SITE MARK UP ASB 11083KW - HOLD						
1	10/17	CSM	K1729 CUSP APPR FOR CONSTRUCTION	ML	GD			11	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM		AI		
0	10/16	JMP	CUSP PROJECT ISSUED FOR HAZOP	SG	ML			10	12/08	DW	ECP	ECP K1152 AS BUILT TO SITE MARK UP ASB 8198KW	VB	PWM		AI		
H	06/14	NR	ECP K1501 ES FOR HAZOP NOT ISSUED	ML	AB			09	07/08	MH	ECP	ECP K1245 AS BUILT TO SITE MARK UP ASB 8129KW	VB	PWM		AI		
H	05/13	LPR	ECP K1501 ES FOR REVIEW NOT ISSUED	GD	ML													



ABANDONED IN-SITU



Todd Energy

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
METHANOL INJECTION
WELLSITE 8, 12 & 15


SHEET No. **2** OF **2** REVISION **15**
DRAWING No. **941-10-00806**

ITEM No.
NAME
SIZE
DESIGN BAR(G) @ 6
OPER.
DUTY

E-2886
GAS/GAS EXCHANGER
203m²
SHELL 62 @ 71
TUBE 238 @ 85c

V-2882
LOW TEMPERATURE SEPARATOR
1219mm ID x 3810mm
SHELL 63 @ 38c
TUBE 238 @ 85c

ABANDONED IN-SITU



- NOTES:
1. REFER TO DWG 941-10-8062 FOR INJECTION SYSTEM
 2. PIPING U/S OF PCV TO BE SYMMETRICAL MINIMIZE PIPING DOWNSTREAM OF PCV
 3. MOVED FROM 941-10-008082
 4. PCV 2882A & E TO BE CONTROLLED IN BACK PRESSURE CONTROL DURING STARTUP. PRESSURE SETPOINT PROVIDED BY OPERATOR.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CONSULTANT	TODD	NO	DATE	BY	ECP	DESCRIPTION	CONSULTANT	TODD	NUMBER	TITLE
F4	02/18	CSM	K1729 CUSP RE-APP. FOR CONSTRUCTION	GD	SJG	22	05/18	CSM	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB T18025KW	JMP	GD	KB	
F3	10/17	CSM	K1729 CUSP APPR. FOR CONSTRUCTION	ML	GD	21	12/16	BB	ECP	ECP K16137 AS BUILT TO SITE MARK UP ASB 16474KW	JMP	AB	SF	
F2	07/17	NR	ECP K1729 APPROVED FOR DESIGN	ML	GD	20	05/13	JC	ECP	ECP K1477 AS BUILT TO SITE MARK UP ASB 13121KW	JMP	AC	ATH	
F1	10/16	JMP	CUSP PROJECT ISSUED FOR HAZOP	SG	ML	19	12/12	CG	ECP	ECP K1426 AS BUILT TO SITE MARK UP ASB 12270KW	JMP	AC	ATH	
F0	08/16	AME	CUSP PROJECT ISSUED FOR REVIEW	ML	SG	18	05/11	JC	ECP	ECP K1326 AS BUILT TO SITE MARK UP ASB 11083KW	VB	AP	AI	
E6	06/10	VB	ECP K1326 RE-ISSUED APP FOR CONST.	ERP	AP	17	01/11	KP	ECP	ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW	VB	LM	AI	
E5	04/10	VB	ECP K1326 APPROVED FOR CONSTRUCTION	GW	AP	16	12/08	MH	ECP	ECP K1282 AS BUILT TO SITE MARK UP ASB 8214KW	VB	LS	AI	

DESIGNED: J. TERRILL DATE: 11.6.91
 DRAWN: G. VINCENT 9/91
 CHECKED: M. WEST 9/91
 APPROVED: D.M. STEWART 9/91
 SCALE: NONE
 STICKFILE

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
 LTS UNIT KA-15
 WELLSITE 8, 12 & 15

SHEET NO: 2 of 4 REVISION: 22
 DRAWING NO: 941-10-00808

Todd Energy


ITEM No.
NAME
SIZE
DESIGN (PRESS. @ Min/Max TEMP.)
OPER.
DUTY

A-9101
WELLSTREAM GAS COMPRESSOR PACKAGE
150NB SUCTION / 80NB DISCHARGE
0.5 & 10 Std, 90.3 BARG @ 0.2 / 149°C
30.0 TO 83.0 BARG LIFT
N/A

E-9131
COOLER

F-9176
ENGINE AIR INTAKE

K-9106A
COMPRESSOR BUILDING EXHAUST FAN
N/A



NOTES:

- ⊗ DENOTES "VENDOR COUPLING"
- ⊕ DENOTES "LOW SELECT"


This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CHKD	APPR.	CHD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHD	APPR.	CHD	APPR.	NUMBER	TITLE
DS	10/17	CSM	K1729	CLSP	APPR.	FOR CONSTRUCTION	M	GD	SF								
D2	07/17	NR	ECP	K1729	APPROVED FOR DESIGN		M	GD	SF								
D1	10/16	JMP	EUSP	PROJECT	ISSUED FOR HAZOP		SG	ML		05	05/18	CSM	ECP	ECP	K1729	AS BUILT TO SITE MARK UP ASB 118025KW	
D0	08/16	AME	EUSP	PROJECT	ISSUED FOR REVIEW		ML	SG		04	10/16	BB	ECP	ECP	XX16002	AS BUILT TO SITE MARK UP ASB 16380KK	
C1	06/07	VB	ECP	K1216	APPROVED FOR DESIGN		CC	PM	AI	03	08/07	MH	ECP	ECP	K1216	AS BUILT TO SITE MARK UP ASB 7078KW	
CO	04/07	VB	ECP	K1216	ISSUED FOR HAZOP		CC	PM		02	06/07	KN	KS21	AS BUILT TO SITE MARK UP ASB 7052KW			
B2	11/06	VB	EMR	KS21	APPROVED FOR CONSTRUCTION		PMM	AVE		01	04/06	DW	KS21	AS BUILT TO SITE MARK UP ASB 6052KW			
										0	06/04	GR	KS21	FIRST ISSUE			

DESIGNED: C. MCKINNON DATE: 06/04
 DRAWN: G. ROBERTSON
 CHECKED: W. FLETCHER
 APPROVED: J. AIKEN
 APPROVED: N. BEALE
 SCALE: NONE
 SHEET NO: 1 OF 10
 REVISION: 05
 DRAWING NO: 941-10-00818

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
KA-8 COMPRESSOR
WELLSITE KA-8, 12&15

Todd Energy



38_KA08_07_FLGSEP_V

BILL OF MATERIAL

ITEM	QTY	EFX CODE	DESCRIPTION
12	1	121317	VALVE, PSV, 1" 150#RF X 2" 150#RF, .110 OR, NACE I, (FARRIS, 26DA10-12000)
13	4	102950	VALVE, BALL, 1/4" NPT, 2000#WOG, RP, 316SS, NACE CW (NAVCO, C1-R02S-20A)
14	1	107911	GAUGE, PRESSURE, BM 2-1/2" LF, 0-300 PSI DUAL, 1/4" NPT (MIKA, Z33.53)
15	2	102949	VALVE, BALL, 1/2" NPT, 2000#WOG, RP, 316SS, NACE CW (NAVCO, C1-R05S-20A)
19	2	NPN-REQ	HOSE, BRAIDED STEEL, 2" 150#RF X 2" NPT X 18" LONG
21	5	117694	VALVE, NEEDLE, 1/4" MNPT X 1/4" FNPT, 316SS BODY (AGCO, H1VDS-22)
27	1	118300	VALVE, GAS, 3-WAY, 2" 150#RF, 316SS BODY, AUTOMATED (KOMOX, 034-FT-D-6-P1-A)
28	1	104804	VALVE, QUICK VENT, 1/4" X 3/8" NPT (WABCO, P52935-2)
40	1	100898	VALVE, BALL, 2" 150#RF, FP, CS, NACE CW HANDLE (TK, FF02F01RLNCCCTT)
41	1	118163	STRAINER, Y, 2" 150#RF, 285 PSIG MAWP, CS, 1/32" SS SCREEN (ALTA, NYF-150)
43	2	106364	FLANGE, RF RED HUB, 1" 150# X 1/2" NPT SA105N
60	1	122036	GAUGE, PRESSURE, DIFF., 3" DIAL, 0-30 PSID DUAL, BACK MT, 316SS (MIKA, 700.04)
100	1	104467	MAGNETIC PICK-UP, 5/8"-18 THREAD X 2-1/2" LONG, CSA, IS (DYNALCO, M204)
101	1	NPN-REQ	JUNCTION BOX ASSEMBLY, FLAMEPROOF, RANGE 3000, Zone 1 EExd IIB T6 IP66 ATEX certified fitted with MK6/6 terminal block.
250	1	NPN-REQ	>>VESSEL, FUEL GAS, 10-3/4" OD, 285 MAWP @ 100DEG.F, SWEET CW FG-36 ELEMENT, EFX DWG#V040724L
260	1	119414	SWITCH, LEVEL, 3" 150#RF, 316SS, XP, ATEX CAV'SS FLOAT (MAGNETROL, T31-003A-212)
270	1	112629	VALVE, SET GAUGE, SWEET, 1/2" FNPT X 3/4" MNPT, CS, 3815# (PENBERTHY, 330) 3/4"
280	1	104433	GAUGE, LEVEL, CS WITH REFLEX FLAT GLASS, 2240# (PENBERTHY, 1RL1)
290	1	100247	VALVE, BALL, 2" 150#RF, RP, CS, NACE CW HANDLE (TK, FF02R01RLNCCCTT)
310	1	116009	VALVE, CHECK, SWING, 2" 150#RF, CS, NACE (NAVCO, CS-F20R01S)

BILL OF MATERIAL: W040724-22A-AB: FUEL GAS SYSTEMS
DATE-TIME EXPORTED: 2005-04-07-11:33

NOTES:

1. INSTRUMENTS USING INSTRUMENT AIR MUST BE VENTED TO ATMOSPHERE.
2. ALL SERVICE LINES OPERATING ABOVE 15 PSIG MUST BE PRESSURE TESTED PER TI PROCEDURE IN THE QC MANUAL.
3. MANIFOLD BOOST PRESSURE TO BE SET ONCE SITE CONDITIONS ARE DETERMINED.
4. ALL TUBING IS 316SS CW SWAGELock FITTINGS.

STOS DWG. NO.: 941-10-00818 W0100278 SHT. NO.: 5 of 10

REV	DESCRIPTION	DATE	DRAWN BY	CHECKED BY
5	EWR K521 AS BUILT TO ASB 6052KW	04/06	DW	VB/AvE/RP
4	FIELD AS BUILT, PER CUSTOMER COMMENTS	05/12/06	PLM	PLM
3	AS BUILT, PER CUSTOMER COMMENTS	05/07/01	PLM	PLM
2	AS BUILT	05/04/11	MGN	PLM
06	ECP X0213 AS BUILT TO SITE MARK UP ASB 15217KW	08/15	BB	JMP/AB/ATH



4700 47 Street SE Calgary AB Canada T2B 3R1 Canada Tel. +1.403.236.6800 Fax +1.403.279.0367
www.enerflex.com

TITLE: SERVICE FLOW FUEL GAS SYSTEMS WAUKESHA L5790GL
FOR: SHELL TODD OIL SERVICES LIMITED
TAG NO.: A-9101 (KA-8/15 WELL HEAD COMPRESSOR)
CONSULTANT: TRANSFIELD WORLEY NEW ZEALAND LSD: TARANAKI NEW ZEALAND
P.O.: 504568 J.O.B No.: 040724
DRWN BY: DH DESIGN BY: PLM DATE: 04/11/22 DWG. No. OP#
DATE: 04/12/20 CHKD BY: PLM DATE: 04/12/20 SF-040724-22 22A
SCALE: NTS APPVD BY: DATE: DATE: DATE:

© 2004 Enerflex Systems Ltd
REPRODUCTION OF ANY PORTION OF THESE MATERIALS WITHOUT THE EXPRESS WRITTEN CONSENT OF ENERFLEX SYSTEMS LTD IS STRICTLY PROHIBITED. THESE MATERIALS SHALL NOT BE USED FOR ANY PURPOSE OTHER THAN THE REPAIR AND MAINTENANCE OF THE PRODUCTS TO WHICH THEY RELATE.


ITEM No.
NAME
SIZE
DESIGN (PRESS. @ Min/Max TEMP.)
OPER.
DUTY

A-9201
WELLSTREAM GAS COMPRESSOR PACKAGE
150NB SUCTION / 80NB DISCHARGE
0.5 & 10 Sfm/D, 90.3 BARG @ 0.2 / 149&C
30.0 TO 83.0 BARG LIFT
N/A

E-9231
COOLER

F-9276
ENGINE AIR INTAKE

K-9206A
COMPRESSOR BUILDING EXHAUST FANS PACKAGE
N/A



NNF hence not included

33(2)

31

32

- NOTES:
- Ø DENOTES "VENDOR COUPLING"
 - DENOTES "LOW SELECT"
 - VALVE 50V26 ON PROCESS BLOWDOWN IS CERTIFIED TO -29&C.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CHKD	APPR.	CHD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHD	APPR.	CHD	APPR.	NUMBER	TITLE
BO	11/06	VB	EMR	KS21	APPROVED FOR CONSTRUCTION	PMM	AWE										
AB	08/05	VB	EMR	KS21	RE ISSUED AFC	JJA	AWE										
AS	24/12/04	CSM	EMR	KS21	APPROVED FOR CONSTRUCTION	WF	JJA										
D1	10/17	CSM	K1729	CLSP	APPR. FOR CONSTRUCTION	ML	GD										
D0	07/17	JMP	ECP	K1729	APPROVED FOR DESIGN	ML	GD										
E1	06/07	VB	ECP	K1216	APPROVED FOR DESIGN	CE	PM										
CG	04/07	VB	ECP	K1216	ISSUED FOR HAZOP	CC	PM										

DESIGNED: C. McINNIS DATE: 06/04
 DRAWN: G. ROBERTSON DATE: 06/04
 CHECKED: W. FLETCHER DATE: 06/04
 APPROVED: J. AIKEN DATE: 06/04
 APPROVED: N. BEALE DATE: 06/04
 SCALE: NONE
 STOCKFILE: NONE

KAPUNI WELLSITES
PIPING & INSTRUMENT DIAGRAM
GAS COMPRESSOR PACKAGE A-9201
WELLSITE KA-8, 12&15

1 of 10 SHEET NO. 06
 DRAWING NO. 941-10-00819

Todd Energy

27_KA18_10_SEPRTR_V

31_KA18_10_SS911_V

30_KA18_10_COOLER_V

35_KA18_10_COMPRSR_V

32_KA18_10_SS9101_V

08_KA08_06_COMGAS_V

34_KA18_10_BLWCSE_V

29_KA18_10_BLWCSE_L

Assume no liquid from the blowcase, section excluded.

BILL OF MATERIAL			
ITEM	QTY	EFF CODE	DESCRIPTION
10	1	NPNREQ	VALVE, CONTROL, 2" 600#RF, WCC, 2-155#F, FD, 6-30 PSI CW/LIMIT SWITCH 73-132A42 TOPHORNIS SAA (FISHER, 657-ET-43)
20	1	NPNREQ	VALVE, CONTROL, 2" 600#RF, WCC, 2-155#F, FC, 6-30 PSI CW/LIMIT SWITCH 73-132A42 TOPHORNIS SAA (FISHER, 657-ET-43)
30	1	NPNREQ	>>VALVE, CONTROL, 2" 600#RF, PP, LCC CW/BALL VALVE, TRUNDAIN NACE (TK, DF0208RLNCCVNB)
40	3	NPNREQ	>>VALVE, CONTROL, 2" 600#RF, PP, LCC CW/BALL VALVE, TRUNDAIN NACE (TK, DF0208RLNCCVNB)
60	2	NPNREQ	>>VALVE, CONTROL, 1" 600#RF, PP, LCC CW/BALL VALVE, FLOATING NACE (TK, FF0068RLNCCVNB)
70	1	NPNREQ	>>VALVE, CONTROL, 1" 600#RF, PP, WCC CW/BALL VALVE, FLOATING NACE (TK, FF0068RLNCCVNB)
71	1	NPNREQ	>>VALVE, CONTROL, 1" 600#RF, PP, WCC CW/BALL VALVE, FLOATING NACE (TK, FF0068RLNCCVNB)
80	1	NPNREQ	>>VALVE, CONTROL, 2" 600#RF, PP, LCC CW/BALL VALVE, FLOATING NACE (TK, FF0068RLNCCVNB)
100	1	103715	VALVE, CHECK, PETON, 3" 600#RF, CS, SS TRIM NACE (DANIEL, 305A)
104	3	112629	VALVE, SET GAUGE, SWEET, 1/2" FNPT X 3/4" MNPT, CS, 38159 (PENBERTHY, 333) 34T
108	1	117694	VALVE, NEEDLE, 1/4" MNPT X 1/4" FNPT, 316SS BODY (AGCO, HVDS-22)
109	2	104428	GAUGE, LEVEL, CS WITH REFLEX FLAT GLASS, 1800# (PENBERTHY, 181R)
110	1	116959	GAUGE, LEVEL, CS WITH REFLEX FLAT GLASS, 2000# (PENBERTHY, 201R)
118	7	118246	VALVE, NEEDLE, 3/4" MNPT X 1/2" FNPT, 316SS, NACE (AGCO, HVDS-46-SG)
140	1	122224	VALVE, PSV, 1" 600#RF X 2" 150#RF, 110" TP OR NACE (FARRIS, 26DA13-1200)
151	2	114010	VALVE, NEEDLE, 3/4" MNPT X 1/2" FNPT, 316SS, NACE (AGCO, HVDS-46-SG)
160	1	121265	VALVE, PSV, PILOT, 1-1/2" 600#RF X 3" 150#RF, 78S OR (FARRIS, 38RC13-1200)
170	1	121265	VALVE, PSV, PILOT, 1-1/2" 600#RF X 3" 150#RF, 78S OR (FARRIS, 38RC13-1200)
180	1	122476	VALVE, PSV, 3/4" 600#RF X 1" 150#RF, 110" OR NACE (FARRIS, 27DA23-1200)
200	2	120362	VALVE, CONTROL, 1" 600#RF, LCC, 1/4" OR, FC, NACE, 0-35 PSI (FISHER, DM)
220	3	119415	SWITCH, LEVEL, 3" 600#RF, 316SS, RP, ATX CW/SS FLOAT (BARNET, 175-200-212)
240	1	120672	REGULATOR, 1/4" NPT, ALUM, 0-150# TAPPED (WFO PSI) (FISHER, 6017R-6015PSC)
300	1	NPNREQ	CONTROLLER, LEVEL, 4" 600#RF, SAMP-ACTING, NACE CW/PCV DEPLACER (FISHER, L2) - Direct Swap Acting
300	1	120634	VALVE, CHECK, WAFER, 2" 600#RF DUAL, CS, NACE (TOPCON, AW-22149X-09)
300	2	NPNREQ	VALVE, GLOBE, 2" 600#RF, WOG, RP, NACE (CRANE, 28-364LLN1) SA105N BODY, API TRIM 12
340	1	NPNREQ	VALVE, GLOBE, 2" 600#RF, WOG, RP, NACE (CRANE, 18-364LLN1) SA105N BODY, API TRIM 12
360	2	107929	GAUGE, PRESSURE, BM, 4" LF, 0-400 PSI DUAL, 1/2" NPT (MKA, 233-54)
361	1	107890	GAUGE, PRESSURE, BM, 4" LF, 0-1500 PSI DUAL, 1/2" NPT (MKA, 233-54)
370	12	106375	FLANGE, RF RED HUB, 2" 600#RF 3/4" NPT SA105N
372	8	106407	FLANGE, RF RED HUB, 2" 600#RF 3/4" NPT SA105N
373	2	106204	FLANGE, RF BLIND, 1-1/2" 600#RF SA105N
374	5	106237	FLANGE, RF BLIND, 1" 600#RF SA105N
375	1	106231	FLANGE, RF BLIND, 1" 600#RF SA105N
376	2	109128	SPECTACLE BLIND, 4" 600#RF, SA161-70N, 1/4" THK
377	3	106262	FLANGE, RF BLIND, 2" 600#RF SA105N
378	1	106296	FLANGE, RF BLIND, 4" 600#RF SA105N
379	1	109125	SPECTACLE BLIND, 3" 600#RF, SA161-70N, 1/2" THK
380	1	118536	SPECTACLE BLIND, 1-1/2" 600#RF, SA161-70N, 1/4" THK
390	2	115414	MWELL, FLANGED, 316SS, 2" 600#RF, 1/2" FNPT, 267" BORE, TAPERED
400	2	103077	GAUGE, TEMP, 3" DIA, 1/2" STEM 0-250 DEG F DUAL, 1/2" NPT (TRENDA, 3009)
410	1	NPNREQ	T-COUPLE ASSY, CSA, XP CW 1-1/2" 600#RF TWELL, 316SS, (PYROMATION, #486-HF41SR0708-BN71-S1) K5-STYLE
430	2	104245	STRAINER, CONE, 4" 600#RF, 40 MESH, 150# FLOW AREA
440	1	NPNREQ	VALVE, BALL, 1" 600#RF, PP, LCC, NACE CW LOCKING HANDLE (TK, FF0068RLNCCVNB) - Floater type full port ball valve
462	2	105326	MORFICE PLATE, TYPE S20, 316SS, 1/8" THK, 4" 600#RF, 2" ID
470	4	105266	MORFICE PLATE, TYPE S20, 316SS, 1/8" THK, 3" 600#RF, 1.75" ID
472	4	105266	MORFICE PLATE, TYPE S20, 316SS, 1/8" THK, 3" 600#RF, 1.25" ID
490	2	107949	GAUGE, TEMP, 3" DIA, 1/2" STEM 0-250 DEG F DUAL, 1/2" NPT (TRENDA, 3009)
495	4	107959	GAUGE, TEMP, 3" DIA, 1/2" STEM 0-250 DEG F DUAL, 1/2" NPT (TRENDA, 3009)
500	6	115448	MWELL, FLANGED, 316SS, 1-1/2" 600#RF, 1/2" FNPT, 267" BORE, TAPERED
510	3	102949	VALVE, BALL, 1/2" NPT, 2000# WOG, RP, 316SS, NACE CW (MCKO, C1-0052-204)
520	11	NPNREQ	SWITCH, PRESSURE, DIFFERENTIAL, RANGE 30-300 PSID (710-2070 MPa), ICEX (E, L, J) 120V-38-480V-QT-14001
600	4	119589	MMP 1000 PSIG, MOUNTED ON INSTRUMENT RACK
700	7	102752	FTG, TUBE, 3/8" FTG, 255 DEG F, 316SS (SWAGelok, SS-67FA-255)

- NOTES:
- BLOWDOWN + VENT PIPING MATERIAL TO BE LOW TEMP.
 - FUSIBLE PLUGS OF FIRE LOOP.
 - ORIFICE PLATE TO BE REPLACE FOR APPLICATION.
 - VALVE CLOSED IN TWO STAGE OPERATION.
 - FOR CI IN SECTION BY PURCHASER.
 - FOR FUTURE TWICE FOR COOLER FD CONTROL.

SERIAL NUMBERS	
CHILLER	C 6000 114070
A1	C 6000 114070
A2	C 6000 114070
A3	C 6000 114070
A4	C 6000 114070
ENGINE	C 10740 40788-1A0
FRAME	C 10740 40788-1A0
INVERTER	C 10740 40788-1A0
INVERTER	C 10740 40788-1A0
COOLER	C 10740 40788-1A0

STOS DWG No.: 941-10-00819	W0100284	SHT No.: 2 of 10		
5	ECP K1379 AS BUILT TO SITE MARK UP- ASB 10178KW	09/10 J/C VBAPAI		
07	ECP K1729 AS BUILT TO SITE MARK UP ASB 118205KW	05/18 CSM J/MF/GD/KB		
06	ECP XX17172 AS BUILT TO SITE MARK UP ASB 17230KW	07/17 RR J/MPT/DGF		
REV	DESCRIPTION	DATE	DRAWN BY	CHECKED BY

EFX Compression

4700 47 Street SE Calgary AB Canada T2B 3R1 Canada Tel: +1 403 236 6800 Fax: +1 403 279 0367
www.eferflex.com

TITLE: PROCESS AND INSTRUMENTATION DIAGRAM
ARIEL J GE4, WALK, L5790 GL, AIR-X LTD 156 EF-112-24
1/2 STAGE COMPRESSOR PACKAGE


FOR: SHELL TODD OIL SERVICES
TAG NO: A-9201 (KA-815 WELL HEAD COMPRESSOR)

CONSULTANT: TRANSFIELD WORLEY NEW ZEALAND
P.O.: 506568

LSDTARANAKI NEW ZEALAND
JOB No.: 040725

DRWN BY: MEN	DESIGN BY: PLM	DATE: 04/10/20	DWG. No.:	OP #
DATE: 04/10/15	APPV BY: PLM	DATE:	PF-040725-50	50
SCALE: NTS				

© 2004 Enerflex Systems Ltd.
REPRODUCTION OF ANY PORTION OF THESE MATERIALS WITHOUT THE EXPRESS WRITTEN CONSENT OF ENERFLEX SYSTEMS LTD. IS STRICTLY PROHIBITED.
THESE MATERIALS SHALL NOT BE USED FOR ANY PURPOSE OTHER THAN THE REPAIR AND MAINTENANCE OF THE PRODUCTS TO WHICH THEY RELATE.



39_KA18_07_FLGSEP_V

BILL OF MATERIAL

ITEM	QTY	EFX CODE	DESCRIPTION
12	1	121317	VALVE, PSV, 1" 150#RF X 2" 150#RF, .110 OR, NACE I, [FARRIS, 26DA10-12000]
13	4	102950	VALVE, BALL, 1/4" NPT, 2000#WOG, RP, 316SS, NACE CW [NAVCO, C1-R025-20A]
14	1	107911	GAUGE, PRESSURE, BM 2-1/2" LF, 0-300 PSI DUAL, 1/4" NPT [WKA, 233.53]
15	2	102949	VALVE, BALL, 1/2" NPT, 2000#WOG, RP, 316SS, NACE CW [NAVCO, C1-R055-20A]
19	2	NPN-REQ	HOSE, BRAIDED STEEL, 2" 150#RF X 2" NPT X 18" LONG
21	5	117694	VALVE, NEEDLE, 1/4" MNPT X 1/4" FNPT, 316SS BODY [AGCO, H1VDS-22]
27	1	118300	VALVE, GAS, 3-WAY, 2" 150#RF, 316SS BODY, AUTOMATED [KOMOX, 034-FT-D-6-P1-A]
28	1	104804	VALVE, QUICK VENT, 1/4" X 3/8" NPT [WABCO, P52935-2]
40	1	100898	VALVE, BALL, 2" 150#RF, FP, CS, NACE CW HANDLE [TK, FF02F01RLNCCCTT]
41	1	118163	STRAINER, Y, 2" 150#RF, 285 PSIG MAWP, CS, 1/32" SS SCREEN [ALTA, NYF-150]
43	2	106364	FLANGE, RF RED HUB, 1" 150# X 1/2" NPT SA105N
60	1	122036	GAUGE, PRESSURE, DIFF., 3" DIAL, 0-30 PSID DUAL, BACK MT, 316SS [WKA, 700.04]
100	1	104467	MAGNETIC PICK-UP, 5/8"-18 THREAD X 2-1/2" LONG, CSA, IS [DYNALCO, M204]
101	1	NPN-REQ	JUNCTION BOX ASSEMBLY, FLAMEPROOF, RANGE 3000, Zone 1 EExd IIB T6 IP66 ATEX certified fitted with MK6/6 terminal block
250	1	NPN-REQ	>>VESSEL, FUEL GAS, 10-34" OD, 285 MAWP @ 100DEG.F, SWEET CW FG-36 ELEMENT, EFX DWG#V040724L
260	1	119414	SWITCH, LEVEL, 3" 150#RF, 316SS, XP, ATEX CW/SS FLOAT [MAGNETROL, T31-003A-212]
270	1	112629	VALVE, SET GAUGE, SWEET, 1/2" FNPT X 3/4" MNPT, CS, 3815# [PENBERTHY, 330] 3/4"
280	1	104433	GAUGE, LEVEL, CS WITH REFLEX FLAT GLASS, 2240# [PENBERTHY, 1RL1]
290	1	100247	VALVE, BALL, 2" 150#RF, RP, CS, NACE CW HANDLE [TK, FF02R01RLNCCCTT]
310	1	116009	VALVE, CHECK, SWING, 2" 150#RF, CS, NACE [NAVCO, CS-F20R015]

BILL OF MATERIAL: W040724-22A-AB: FUEL GAS SYSTEMS			
DATE-TIME EXPORTED: 2005-04-07-11:33			

NOTES:

1. INSTRUMENTS USING INSTRUMENT AIR MUST BE VENTED TO ATMOSPHERE.
2. ALL SERVICE LINES OPERATING ABOVE 15 PSIG MUST BE PRESSURE TESTED PER TI PROCEDURE IN THE QC MANUAL.
3. MANIFOLD BOOST PRESSURE TO BE SET ONCE SITE CONDITIONS ARE DETERMINED.
4. ALL TUBING IS 316SS CW SWAGelok FITTINGS.

STOS DWG. NO.:	941-10-00819	W0100287	SHT. NO.:	5 of 10
05	ECP X0213 AS BUILT TO SITE MARK UP ASB 15217KW	08/15	BB	JMP/AB/ATH
4	EWR K521 AS BUILT TO ASB 6052KW	04/06	DW	VB/AvE/ERP
3	FIELD AS BUILT, PER CUSTOMER COMMENTS	05/12/05	PLM	PLM
2	AS BUILT, PER CUSTOMER COMMENTS	05/07/01	PLM	PLM

REV	DESCRIPTION	DATE	DRAWN BY	CHECKED BY

EFX Compression

4700 47 Street SE Calgary AB Canada T2B 3R1 Canada Tel. +1.403.236.6800 Fax +1.403.279.0367
www.enerflex.com

TITLE: SERVICE FLOW FUEL GAS SYSTEMS WAUKESHA L5790GL


FOR: SHELL TODD OIL SERVICES LIMITED
TAG NO.: A-9201 (KA-8/15 WELL HEAD COMPRESSOR)

CONSULTANT: TRANS FIELD WORLEY NEW ZEALAND
P.O.: 504568

LSD: TARANAKI NEW ZEALAND
JOB No.: 040725

DRWN BY: MGN	DESIGN BY: PLM	DATE: 04/10/20	DWG. No: SF-040725-22	OP#: 22A
DATE: 04/10/20	CHKD BY: PLM	DATE: 04/10/26		
SCALE: NTS	APPVD BY: PLM	DATE:		

© 2004 Enerflex Systems Ltd
REPRODUCTION OF ANY PORTION OF THESE MATERIALS WITHOUT THE EXPRESS WRITTEN CONSENT OF ENERFLEX SYSTEMS LTD IS STRICTLY PROHIBITED. THESE MATERIALS SHALL NOT BE USED FOR ANY PURPOSE OTHER THAN THE REPAIR AND MAINTENANCE OF THE PRODUCTS TO WHICH THEY RELATE.



- NOTES:
1. FAL-9031A IS AN EVENT LOG ONLY. AT ZERO FLOW POWER IS DENIED TO E-9030.
 2. TIMED (30 MIN) OVERRIDE OF FAL-9031A TO ALLOW START-UP OF E-9030 PRIOR TO SUPPLYING FUEL GAS TO A-9101 & A-9201.
 3. TAL-9030A TO BE DISABLED WHEN "A-9029 USD" IS ACTIVE.
 4. OVER PRESSURE PROTECTION DEVICE CLOSING WHEN ITS SET POINT IS REACHED ISOLATING THE LINE PRESSURE FROM THE GAUGE.

NO	DATE	BY	CHKD	APPR	CHD	APPR	NO	DATE	BY	ECP	DESCRIPTION
A7	0905	VB	EMR-KS21-RE-ISSUED AFC	JA	AME						
A8	060505	VB	EMR-KS21-RE-ISSUED AFC	SD	JA						
A5	241204	CSM	EMR-KS21-APPROVED FOR CONSTRUCTION	WF	JA						
M	280904	SK	EMR-KS21-RE-ISSUED AFD	WF	JA						
A3	0904	VB	EMR-KS21-APPROVED FOR DESIGN	WF	JA						
B1	0218	CSM	K1729-CUSP-RE-APPR-FOR CONSTRUCTION	GD	SJG		03	0518	CSM	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB T18025KW
B0	1017	CSM	K1729-CUSP-APPR-FOR CONSTRUCTION	ML	GD		02	1208	MH	ECP	ECP K1282 AS BUILT TO SITE MARK UP ASB R214KK
							01	0406	DW	KS21	AS BUILT TO SITE MARK UP ASB 6052KW
							0	0604	TMA	KS21	FIRST ISSUE

DESIGNED	C. MCKINNON	DATE	06/04
DRAWN	T. ALLERTON	DATE	06/04
CHECKED	W. FLETCHER	DATE	06/04
APPROVED	J. AIKEN	DATE	06/04
APPROVED	N. BEALE	DATE	06/04
SCALE	NTS		

KAPUNI WELLSITES
PIPING & INSTRUMENTATION DIAGRAM
FUEL GAS CONDITIONING PACKAGE A-9029
WELLSITES KA-8, 12 & 15

STICKLE
Todd Energy

SHEET NO 1 OF 1 REVISION 03
 DRAWING NO 941-10-00820


This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

ITEM No.
NAME
SIZE
DESIGN (PRESS. @ Min/Max TEMP.)
OPER.
DUTY

V-9010
WELLSTREAM SEPARATOR (TWO PHASE)
1600mm ID x 4500mm T/T
94.42 Barg @ 0.2 / 85°C NOTE 9
30.0 Barg @ 40°C
N/A

P-9015
CONDENSATE TRANSFER PUMP
100 NB SUCTION x 40 NB DISCHARGE
94.42 Barg @ 0.2 / 85°C
21.0 m3/h @ 68.5m TDH
N/A

V-9015
CONDENSATE TRANSFER PUMP SEAL FLUID VESSEL
20 LITRE
94.42 Barg @ 0.2 / 85°C
N/A
N/A



HOLD
PROJECT 12339
13-Aug-20
1. INSTALLATION OF PUMP
MINIMUM FLOW RETURN LINE
TBC.

- NOTES:
- VOID.
 - VOID.
 - FM-9015A CORIOLIS TYPE FLOW METER C/W 100NB 900# SSRF FLANGES.
 - LCV-9015A SET POINT @ ZERO ON P-9015 SHUTDOWN. LCV-9015A SET POINT @ AUTO ON P-9015 START-UP. START-UP P-9015 AGAINST CLOSED LCV-9015A & RAMPS CONTROLLER OUTPUT TO LIMIT SPEED OF LCV-9015A OPENING.
 - SPOOL FOR FUTURE CONDENSATE TRANSFER PUMP IN SERIES WITH P-9015.
 - VOID.
 - RO-9015A 20 NB SCRUD RESTRICTION ORIFICE SUPPLIED BY P-9015 VENDOR.
 - TO MANUALLY DUMP SEPARATOR VESSEL CONTENTS MOVE CONTROL ON RCU-9015A FROM 'AUTO' TO 'START' AND HOLD UNTIL PUMP STARTS.
 - VENT GLOBE VALVE DESIGN CONDITIONS ARE 87.6 BARG @ 85°C AND 94.4 BARG @ 57°C.
 - ZAC-9015B ALARMS/TRIPS WHEN PUMP IS RUNNING & LCV-9015A OUT PUT IS <5%.
 - VOID.
 - TUNDISH TO BE AT HIGH POINT WITH DRAIN TO SUMP OF CONCRETE BUND.
 - VOID.
 - LEVEL DISCREPANCY ALARM.
 - SWITCHING MODE, NORMAL OPERATION: P-9015 IS NOT RUNNING, LEVEL CONTROL VIA LCV-9015A.

PROJECT MASTER

21 SEP 2020

CONSTRUCTION NOTES:
C1. EXISTING SP-0794, 25V128 & SDV-9015C RETAINED AND RE-USED.
C2. EXISTING 100V632 RETAINED AND RE-USED.
C3. EXISTING TW-9015A, TIT-9015A, PIT-9015B & 25V524 RETAINED AND RE-USED.

V-9010 / P-9015
DEDICATED CONCRETE BUND

Material is mainly water, not flammable - not included.
PCR_3_2020_81 (12339)

NO	DATE	BY	CONSTRUCTION ISSUE	CONSULTANT	TOCO	NO	DATE	BY	REVISION	DESCRIPTION	CONSULTANT	TOCO	NO	DATE	BY	REVISION	DESCRIPTION
F3	05/20	ES	ISSUED FOR DESIGN FOR 2020_81 (12339)	PLP	PLP	07	05/15	ES	ECP	ECP X0213 AS BUILT TO SITE MASK L P ASB 155250W	JAP	AB	ATH				
F2	05/20	YC	RE ISSUED FOR HAZOP - FOR XXXX (12339)	PLP	PLP	06	05/14	YR	ECP	ECP X1559 AS BUILT TO SITE MASK L P ASB 142350W	JAP	AB	ATH				
F1	12/19	AD	ISSUED FOR HAZOP - FOR XXXX (12339)	PLP	PLP	12	05/13	SH	ECP	ECP X1802 AS BUILT TO SITE MASK L P ASB 115025AK	JAP	SO	AW				
F0	11/19	EBT	ISSUED FOR DESIGN REVIEW - FOR XXXX (12339)	PLP	PLP	09	05/16	EB	ECP	ECP X1729 AS BUILT TO SITE MASK L P ASB 118025W	JAP	GD	AB				
						10	05/16	EA	ECP	ECP X16003 AS BUILT TO SITE MASK L P ASB 163250W	JAP	AB	SF	111-10-825	CHEMICAL ELECTRIC		
						09	03/16	JAR	ECP	ECP X116002 AS BUILT TO SITE MASK L P ASB 163250W	JAP	AB	ATH	111-10-825	FLUID FLUX		
						08	01/16	BB	ECP	ECP X0213 AS BUILT TO SITE MASK L P ASB 155350W	JAP	AB	ATH	111-10-824	STORMWATER SYSTEM		
						07	05/15	EB	ECP	ECP X0213 AS BUILT TO SITE MASK L P ASB 155350W	JAP	AB	ATH				

ITEM No.
NAME
SIZE
DESIGN (PRESS. @ Min/Max TEMP.)
OPER.
DUTY

V-9020
WELLSTREAM SEPARATOR (TWO PHASE)
1600mm ID x 4500mm T/T
94.42 Barg @ 0.2 / 85°C NOTE 9
30.0 Barg @ 40°C
N/A

P-9025
CONDENSATE TRANSFER PUMP
100 NB SUCTION x 40 NB DISCHARGE
94.42 Barg @ 0.2 / 85°C
21.0 m3/h @ 68.5m TDH
N/A

V-9025
CONDENSATE TRANSFER PUMP SEAL FLUID VESSEL
20 LITRE
94.42 Barg @ 0.2 / 85°C
N/A
N/A

- 941-10-819/1 USD SIGNAL FROM A-9201 USD
- 941-10-801/1 ESD SIGNAL FROM WELLSITE ESD
- 941-10-00819/1 USD SIGNAL TO A-9201 USD
- 941-10-00801/1 SIGNAL TO XSV-2820
- 941-10-00801/3 SIGNAL TO XSV-2820A

HOLD PROJECT 12339
13-Aug-20
1. INSTALLATION OF PUMP MINIMUM FLOW RETURN LINE TBC.

08_KA08_06_COMGAS_V

- FROM COMPRESSOR A-9101 DISCHARGE 100HG-6-28036
- COMPRESSED GAS TO LTS INLET MANIFOLD 100WG-6-9003
- COMPRESSED GAS TO LTS INLET MANIFOLD 150WF-6-9003

N/NF - not included

HYDROCARBON LIQUIDS FROM BLOWDOWN

- 29_KA18_10_BLCSE_L
- WELLSTREAM FLUID FROM KA-15 W-2840

FROM WET NETWORK VL SLUGCATCHER

- 07_KA18_05_SLGCAT_L
- WELLSTREAM FLUID FROM KA-8 W-2820

- TO / FROM V-9010

- WELLSTREAM FLUID TO LTS INLET MANIFOLD
- WELLSTREAM FLUID TO V-9010

02_KA08_02_FLWLNE_V

- TO STORMWATER SYSTEM

V-9020 / P-9025 DEDICATED CONCRETE BUND

1/2" SS TUBING

- CONSTRUCTION NOTES:**
- EXISTING SP-0794, 25V128 & SDV-9025C RETAINED AND RE-USED.
 - EXISTING 100V632 RETAINED AND RE-USED.
 - EXISTING TW-9025A, TIT-9025A & PIT-9025B & 25V524 RETAINED AND RE-USED.

27_KA18_10_SEPRTR_V

28_KA18_10_SEPRTR_L

Material is mainly water, not flammable - not included.

30

33_KA18_10_PUMPBP_L

16_KA18_08_LPIG64_L

NEW WORK SHOWN
PCR_3_2020_81 (12339)


- NOTES:**
- VOID.
 - VOID.
 - FM-9025A CORIOLIS TYPE FLOW METER C/W 100NB 900# SS RF FLANGES.
 - LCV-9025A SET POINT @ ZERO ON P-9025 SHUTDOWN. LCV-9025A SET POINT @ AUTO ON P-9025 START-UP. START-UP P-9025 AGAINST CLOSED LCV-9025A & RAMPS CONTROLLER OUTPUT TO LIMIT SPEED OF LCV-9025A OPENING.
 - SPOOL FOR FUTURE CONDENSATE TRANSFER PUMP IN SERIES WITH P-9025.
 - VOID.
 - RO-9025A 20 NB SCRD RESTRICTION ORIFICE SUPPLIED BY P-9025 VENDOR.
 - TO MANUALLY DUMP SEPARATOR VESSEL CONTENTS MOVE CONTROL ON RCU-9025A FROM "AUTO" TO "START" AND HOLD UNTIL PUMP STARTS.
 - VENT GLOBE VALVE DESIGN CONDITIONS ARE 87.6 BARG @ 85°C AND 94.4 BARG @ 57°C.
 - ZAC-9025B ALARMS/TRIPS WHEN PUMP IS RUNNING & LCV-9015A OUT PUT IS <5%.
 - VOID.
 - TUNDISH TO BE AT HIGH POINT WITH DRAIN TO SUMP OF CONCRETE BUND.
 - VOID.
 - LEVEL DISCREPANCY ALARM.
 - SWITCHING MODE, NORMAL OPERATION: P-9025 IS NOT RUNNING; LEVEL CONTROL VIA LCV-9025A.

PROJECT MASTER

Material is mainly water, not flammable - not included.

NO	DATE	BY	CONSTRUCTION ISSUE	CONSULTANT	TCCO	NO	DATE	BY	REVISIONS	DESCRIPTION	CONSULTANT	TCCO	NO	DATE	BY	REFERENCE DRAWING	TITLE
F3	09/20	EB	ISSUED FOR DESIGN FOR PCR_3_2020_81 (12339)	GRP	TS	ZA	11	08/19	SH	ECP	ECP	0213	AS BUILT TO SITE MARK UP ASB 11250HW	JYP	AB	ATH	
F2	05/20	YC	RE ISSUED FOR HAZOP FOR PCR_3_2020_81 (12339)	GRP	TS				IR	ECP	ECP	K150	AS BUILT TO SITE MARK UP ASB 14250HW	JYP	AB	ATH	
F1	10/19	AD	ISSUED FOR HAZOP FOR PCR_3_2020_81 (12339)	CSM	JAT				CSM	ECP	ECP	K172	AS BUILT TO SITE MARK UP ASB 11025HW	JYP	CD	BY	911-10-825
F0	10/19	EBT	ISSUED FOR DESIGN REVIEW FOR PCR_3_2020_81 (12339)	CSM	TS				EB	ECP	ECP	X1502	AS BUILT TO SITE MARK UP ASB 10350HW	JYP	AB	SF	911-10-825
									IR	ECP	ECP	X1502	AS BUILT TO SITE MARK UP ASB 10350HW	JYP	AB	ATH	911-10-874
									AFR	ECP	ECP	X1502	AS BUILT TO SITE MARK UP ASB 10350HW	CHD	AFR	CHD	AFR

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY



Material is mainly water, not flammable - not included.

Material is mainly water, not flammable - not included.

PROJECT MASTER

21 SEP 2020

ESD DAY CONSTRUCTION SHOWN IN RED CLOUDS

NEW WORK SHOWN PCR_3_2 (Material is mainly water, not flammable - not included.)


NEW WORK SHOWN PROJECT (11730)

- NOTES:**
- START-UP BYPASS TO ALLOW PRESSURE EQUALISATION ACROSS MAIN LINE SDV.
 - VOID.
 - CONNECTION FOR M60H INJECTION IF REQUIRED.
 - VALVE TO BE RAMPED CLOSED UNDER ESD / USD.
 - FUTURE REVERSE FLOW TO KAP-J WELLSITE.
 - LCV-2858A CONTROL DISABLED AND FORCED TO 0% WHEN IN PUMPING MODE. LIC-2858A TO CONTROL PUMPS P-28201 / 28202.
 - PUMP CONTROL DISABLED AND STOPPED WHEN PUMPS P-28201 / 28202 IN BYPASS MODE OR WHEN LCV-2858A IS IN CONTROL MODE.
 - VALVE LOCKED OPEN TO PROVIDE PATH FOR SLUG CATCHER PUMPS RELIEF VALVES DISCHARGE.
 - TIE-IN FOR FUTURE LIQUID RECIRCULATION AND HEATING FOR ASPHALTENE EMULSION CONTROL.
 - PUMP P-28201/P-28202 CAN BE STARTED IF SDV-28201 AND SDV-2858B IN OPEN POSITION.
 - DISSIMILAR CHECK VALVES.
 - VALVE TO BE RAMPED CLOSED UNDER PAHH-2858A.
 - CONNECTION FOR FUTURE DEMULSIFIER INJECTION QUILL.

- CONSTRUCTION NOTES:**
- EXISTING TW-2858A, TE-2858A & TIT-2858A TO BE RE-USED.
 - EXISTING 25V254 TO BE RE-USED.
 - EXISTING SDV-2858B TO BE RE-USED.
 - EXISTING 100V632 TO BE RE-USED.
 - DN80 RELIEF LINE ON TOP ENTRY TO DN100 WELLSITE FLUID LINE FROM KA-18. VALVE WILL BE CLOSED POST ESD WORK HOWEVER IS SHOWN LO WHEN PUMP RELIEF IS TIED IN.

PROJ. NO.	NO.	DATE	DESCRIPTION	BY	CHKD.	APPR.	NO.	DATE	DESCRIPTION	BY	CHKD.	APPR.
12339	0920	09	ISSUED FOR DESIG FOR P-2820, 81 (12339)	GP	JT	AF	01	0918	ISSUED FOR DESIG FOR P-2820, 81 (12339)	GP	JT	AF
	0920	09	ISSUED FOR HAZOP - PCR_XXXX (12339)	GP	JT	AF	01	0918	ISSUED FOR HAZOP - PCR_XXXX (12339)	GP	JT	AF
	1219	08	ISSUED FOR HAZOP - PCR_XXXX (12339)	CSU	JT	AF	01	0815	ISSUED FOR HAZOP - PCR_XXXX (12339)	CSU	JT	AF
	1109	08	ISSUED FOR DESIG REVIEW - XXXX (12339)	CSU	JT	AF	01	0815	ISSUED FOR DESIG REVIEW - XXXX (12339)	CSU	JT	AF
	1109	08	APPROVED FOR CONSTRUCTION - K106 (11730)	CSU	JT	AF	01	0815	APPROVED FOR CONSTRUCTION - K106 (11730)	CSU	JT	AF
	0519	05	ISSUED FOR DESIG - K105 (11730)	GP	JT	AF	01	0518	ISSUED FOR DESIG - K105 (11730)	GP	JT	AF
	0719	07	ISSUED FOR DESIG - K106 (11730)	GP	JT	AF	01	0715	ISSUED FOR DESIG - K106 (11730)	GP	JT	AF
	0719	07	ISSUED FOR DESIG - K106 (11730)	GP	JT	AF	01	0715	ISSUED FOR DESIG - K106 (11730)	GP	JT	AF
	0719	07	ISSUED FOR DESIG - K106 (11730)	GP	JT	AF	01	0715	ISSUED FOR DESIG - K106 (11730)	GP	JT	AF
	0719	07	ISSUED FOR DESIG - K106 (11730)	GP	JT	AF	01	0715	ISSUED FOR DESIG - K106 (11730)	GP	JT	AF

DESIGNED: J. POTROZ
 DATE: 08/16
 DRAWN: J. POTROZ
 CHECKED: J. POTROZ
 APPROVED: J. POTROZ
 SCALE: AS SHOWN
 SHEET No. 1 of 1
 REVISION: C3
 TITLE: PIPING & INSTRUMENT DIAGRAM SLUG CATCHER WELLSITE KA-8, 12 & 15
 SHEET No. 941-10-00829(X)
 1 of 1
 REVISION: C3
 01




ITEM No
NAME
SIZE
DESIGN
OPER
DUTY

P-28201 / 28202
SLUG CATCHER PUMPS
DN XXX SUCTION / DN XXX DISCHARGE
21.1m³/h @ 17 bar DIFFERENTIAL
XXkW (TBC)
HOLD 11

V-28201 / 28X202
PUMP SEAL OIL ACCUMULATOR
XXmm OD x XXmm OVERALL: XX LITRE
XX barg @ XX°C

E-28201 / 28202
PUMP SEAL OIL COOLER
XX barg @ XX°C



06_KA18_05_SLCAT_V

49_KA18_05_SLCAT_L

54_KA18_05_SCPUMP_L

HOLD
PROJECT 12339
16-Sep-20

1. INSTRUMENT-TAG-NUMBERS
2. LINE-NUMBERS
3. TUBING SIZES TBC
4. PUMP FLANGE SIZE TBC
5. CONFIGURATION TBC
6. PSV SIZE & SET-PRESS. TBC
7. PSV-OUTLET-LINE-SIZE-TBC
8. CORIOLIS-SS-FLANGE-RATING CL-900-TBC
9. SDV-REQUIREMENT-TBC
10. PUMP-CAPACITY-TBC
11. PUMP-INSTALLED-MOTOR POWER TBC

PROJECT MASTER
21 SEP 2020

CONSTRUCTION NOTES:
C1. ALLOW MIN. 2m LONG TO ALLOW PUMP STATOR REMOVAL


ALL NEW WORK
PCR_3_2020_81 (12339)

- NOTES:
1. DROP OUT SPOOL FOR PUMP STATOR REMOVAL.
 2. PUMP P-28201 / P-28202 CAN ONLY BE STARTED IF SDV-28201 AND SDV-2858B ARE IN OPEN POSITION.
 3. HEAT TRACED AND INSULATED 2SE.

REV	DATE	BY	DESCRIPTION	CHKD	APPR	CHKD	APPR	DATE	BY	ECP	REVISIONS	CONSULTANT	TOOO	DATE	BY	ECP	REFERENCE DRAWINGS	SCALE	STOCK FILE	DESIGNED	DATE	KAPUNI WELLSITES
A3	09/20	CB	ISSUED FOR DESIGN FOR L2020_A1 (12339)	GFP	IS	2A	1B													B. BERGER	11/19	PIPING & INSTRUMENT DIAGRAM
A2	02/20	YC	REVISION FOR HAZOP - PCR_XXXX (12339)	GFP	IS	-	-													C.B. MURPHY	11/19	SLUG CATCHER PUMPS P-28201 & P-28202
A1	12/19	ASB	ISSUED FOR HAZOP - PCR_XXXX (12339)	CSM	JVI	-	-													H. SANGUEZA	11/19	WELLSITE KA-8,12, 15 & 18
A0	11/19	EDT	ISSUED FOR DESIGN REVIEW - PCR_XXXX (12339)	CSM	IS	-	-	00	11/19	EDT										M.C. WENG	11/19	
				CHD	APPR	CHD	APPR															

ITEM No.
NAME
SIZE
DESIGN
OPER. BAR(G) @ cC
DUTY

V-2808
LOWTEMPERATURE SEPARATOR NOTE A
1830mm ID x 5640mm TANTAN
TUBE 238 @ 100cC
SHELL 69 @ 0/cC TO 85cC



This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.


NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	NO	DATE	BY	ECP	NUMBER	TITLE	
A4	02/18	CSM	K1729 EUSP RE-APPR FOR CONSTRUCTION	GD	SJG														
A3	10/17	CSM	K1729 EUSP RE-APPR FOR CONSTRUCTION	ML	GD														
A2	07/17	NR	ECP-K1729 APPROVED FOR DESIGN	ML	GD														
A1	09/16	JMP	EUSP PROJECT ISSUED FOR HAZOP	SG	ML		01	05/18	CSM	ECP									
AG	08/16	AMC	EUSP PROJECT ISSUED FOR REVIEW	ML	SG		00	09/16	JMP										

DESIGNED	DATE	KAPUNI WELLSITES	
DRAWN J.POTROZ	09/16	PIPING & INSTRUMENT DIAGRAM	
CHECKED		LTS UNIT	
APPROVED		KA-8, 12 & 15	
SCALE	NTS	SHEET No	1 of 3
STICKLE		REVISION	01

Todd Energy

DRAWING No: 941-10-00830

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY




This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	REVISIONS	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
M	02/18	CSM	K1729 CLSP RE-APPR FOR CONSTRUCTION	GD	SJG		SF												
A3	10/17	CSM	K1729 CLSP RE-APPR FOR CONSTRUCTION	ML	GD		SF												
A3	07/17	NR	ECP K1729 APPROVED FOR DESIGN	ML	GD		SF												
A1	10/16	JMP	CLSP PROJECT ISSUED FOR HAZOP	SG	ML			01	05/18	CSM	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB118025KW	JMP	GD		KB			
AG	09/16	JMP	CLSP PROJECT ISSUED FOR HAZOP	NS	ML			00	09/16	JMP		FIRST ISSUE							

DESIGNED	DATE	KAPUNI WELLSITES	
DRAWN J.POTROZ	09/16	PIPING & INSTRUMENT DIAGRAM	
CHECKED		LTS UNIT	
APPROVED		KA-8, 12 & 15	
SCALE	NTS	SHEET No	2 of 3
STICKFILE		REVISION	01
		DRAWING No	941-10-00830

ITEM No.
NAME
SIZE
DESIGN BAR(G) @ €
OPER.
DUTY

E-2816, E-2817, E-2818
GAS/GAS EXCHANGER
TUBE 238 @ 85°C (NOTE 1)
SHELL 69 @ -29/93°C



- NOTES
1. SECONDARY DESIGN CONDITIONS 248@-3/38°C.
2. REFER DWG 941-10-00806/1 FOR INJECTION SYSTEM

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or lent without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	REVISIONS	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
M	02/18	CSM	K1729 EUSP RE-APPR. FOR CONSTRUCTION	GD	SJG	SF													
A3	10/17	CSM	K1729 EUSP APPL. FOR CONSTRUCTION	ML	GD	SF													
A3	07/17	NR	ECP K1729 APPROVED FOR DESIGN	ML	GD	SF		02	08/19	BB			XK18002 AS BUILT TO SITE MARK UP ASB T19010KW	JMP	AB		MW		
A1	10/16	JMP	EUSP PROJECT ISSUED FOR HAZOP	SG	ML			01	05/18	CSM	ECP		ECP K1729 AS BUILT TO SITE MARK UP ASB T18029KW	JMP	GD		KB		
AG	09/16	JMP	EUSP PROJECT ISSUED FOR HAZOP	NS	ML			00	09/16	JMP			FIRST ISSUE						

DESIGNED	DATE	KAPUNI WELLSITES	
J. POTROZ	09/16	PIPING & INSTRUMENT DIAGRAM	
		UNIT B	
		KA-8, 12 & 15	
		SHEET No	REVISION
		3 of 3	02
		DRAWING No	
		941-10-00830	




Todd Energy

Appendix 7.
P&ID Sectionalisation for KA-13

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

W-21330 WELLHEAD KA-13 API-10000# SHUT IN THP 94 BARG/656C
 P-21346 WELLHEAD CELLAR PUMP
 P-21349 HYDRAULIC FLUID PUMP
 P-21348 HYDRAULIC FLUID PUMP
 T-21347 HYDRAULIC FLUID RESERVOIR 270d x 625L



- NOTES:**
- TIE-IN POINT FOR SECOND KA-13 FLOWLINE CROSSOVER
 - EROSION PROBE.
 - FLOWLINES & ALL CABLES & OTHER LINES FROM TO UNIT HAVE BEEN LOCATED IN A COVERED CONCRETE SELF-DRAINING TRENCH.
 - THIS LINE HAS BEEN DERATED FROM SPEC 50/50A TO SPEC 15. FLANGES REMAIN AT 5000#
 - 20 SECOND DELAY IN SV-21330 B1 (SUBSURFACE SAFETY VALVE) ON CLOSING. 20 SECOND DELAY ON SV-21330 A1 (FLOWLINE SAFETY VALVE) ON OPENING.
 - STARTUP OVERRIDE PB-21330C (TIMES OUT AFTER 30 MINUTES OR XS-21330C TO NORMAL POSITION) OVERRIDES THE FOLLOWING ESD SIGNALS; PALL-21330A, PALL-21310B, PALL-21310C.

- VALVES INDICATING SIZE ONLY ARE NOT GIVEN A V NUMBER AS THEY DO NOT CONFORM WITH SPEC 5.1
- HCV-21330A IS NOT SUITABLE FOR TEMPERATURES BELOW -29C WHICH MAY OCCUR ON LP OPERATING MODE STARTUP.
- PCV-21346B BACK PRESSURE REGULATOR TO SHUTDOWN P-21346 BELOW 6 BARG AIR PRESSURE.
- FLOWLINE CHOKES TO BE RAMPED CLOSED UNDER USD, ESD, KPS-ESD, OR ALL KPS INLET VAVES CLOSED.
- DRY BREAK CONNECTION LOCATED AT CHEMICAL INJECTION SKID.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CONSTRUCTION ISSUE	CHKD	APPR.	CHKD	APPR.	NO	DATE	BY	ECP	DESCRIPTION	CHKD	APPR.	CHKD	APPR.	NUMBER	TITLE
G2	01/17	JMP	ECP K1729 APPROVED FOR CONSTRUCTION	ML	NG	29	11/19	SH	ECP	ECP K18002 AS BUILT TO SITE MARK UP ASB T19013KW	JMP	SG		
G1	11/16	JMP	CUSP PRG - APPROVED FOR DESIGN	ML	NG	28	04/18	CSM	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB T18029KW	JMP	GD		
G0	08/16	JMP	CUSP PRG - ISSUED FOR HAZOP	TD	ML	27	01/18	LS	ECP	ECP KX17172 AS BUILT TO SITE MARK UP ASB T171202	JMP	TD		
FD	04/08	KN	5143066 ISSUED FOR REVIEW	ML	PWM	26	07/17	RR	ECP	ECP K1729 AS BUILT TO SITE MARK UP ASB T1724KW	JMP	TD		
E4	12/29	AGM	EWK H495 ISSUED FOR CONSTRUCTION	PM	AM	25	09/16	BB	ECP	ECP KX16002 AS BUILT TO SITE MARK UP ASB 16369KW	JMP	AB		
E0	09/29	JW	EWK H496 ISSUED FOR DESIGN	PM	AM	24	05/16	BB	ECP	ECP KX16002 AS BUILT TO SITE MARK UP ASB 16131KW	JMP	AB		
G3	04/17	NR	ECP K1544 APPROVED FOR CONSTRUCTION	GD	SG	23	04/13	JC	ECP	ECP K1544 ISSUED IN ERROR	JMP		
G3	04/17	NR	ECP K1544 APPROVED FOR CONSTRUCTION	GD	SG	22	04/13	JC	ECP	ECP K1544 AS BUILT TO SITE MARK UP ASB 13068KW	JMP	AC		

KAPUNI WELLSITES

PIPING & INSTRUMENT DIAGRAM
WELLHEAD
WELLSITE KA-13

DESIGNED: . DATE: 11-6-84
DRAWN: VG
CHECKED: J.C. TTS 25-6-84
APPROVED: PL 25-6-84
APPROVED: M. SHWER 25-6-84
SCALE: NONE
STICKFILE: .


SHEET No. 1 of 2 REVISION | 29
DRAWING No. 941-10-01301

Todd Energy

ITEM No.
NAME
SIZE
DESIGN
OPER.
DUTY

V-21310
HIGH PRESSURE KNOCKOUT
1068mmDD x 4572mm TAN/TAN
89.4 @ 85°C

02_KA13_02_FLWLNE_V



36


- NOTES:**
- VESSEL TO BE RATED TO -36°C @ 21 BARG. (MIN TEMPERATURE DURING START UP).
 - VALVE TO SWITCH BETWEEN WET GAS OPERATION AND MULTIPHASE OPERATION.
 - DUPLEX SPOOL OF 10D LENGTH TO ALLOW CI FILM FORMATION.
 - CONNECTIONS FOR WELLSTREAM COOLER (IF REQUIRED).
 - CONNECTIONS FOR PORTABLE WELL TESTING SEPARATOR.
 - MD-SELECT CONFIGURATION WITH SHARING OF SENSOR ELEMENT FOR PRE-ALARM (MULTI-PHASE MODE).
 - HIGH HIGH TRIP FUNCTION FOR KA-13 LIQUID LINE TO BE 2003 FROM PIT-21310C/D/E.
 - MAXIMUM ALLOWABLE OPERATING PRESSURE OF THE SYSTEM IS LIMITED TO 89.4 BARG @ 85°C BY THE LSHH/LSLL-21310A INSTRUMENTS.

This drawing is confidential and is the property of SHELL TODD OIL SERVICES LTD. It must not be disclosed to any third party or used without written consent from Shell Todd Oil Services Ltd.


NO	DATE	BY	CHKD	APPR	CHKD	APPR	NO	DATE	BY	DESCRIPTION	CHKD	APPR	CHKD	APPR	NUMBER	TITLE
A3	09/17	NR								ECP K1729 AS BUILT TO SITE MARK UP AS B 17248KW						
A2	01/17	JMP								ECP K1729 AS BUILT TO SITE MARK UP AS B 17248KW						
A1	11/16	JMP								ECP K1729 AS BUILT TO SITE MARK UP AS B 17248KW						
AD	06/16	JMP								ECP K1729 AS BUILT TO SITE MARK UP AS B 17248KW						

DESIGNED	DATE	KAPUNI WELLSITES	
DRAWN	06/16	PIPING & INSTRUMENT DIAGRAM	
CHECKED	06/16	HIGH PRESSURE KNOCK OUT	
APPROVED	06/16	KA-13	
SCALE	NONE		
SHEET No		1 of 1	REVISION
DRAWING No		941-10-01321	

SHELL TODD OIL SERVICES LIMITED
PRIVATE BAG NEW PLYMOUTH NEW ZEALAND



- NOTES:**
1. THIS FLANGE HAS BEEN DERATED FROM SPEC 5050A TO SPEC 15. FLANGES REMAIN AT 5000-#
 2. TIE-IN FOR PRODUCTION TESTING.
 3. PIPE CLAMP SENSOR.
 4. WIRELESS INSTRUMENT.
 5. ECP K1602 VALVES 150V34 & 150V55 REMOVED. AN ADDITIONAL SURGE DIVERTER INSTALLED ACROSS IF025. 6mm BONDING CABLE ATTACHED ACROSS IF032.
 6. TIT/TI-21321A/21310D TO INDICATE POTENTIAL OVER-TEMP OF PIPE COATING (50C) AND MINIMUM TEMPERATURE. TO BE LOCATED CLOSE TO PIPELINE..
 7. CAMLOCK ADAPTOR & DUST CAP VERTICAL LINE WITH NO BEND. BIOCID DOSING THROUGH CONNECTION.
 8. 600LB FLANGE IN SPEC 1 SERVICE.
 9. MID-SELECT CONFIGURATION WITH SHARING OF SENSOR ELEMENTS FOR PRE-ALARM (MULTI-PHASE MODE).
 10. HIGH HIGH TRIP FOR KA-13 LIQUID LINE TO BE 2003 VOTING FROM PIT-21310 C/D/E.
 11. PALL & PAHH-21310B & LALL-21310A TO BE DISABLED DURING MULTIPHASE OPERATION TO AVOID SPURIOUS TRIPS.
 12. PAHH-21310E FORCED TRIPPED WHEN NOT IN MULTIPHASE MODE.
 13. RE-PRESSURISATION VALVE.



This must be the closed valve (or the SDV) as there's no other valves upstream - check with Mike


NO	DATE	BY	CONSTRUCTION ISSUE	CONSULTANT	TODD	REVISIONS	DESCRIPTION	CONSULTANT	TODD	REFERENCE DRAWINGS
E2	01/7	JMP	ECP K1729 APPROVED FOR CONSTRUCTION	ML	NG	SF	23	09/15	NR	ECP K1602 AS BUILT TO SITE MARK UP ASB 15299KW
E4	11/6	JMP	EUSP PROJECT APPR. FOR DESIGN	ML	NG	SF	22	07/15	BB	ECP X0213 AS BUILT TO SITE MARK UP ASB 15254KW
E6	10/6	JMP	EUSP PROJECT ISSUED FOR HAZOP	TD	ML		21	12/14	JMP	ECP K1602 AS BUILT TO SITE MARK UP ASB 14228KW
D6	05/02	HCS	EMR K634 APPROVED FOR CONSTRUCTION	EMRM	AP	PAA	20	07/13	MH	ECP K1544 AS BUILT TO SITE MARK UP ASB 13134KW
C2	02/00	RJR	EMR K406 RE-ISSUED FOR CONSTRUCTION	PM	AM	TAF				
C1	12/99	AGM	EMR K406 RE-ISSUED FOR CONSTRUCTION	PM	AM	TAF	26	08/19	SH	ECP XK18002 AS BUILT TO SITE MARK UP ASB 119008KW
							25	07/17	RR	ECP K1729 AS BUILT TO SITE MARK UP ASB 17243KW
E3	04/17	NR	ECP K1729 RE-APPROVED FOR CONSTRUCTION	GD	SG	SF	24	09/16	BB	ECP XK16002 AS BUILT TO SITE MARK UP ASB 16369KW

DESIGNED	DATE	DRAWN	DATE	CHECKED	DATE	APPROVED	DATE
R WILSON	12-6-84	J C TTS	25-6-84	RB	25-6-84	M SHMER	25-6-84

NO	DATE	BY	CONSTRUCTION ISSUE	CONSULTANT	TODD	REVISIONS	DESCRIPTION	CONSULTANT	TODD	REFERENCE DRAWINGS

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

**KAPUNI WELLSITES
 PIPING & INSTRUMENT DIAGRAM
 GATHERING LINES
 WELLSITE KA-13**



- NOTES:**
- * VENDOR SUPPLY
 - 1. FLAME ARRESTORS REPLACED BY GAUZE.
 - 2. VOID.
 - 3. THIS LINE HAS BEEN DERATED FROM SPEC 50/50A TO SPEC 15. FLANGES REMAIN AT 5000#
 - 4. LG HAS A.S.V. (AUTOMATIC SAFETY VALVE) FITTED.
 - 5. TANK WITHIN CERTIFICATION.

This drawing is confidential and is the property of TODD ENERGY. It must not be disclosed to any third party or used without written consent from TODD ENERGY.

NO	DATE	BY	CHKD	APPR	CHKD	APPR	NO	DATE	BY	CHKD	APPR	DESCRIPTION
00	05/11	VB					23	02/12	MH	ECP		ECP K1353 AS BUILT TO SITE MARK UP ASB 12026KW
01	05/09	VB					22	01/11	KP	ECP		ECP K1379 AS BUILT TO SITE MARK UP ASB 10250KW
02	03/09	VB					21	06/10	BA	ECP		ECP K1379 AS BUILT TO SITE MARK UP ASB 10109KW
03	03/17	NR					20	03/10	BA	ECP		ECP K1249 AS BUILT TO SITE MARK UP ASB 10059KW
04	01/17	JMP					19	09/09	JMP	ECP		ECP K1249 AS BUILT TO SITE MARK UP ASB 9174KW
05	11/16	JMP					25	04/18	CSM	ECP		ECP K1729 AS BUILT TO SITE MARK UP ASB 118023KW
06	09/16	JMP					24	07/17	RR	ECP		ECP K1729 AS BUILT TO SITE MARK UP ASB 17243KW

DESIGNED	DATE	KAPUNI WELLSITES	
DRAWN	7-6-84	PIPING & INSTRUMENT DIAGRAM	
CHECKED	25-6-84	CHEMICAL INJECTION	
APPROVED	25-6-84	WELLSITE KA-13	
SCALE	25-6-84		
STICKLE			
TODD ENERGY		SHEET NO	1 OF 1
		REVISION	25
		DRAWING NO	941-10-01306

Appendix 8.

Full Wellsites Heat and Material Balance

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

	KA-02					KA-05		
Stream Number	1	2	3 <i>Note 1</i>	4	5	6	7	8
Name / Description	KA-02_Wellfluid_to_KA-02_Wellstream_Cooler	KA-02_Wellstream_Cooler_to_LTS_02	LTS-02_Liquid_to_Liquid_Manifold	LTS-02_Gas_to_E-020XA	E-020XA_to_Gas_Manifold	KA-05_Wellfluid_to_KA-05_Choke	KA-05_Choke_to_KA-05_KA-06/17_Combined	KA-05_KA-06/17_Combined
Mole Fraction								
WATER	0.2469	0.2469	0.8952	0.0004	0.0004	0.2072	0.2072	0.2858
CARBON DIOXIDE	0.3308	0.3308	0.0234	0.4476	0.4476	0.3632	0.3632	0.3163
METHANE	0.3311	0.3311	0.0052	0.4550	0.4550	0.3364	0.3364	0.2897
ETHANE	0.0398	0.0398	0.0041	0.0533	0.0533	0.0424	0.0424	0.0373
PROPANE	0.0197	0.0197	0.0065	0.0248	0.0248	0.0243	0.0243	0.0225
n-BUTANE	0.0101	0.0101	0.0081	0.0110	0.0110	0.0129	0.0129	0.0132
n-PENTANE	0.0027	0.0027	0.0046	0.0019	0.0019	0.0042	0.0042	0.0051
METHANOL	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
n-HEPTANE (C7)	0.0175	0.0175	0.0466	0.0059	0.0059	0.0066	0.0066	0.0210
n-DECANE (C10)	0.0015	0.0015	0.0053	0.0000	0.0000	0.0026	0.0026	0.0091
n-EICOSANE (C20)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
TOTAL	1.0001	1.0001	0.9990	0.9999	0.9999	0.9998	0.9998	1.0000

Note 1: Stream 3 is constituting of high water content (% water cut is >125%) hence is not considered as flammable.

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

	KA-6/17						
Stream Number	9	10	11	12	13	14	34
Name / Description	KA-06_Wellfluid_to_KA-06_KA-17_Combined	KA-06/17_Combined_to_E-2651	E-2651_to_V-2654	V-2654_Liquid_to_KA-05_KA-06/17_Combined	V-2654_Gas_to_Gas_Manifold	KA-17_Wellfluid_to_KA-06_KA-17_Combined	KA-05_KA-06/17_KA-13_Combined
Mole Fraction							
WATER	0.0218	0.0609	0.0609	0.7540	0.0016	0.1241	0.2168
CARBON DIOXIDE	0.4443	0.4370	0.4370	0.0370	0.4712	0.4253	0.3497
METHANE	0.4232	0.3949	0.3949	0.0112	0.4277	0.3491	0.3245
ETHANE	0.0529	0.0493	0.0493	0.0071	0.0529	0.0434	0.0414
PROPANE	0.0270	0.0253	0.0253	0.0119	0.0265	0.0225	0.0237
n-BUTANE	0.0125	0.0118	0.0118	0.0147	0.0115	0.0107	0.0130
n-PENTANE	0.0035	0.0033	0.0033	0.0106	0.0027	0.0029	0.0047
METHANOL	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
n-HEPTANE (C7)	0.0116	0.0137	0.0137	0.1066	0.0060	0.0174	0.0187
n-DECANE (C10)	0.0032	0.0037	0.0037	0.0469	0.0001	0.0046	0.0076
n-EICOSANE (C20)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
TOTAL	1.0000	0.9999	0.9999	1.0000	1.0002	1.0000	1.0000

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

	KA-19					
	15	16	17	18	19	20
Name	KA-19_Wellfluid_to_KA-19_Choke	KA-19_Choke-to_E-2153	E-2153_to_V-2154	V-2154_Liquid_to_Liquid_Manifold	V-2154_Gas_to_Wet_Gas_Network	Wet_Gas_Network_to_Wet_Gas_KA-18_Combined
Mole Fraction						
WATER	0.0338	0.0338	0.0338	0.6021	0.0016	0.0014
CARBON DIOXIDE	0.4380	0.4380	0.4380	0.0581	0.4596	0.4630
METHANE	0.4130	0.4130	0.4130	0.0188	0.4354	0.4352
ETHANE	0.0521	0.0521	0.0521	0.0122	0.0543	0.0535
PROPANE	0.0271	0.0271	0.0271	0.0205	0.0275	0.0265
n-BUTANE	0.0128	0.0128	0.0128	0.0254	0.0122	0.0117
n-PENTANE	0.0038	0.0038	0.0038	0.0193	0.0030	0.0027
METHANOL	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
n-HEPTANE (C7)	0.0144	0.0144	0.0144	0.1542	0.0065	0.0060
n-DECANE (C10)	0.0050	0.0050	0.0050	0.0892	0.0000	0.0000
n-EICOSANE (C20)	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000
TOTAL	1.0000	1.0000	1.0000	0.9999	1.0001	1.0000

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

	KA-8/18						
Stream Number	21	22	23	24 <i>Note 1</i>	25 <i>Note 1</i>	26 <i>Note 1</i>	27
Name / Description	KA-18_Wellfluid_to_KA-18_Choke	KA-18_Choke_to_Wet_Gas_KA-18_Combined	Wet_Gas_KA-18_Combined_to_V-2858	V-2858_Liquid_to_LCV-2858A	LCV-2858A_to_KA-8_KA-18_Liquid_Combined	KA-08_KA-18_Liquid_to_Liquid_Manifold	V-2858_Gas_to_KA-08_KA-18_Gas_Combined
Mole Fraction							
WATER	0.1798	0.1798	0.0421	0.9064	0.9064	0.8556	0.0015
CARBON DIOXIDE	0.3213	0.3213	0.4306	0.0150	0.0150	0.0267	0.4502
METHANE	0.3914	0.3914	0.4252	0.0039	0.0039	0.0083	0.4450
ETHANE	0.0455	0.0455	0.0517	0.0026	0.0026	0.0052	0.0540
PROPANE	0.0257	0.0257	0.0263	0.0045	0.0045	0.0087	0.0274
n-BUTANE	0.0131	0.0131	0.0120	0.0058	0.0058	0.0107	0.0123
n-PENTANE	0.0038	0.0038	0.0029	0.0043	0.0043	0.0075	0.0028
METHANOL	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
n-HEPTANE (C7)	0.0172	0.0172	0.0086	0.0461	0.0461	0.0615	0.0069
n-DECANE (C10)	0.0022	0.0022	0.0006	0.0116	0.0116	0.0155	0.0000
n-EICOSANE (C20)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
TOTAL	1.0000	1.0000	1.0000	1.0002	1.0002	0.9997	1.0001

Note 1: Streams 24, 25 and 26 are constituting of high water content (% water cut are >125%) hence are not considered as flammable.

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

KA-8/18							
Stream Number	28	29	30 <i>Note 1</i>	31	32	33	33(2)
Name / Description	KA-08_WellFluid_to_KA-08_KA-18_Gas_Combined	KA-08_KA-18_Gas_Combined_to_V-9010	V-9010_Liquid_to_KA-8_KA-18_Liquid_Combined	V-9010_Gas_to_A-9101	A-9101_to_LTS-8	LTS-8_Liquid_to_KA-8_KA-18_Liquid_Combined	LTS-8_Gas_to_Dry_Gas_Pipeline
Mole Fraction							
WATER	0.1279	0.0234	0.8768	0.0016	0.0016	0.2281	0.0006
CARBON DIOXIDE	0.3445	0.4318	0.0185	0.4425	0.4425	0.1913	0.4435
METHANE	0.4171	0.4402	0.0055	0.4513	0.4513	0.0696	0.4528
ETHANE	0.0483	0.0530	0.0035	0.0543	0.0543	0.0422	0.0543
PROPANE	0.0275	0.0274	0.0061	0.0279	0.0279	0.0664	0.0278
n-BUTANE	0.0142	0.0126	0.0078	0.0127	0.0127	0.0767	0.0125
n-PENTANE	0.0041	0.0031	0.0059	0.0030	0.0030	0.0491	0.0028
METHANOL	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
n-HEPTANE (C7)	0.0129	0.0079	0.0534	0.0068	0.0068	0.2624	0.0057
n-DECANE (C10)	0.0034	0.0006	0.0225	0.0001	0.0001	0.0138	0.0000
n-EICOSANE (C20)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
TOTAL	0.9999	1.0000	1.0000	1.0002	1.0002	0.9996	1.0000

Note 1: Stream 30 is constituting of high water content (% water cut is >125%) hence is not considered as flammable.

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

KA-8/18							
Stream Number	35	36	37 ^{Note 1}	38 ^{Note 1}	39	40	41
Name / Description	E-2800_Tube_Side_to_LTS-8_Coils	LTS-8_Coils_Out_to_V-2803	V-2803_Liquid_to_LCV-2803A/B	LCV-2803A/B_to_V-2805	V-2803_Gas_to_E-2801/2_Tube_Side	E-2801/2_Tube_Side_to_PCV-2804A/E	PCV-2804A/E_to_E-2801/2_Gas_V-2805_Gas_Mix
Mole Fraction							
WATER	0.0016	0.0016	0.9925	0.9925	0.0016	0.0016	0.0016
CARBON DIOXIDE	0.4424	0.4424	0.0075	0.0075	0.4424	0.4424	0.4424
METHANE	0.4513	0.4513	0.0000	0.0000	0.4513	0.4513	0.4513
ETHANE	0.0543	0.0543	0.0000	0.0000	0.0543	0.0543	0.0543
PROPANE	0.0279	0.0279	0.0000	0.0000	0.0279	0.0279	0.0279
n-BUTANE	0.0127	0.0127	0.0000	0.0000	0.0127	0.0127	0.0127
n-PENTANE	0.0030	0.0030	0.0000	0.0000	0.0030	0.0030	0.0030
METHANOL	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
n-HEPTANE (C7)	0.0067	0.0067	0.0000	0.0000	0.0067	0.0067	0.0067
n-DECANE (C10)	0.0001	0.0001	0.0000	0.0000	0.0001	0.0001	0.0001
n-EICOSANE (C20)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
TOTAL	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000

Note 1: Streams 37 and 38 are constituting of water and carbon dioxide only hence are not flammable.

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

KA-8/18								
Stream Number	42	43	44 ^{Note 1}	45 ^{Note 1}	46	47	48	49
Name / Description	V-2805_Gas_to_E-2801/2_Gas_V-2805_Gas_Mix	E-2801/2_Gas_V-2805_Gas_Mix_to_LTS-8	V-2805_Liquid_to_LCV-2805	LCV-2805_to_V-2805_Liquid_LTS-8_Liquid_Mix	LTS-8_Liquid_to_LCV-2804A	LCV-2804A_to_V-2805_Liquid_LTS-8_Liquid_Mix	V-2805_Liquid_LTS-8_Liquid_Mix_to_E-2800_Shell_Side	LTS-8_Gas_to_E-2801/2_Shell_Side
Mole Fraction								
WATER	0.0020	0.0016	0.9925	0.9925	0.2333	0.2333	0.2333	0.0007
CARBON DIOXIDE	0.5632	0.4424	0.0075	0.0075	0.1922	0.1922	0.1922	0.4434
METHANE	0.4312	0.4513	0.0000	0.0000	0.0718	0.0718	0.0718	0.4528
ETHANE	0.0036	0.0543	0.0000	0.0000	0.0420	0.0420	0.0420	0.0543
PROPANE	0.0000	0.0279	0.0000	0.0000	0.0655	0.0655	0.0655	0.0278
n-BUTANE	0.0000	0.0127	0.0000	0.0000	0.0754	0.0754	0.0754	0.0125
n-PENTANE	0.0000	0.0030	0.0000	0.0000	0.0481	0.0481	0.0481	0.0028
METHANOL	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
n-HEPTANE (C7)	0.0000	0.0067	0.0000	0.0000	0.2576	0.2576	0.2576	0.0057
n-DECANE (C10)	0.0000	0.0001	0.0000	0.0000	0.0140	0.0140	0.0140	0.0000
n-EICOSANE (C20)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
TOTAL	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000

Note 1: Streams 44 and 45 are constituting of water and carbon dioxide only hence are not flammable.

KAPUNI WELLSITES
QUANTITATIVE RISK ASSESSMENT

Stream Number ^{Note 1}	KA-13		KA-4/14				
	35	36	37	38	39	40	41
Name / Description	KA-13_Wellfluid_to_KA-13_Choke	KA-13_Choke_to_Condensate_Pipeline	KA-4_Wellfluid_to_KA-4_Choke	KA-4_Choke_to_KA4/14_Combined	KA-4/14_Combined_to_Liquid_Manifold	KA-14_Wellfluid_to_KA-14_Choke	KA-14_Choke_to_KA-4/14_Combined
Mole Fraction							
WATER	0.0267	0.0267	0.0437	0.0437	0.0352	0.0299	0.0299
CARBON DIOXIDE	0.4414	0.4414	0.4224	0.4224	0.4278	0.4312	0.4312
METHANE	0.4204	0.4204	0.4102	0.4102	0.4158	0.4193	0.4193
ETHANE	0.0525	0.0525	0.0511	0.0511	0.0517	0.0521	0.0521
PROPANE	0.0269	0.0269	0.0290	0.0290	0.0292	0.0293	0.0293
n-BUTANE	0.0125	0.0125	0.0153	0.0153	0.0152	0.0151	0.0151
n-PENTANE	0.0036	0.0036	0.0048	0.0048	0.0046	0.0045	0.0045
METHANOL	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
n-HEPTANE (C7)	0.0123	0.0123	0.0196	0.0196	0.0174	0.0161	0.0161
n-DECANE (C10)	0.0036	0.0036	0.0038	0.0038	0.0031	0.0026	0.0026
n-EICOSANE (C20)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
TOTAL	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000

Note 1: Stream numbers of 35 to 41 are also available for KA-8/18 wellsite, this is due to additional streams were added to the initial HMB and hence created some repeats. However, the compositions are different for the same numbers at the different wellsites.

TODD ENERGY LTD

Kapuni Wellsites QRA Assumptions Register

610114-RPT-R0001
July 2022

Worley New Zealand Ltd
25 Gill Street, New Plymouth 4310
PO Box 705, New Plymouth 4340

Telephone +64-6-759 6300
Facsimile +64-6-759 6301
www.worley.com

Rev	Description	Originator	Reviewer	Worley Approver	Date	Client Approval	Date
A	Issued for Review/Comment	Y Lee	E Gloy	Y Lee	05/2020		
0	Approved for Use	Y Lee	L Ong	Y Lee	08/2020		
1	Re-Approved for Use	Y Lee	O Kilian	Y Lee	07/2022		

TABLE OF CONTENTS

1.	ABBREVIATIONS	1
2.	INTRODUCTION	2
2.1	Objective	2
2.2	Scope.....	2
2.3	Facility Description.....	4
3.	MODELLING INPUTS AND ASSUMPTIONS	8
3.1	Assessment Tool	8
3.2	Definition of Parts Count Sections	8
3.3	Failure Frequency Data and Hole Size Distributions	9
3.4	Blowout Events	12
3.5	Ignition Probabilities	13
3.6	Material Composition	14
3.7	Release Scenarios.....	14
3.8	Congested Area.....	15
3.9	Atmospheric Conditions for Modelling	15
3.10	Fatality Criteria.....	17
3.11	Risk Criteria	20
4.	REFERENCES	22

1. ABBREVIATIONS

API	American Petroleum Institute
AWS	Automatic Weather Station
BLEVE	Boiling Liquid Expanding Vapour Explosion
BOP	Blowout Preventer
DNV GL	Det Norske Veritas Germanischer Lloyd
EI	Energy Institute
ESDV	Emergency Shutdown Valve
FBR	Full Bore Rupture
GOR	Gas Oil Ratio
HCRD	Hydrocarbon Release Database
HIPAP4	NSW Hazardous Industry Planning Advisory Paper No. 4
HMB	Heat and Material Balance
HPKO	High Pressure Knock Out
IOGP	International Association of Oil and Gas Producers
IRPA	Individual Risk Per Annum
KPS	Kapuni Production Station
LFL	Lower Flammable Limit
LPG	Liquefied Petroleum Gas
LSIR	Location Specific Individual Risk
LTS	Low Temperature Separator
PFD	Process Flow Diagram
PFPP	Passive Fire Protection
P&ID	Piping & Instrumentation Diagram
PLL	Potential Loss of Life
QRA	Quantitative Risk Assessment
RADD	Risk Assessment Data Directory
STDC	South Taranaki District Council
UK HSE	United Kingdom Health and Safety Executive
VCE	Vapour Cloud Explosion
WSO	Water Shut-off

2. INTRODUCTION

This document sets out the assumptions to be used for the Todd Energy (Todd) Kapuni wellsites Quantitative Risk Assessment (QRA).

2.1 Objective

The objective of the QRA is to develop risk contours to meet the risk assessment requirements of the South Taranaki District Council (STDC) District Plan, Section 11: Hazardous Substances.

2.2 Scope

The scopes include:

- 1) Conduct risk assessment for seven (7) Kapuni wellsites with 17 wells; and
- 2) Update the existing KA-4/14 and KA-13 wellsites QRA [Ref. 1] and hence supersedes the results from the QRA.

The final report will be a combined QRA report for all nine (9) Kapuni wellsites with 20 wells.

Currently, seven (7) wellsites are producing, KA-3 is out of service and KA-9 is designed for water disposal only. The wellsite details are summarised in Table 2-1. Only producing wells will be considered in the QRA.

Table 2-1: Kapuni Wellsites

Wellsite	Number of wells	Producing	Scheduled for Abandonment ^{Note 1}	Suspended ^{Note 2}	Shut in ^{Note 3}	Observation / water ^{Note 4}	Notes
KA-1, KA-7, KA-19 and KA-20	4	1			1 (KA-7)	2 (KA-1 and KA-20)	
KA-2	1	1					
KA-3	1			1			
KA-4 and KA-14	2	2					KA-14 is only operating once (for 24 hours) every 10 days [Ref. 20].
KA-5 and KA-10	2	1				1 (KA-10)	
KA-6, KA-11 and KA-17	3	2		1 (KA-11)			
KA-8, KA-12, KA-15 and KA-18	4	2	1 (KA-12)		1 (KA-15)		
KA-9	2					2	A new well, KW03, is drilled in May 2021 for further water injection purposes.

Wellsite	Number of wells	Producing	Scheduled for Abandonment <small>Note 1</small>	Suspended <small>Note 2</small>	Shut in <small>Note 3</small>	Observation / water <small>Note 4</small>	Notes
KA-13	1	1					KA-13 is only operating in 1 out of every 3 months.
Total	20	10	1	2	2	5	

Notes:

1. Wells that are scheduled for abandonment are plugged with abandonment plans underway.
2. Suspended wells are plugged and major intervention is required to bring the well back to service.
3. Shut in wells are isolated but could be brought back into service. Note that KA-7 and KA-15 were considered as producing well in the Kapuni Safety Case [Ref. 2], however, the wells are currently shut-in and hence will not be included in the risk assessment [Ref. 3 and Ref. 4].
4. Water wells are for water injection only and will not be used for hydrocarbon / producing. Observation wells are only for monitoring reservoir conditions and informing development of reserves estimates. They are designed for instrumentation only and cannot inject or produce.

There is no plan to bring the non-producing wells back online in the future. In the unlikely event that this changes, the QRA will be updated to verify any impact on the risk contours. Engagement with STDC will be completed as part of this process and a new resource consent will be required.

2.2.1 Exclusions

The following will be excluded from the QRA scope:

- Risk from the gathering pipelines to Kapuni Production Station (KPS). The scope for each wellsite will include up to the pipeline isolation valves (if available) or when the pipelines go underground. Pipelines passing through the wellsites (e.g., at KA-4/14 and KA-5) are not considered in the base case. The pipeline sections will be assessed in the sensitivity case. Note that the pipeline (P/L) to PECPR on the P&ID will be used in some sections to identify the pipeline boundary;
- Risk other than hydrocarbon / process risk (e.g., transportation risk, seismic risk and volcanic risks);
- Decommissioned and/or mothballed equipment;
- Utilities such as produced water and instrument air as they do not contain any hydrocarbon inventory;
- Individual risk calculations, including Individual Risk Per Annum (IRPA) and Potential Loss of Life (PLL) as the wellsites are normally unmanned;
- Societal risk (F-N curve) as the wellsites are located as remote area with low populations;
- Corrosion Inhibitors present at the wellsites as they are not flammable;
- Methanol injecting pumps as they are only used during start-up (except for KA-8/12/15/18 wellsite where methanol dosing is required throughout the year). Note that methanol tanks are always full and connected to the methanol pumps, with the pumps turn off when methanol is not being injected [Ref. 19], hence the methanol tanks and tubing to the methanol pumps will be included.
- Toxic effect of carbon dioxide.

2.3 Facility Description

Kapuni is an onshore gas and condensate field located in South Taranaki, approximately 50 km south of New Plymouth. 20 Kapuni wells are located on nine (9) separate wellsites in the area surrounding the Kapuni Production Station (KPS). The production wellsite process is a simple separation of gas and liquids involving the direction of wellstream gas and liquids to a low temperature separator (LTS) unit on the wellsite. The LTS separates the gas and liquids by means of pressure reduction to cause cooling.

An aerial overview of the wellsites location with reference to KPS is shown in Figure 2-1.

The wellsites access are via vehicle gates which are normally adjacent to the main wellsite control huts for the wellsites. Each wellsite hut is a single storey building which contains the wellsite control logic systems, emergency and communications equipment.

The wellsites have an open layout with areas separated from each other to prevent knock-on effects. The open area reduces the potential for overpressure from an explosion and reduces fire damage / escalation potential.




Figure 2-1: Kapuni Wellsites Location with reference to Kapuni Production Station

The details of each of the wellsite is as below.

2.3.1 Wellsite KA-1, KA-7, KA-19 and KA-20

Located just off Palmer Road, the site contains 4 wells. A wellstream heater is fitted to the KA-19 well. KA-1 well is suspended, KA-7 is not operational following the recent unsuccessful Water Shut-off (WSO) [Ref. 3] and KA-20 well is an observation well.

This site also acts as a distribution point for gas from the northern wells. It re-routes gas arriving from the gathering lines from wellsite KA-4/14 and KA-8/12/15/18 to KPS.

2.3.2 Wellsite KA-2

Located on Palmer Road, the site has an LTS unit and the flowline is equipped with two wellstream coolers.

2.3.3 Wellsite KA-3

This wellsite has been suspended and plugged.

2.3.4 Wellsite KA-4 and KA-14

Located just off Palmer Road, the site contains two wells, two LTS units, and a wellstream heater.

2.3.5 Wellsite KA-5 and KA-10

Located just off Skeet Road, this site contains one producing well (KA-5) and one observation well (KA-10), with a Desander unit for solids separation, and a PCV used on start-up.

2.3.6 Wellsite KA-6, KA-11 and KA-17

Located on Ahipaipa Road, this site contains two in service wells, and one suspended well (KA-11). KA-6 and KA-17 wellstream fluids are co-mingled, routed through a wellstream cooler and then to an LTS Unit.

2.3.7 Wellsite KA-8, KA-12, KA-15 and KA-18

Located just off Eltham Road, this site contains two (2) producing wells. KA-12 well is plugged and scheduled for abandonment and KA-15 well is shut-in and isolated [Ref. 4]. Two wellstream process skids and two wellhead compression units are fitted to the wells.

2.3.8 Wellsite KA-13

Located just off Skeet Road, this site contains one well, Desander, a flowline choke valve and a High Pressure Knock Out (HPKO) vessel. It connects into the KA-6/5 gathering lines.

2.3.9 Wellsite KA-9

Located on Lower Duthie Road, two wells were drilled on the site, KA-9 (referred to as KW-2) and KA-16. KA-16 is suspended and KW-2 is currently in service as a water injection well. There is very little equipment left on the wellsite, only the water injection line, a filter, and two pig receivers.

The wellsites flow schematic is presented in Figure 2-2.




Figure 2-2: Kapuni Wellsites Flow Schematic

3. MODELLING INPUTS AND ASSUMPTIONS

This section outlines all modelling inputs and assumptions that will be used in the QRA. The assumptions and methodology will be consistent with those in the Todd Energy's Fire and Gas Analysis and Quantitative Risk Assessment Methodology Guideline [Ref. 5].

3.1 Assessment Tool

The risk assessment model will be set up using DNV GL Safeti version 8.22 [Ref. 6].

3.2 Definition of Parts Count Sections

3.2.1 Isolatable Inventory

Sectionalisation will be performed to segregate the facilities into a number of isolatable sections. Each potential leak source will be associated with a particular isolatable inventory. Primarily, the isolatable inventories will be defined by emergency shutdown valve (ESDV) boundaries. These sections will be split further where required, and the entire contained inventory was considered as available for release. Further segregations are based on:

- Significant change in operating parameters (temperature and pressure);
- Significant change in stream composition;
- Change in stream phase; and
- Equipment location.

The probability of successful detection and isolation is assumed to be 100%. At isolatable boundaries, the valve will be assumed as the last component of the upstream inventory. If a cap or blind flange is shown against a valve, it will be assumed to be closed, even if not indicated as such.

Node sections will be highlighted in the Process Flow Diagrams (PFDs) and will be detailed in a Node Definition table in the QRA report which presents details of all the nodes including unique identification code, definition of boundaries, operating temperature and pressure, maximum pipe diameter, etc.

Following sectionalisation, a parts counts will be conducted to perform the frequency analysis for the QRA.

3.2.2 Components

The definition of components within the parts count will be aligned with failure rate data published in the International Association of Oil and Gas Producers (IOGP) Risk Assessment Data Directory (RADD) Process Release Frequency [Ref. 7]. The parts count will consider the following:

- Equipment items;
- Valves;
- Flanges;
- Instrumentation and small-bore fittings; and
- Pipework.

The parts count will be recorded in an MS Excel spreadsheet, with each section broken down based on the piping and instrumentation diagrams (P&IDs). Marked up P&IDs will be attached with the QRA report.

3.3 Failure Frequency Data and Hole Size Distributions

3.3.1 General Leak Frequency

The leak frequencies for process equipment and piping will be taken from the IOGP Process Release Frequency [Ref. 7]. The release frequencies of the main process equipment items from IOGP are based on the UK HSE (UK Health and Safety Executive) hydrocarbon release database (HCRD) which has been compiled by the UK HSE over a 20-year period. Two sets of data are presented in IOGP Process Release Frequency, which include the 1992 – 2015 data and 2006 – 2015 data.

The recommended values based on experience in the period 2006 – 2015 (inclusive) will be used. The IOGP release notes state that the number of incidents recorded per year in the database has been steadily decreasing, and it is considered appropriate to base the frequency on more recent data on the assumption that this is more representative of what will occur in the future.

Failure frequency data from the HCRD contains detailed historical information on offshore hydrocarbon release incidents occurring in the UK offshore environment and is considered an industry standard for offshore QRA applications. The database categorises failure rates on a detailed basis of equipment type and size and provides a probabilistic hole size distribution associated with the failure.

The HCRD data are also normally used for QRA at onshore facilities, although the use of offshore failure rate may be considered to be conservative for use in most onshore applications, on the basis that:

- Offshore environments tend to be harsher, both external (saliferous environment) and internal (produced sand), increasing the rate of equipment corrosion and erosion;
- Congestion at offshore facilities increases the likelihood of damage through impact; and
- Restricted access to offshore facilities may limit maintenance campaigns, increasing the likelihood of failure.

Atmospheric Storage Tank

The IOGP Release Frequency Data does not provide the frequencies for atmospheric storage tanks. Therefore, the following leak frequencies as shown in Table 3-1 from the TNO Purple Book [Ref. 23] will be used for methanol tanks.

Table 3-1: Release Frequencies for Atmospheric Storage Tank

Type of Release	Storage Tanks, Atmospheric
Instantaneous release of the complete inventory	5.0E-06 per year
Continuous release of the complete inventory in 10 minutes at a constant rate	5.0E-06 per year
Continuous release from a hole with an effective diameter of 10 mm	1.0E-04 per year

3.3.2 Pigging

Pig traps are located at the wellsites to clean, condition and/or monitor the pipelines. The pigging frequency will be used to calculate a modification factor for the leak frequency from the pig receivers.

Table 3-2: Pigging Frequencies and Modification Factor [Ref. 19]

Tag	Description	To		Pigging Frequency (per year)	Average pigging duration (hours)	Modification Factor
<i>KA-06/17</i>						
A-2613	Hydrocarbon gas to gathering line	A-5001	KPS	4	1.5	0.001
A-2614	Hydrocarbon liquid to gathering line	A-5003	KPS	4	1.5	0.001
<i>KA-02</i>						
A-0101B	Hydrocarbon liquid to A-0501A (KPS)	A-0501A	KPS	2	8	0.002
A-0103	Hydrocarbon gas to A-0503 (KPS)	A-0503	KPS	4	1.5	0.001
<i>KA-08/18</i>						
A-2863	Wet gas from KA-4/14	A-2165	KA-19	4	1.5	0.001
A-2813	Dry gas to KA-4	A-0502D	KPS	2	1	0.0002
A-2814	Dry gas to KA-4	A-2440	KA-4/14	4	1.5	0.001
A-2864	Condensate to KA-1&7	A-0501B	KPS	4	7	0.003
<i>KA-4/14</i>						
A-2440	Dry gas to KA-7	A-2167	KA-19	1	1	0.0001
<i>KA-19</i>						
A-2165	Wet gas to KA-8/18 via KA-4/14	A-2863	KA-8/18	4	1	0.0005
A-2167	Dry gas from KA-4/14 wellsites	A-2440	KA-4/14	1	1	0.0001
A-2163	Wet gas from A-5002	A-5002	KPS	4	0.5	0.0002
A-2166	Dry gas to KPS A-502A	A-0502A	KPS	1	0.5	0.0001
A-2164	Vector Treated Gas from KPS A-5004	A-5004	KPS	1	0.5	0.0001
A-2169	(Hydrocarbon gas) To Kiwi Dairy Co. & Taranaki Byproducts Co.	N/A	Other	1	6	0.001

Note: No pig traps at KA-05 and KA-13.

3.3.3 Release Hole Sizes

For every component failure, there is a range of credible hole sizes ranging from pinhole leak to full bore rupture (FBR). The representative hole sizes to be used for process sites are as shown in Table 3-3.

The geometric mean for hole diameter will be used to represent a range in hole sizes as this approach has a mathematical basis that aligns with numbers that are exponential in nature, such as is the case for hole sizes where the consequence is dependent on the area of the hole size or square of the diameter. For example, the representative hole size for the range 10 – 50 mm is calculated as $(10 \times 50)^{0.5} = 22$ mm. The use of geometric mean is also aligned with the recommendation in the latest IOGP Process Release Frequency [Ref. 7].

Table 3-3: Hole Size Distribution

IOGP Hole Size Group (mm)	Representative Hole Size (mm)
1 - 3	2
3 - 10	6
10 - 50	22
50 - 150	85
> 150	Range geometric mean

22 mm will be used as the maximum hole size for small bore fittings as per the Todd Energy’s Methodology Guideline [Ref. 5].

The same approach will be taken to select the representative hole size for rupture cases (release > 150 mm). The selected hole size will be the geometric mean of 150 and the largest line size in the section. This is consistent with the approach used for other release size categories and may be appropriate given the limited FBR base data that is used by the algorithm to calculate frequency.

It is noted for methanol tanks that will reference to TNO Purple Book [Ref. 23] failure data, actual hole sizes following the failure data will be used as there are no sufficient leak size distribution data in Purple Book to calculate the geometric mean.

3.3.4 Leak Frequency Modification Factor

Several leak frequency modification factors will be applied to the release frequency database as per the Todd Energy’s Methodology Guideline [Ref. 5]. These are listed below:

- Piping Release Frequency
 - Pipework will be split into categories: process (on skid) piping and interskid piping as described in the definition for equipment type 1: steel process pipes of IOGP Process Release Frequencies [Ref. 7].
 - For interskid piping, the modification factor for “inter-unit piping” (section 3.3.3 of IOGP Process Release Frequencies) which is 0.9 will be applied, i.e. there will be a 90% reduction in frequencies.
- Rupture Release Frequency
 - A review of the UK HSE Hydrocarbon Release Database (HCRD) from 1992 to 2015 has been performed and it was determined that there were 31 incidents in the full-bore release category within 24 years. These were reviewed by Todd to determine the applicability of these cases in comparison with Todd Energy facilities. For wellsites, 22 of the incidents can be discounted on the basis that the release scenarios cannot occur on an onshore wellsite. The frequency for rupture release will be reduced by 65%.

The maximum flange release hole size will also be limited to 22 mm as a release from a flange is normally limited to a segment of a gasket between bolts [Ref. 5].

3.4 Blowout Events

For normal operations, it is assumed that a blowout may occur during either production, well workover or well wireline activities. The categories applied for classifying the incidents [Ref. 11 and 12] are shown in Table 3-4.

Table 3-4: Categories of Blowout Incidents

Main	Category	Description
Blowout and well release	Blowout (surface flow)	<ul style="list-style-type: none"> Uncontrolled incidents with surface flow, including subsea releases, e.g., from topside or subsea wellhead, drill floor or Christmas tree. Considered as a full blowout event from the full well bore size. This will be modelled based on the expected maximum well fluid flowrate that the reservoir can supply to the wellbore instead of the wellhead pressure to avoid over-estimating the release rate and creating unrealistic results.
	Blowout (underground flow)	<ul style="list-style-type: none"> Underground flow only or with limited surface flow where minor flow occurred and typically the Blowout Preventer (BOP) has been activated. Considered to have no consequences on the surface and will therefore not be considered in this study.
	Diverted well release	<ul style="list-style-type: none"> An incident where the diverter system functioned as intended. Assumed to be a well release that can be shut-in or diverted to flare in a short period of time. This event will not be included as the event frequency as given in Table 3-4 is equal to zero.
	Well release	<ul style="list-style-type: none"> An incident where hydrocarbons (oil or gas) flow from the well at some point where flow was not intended, and the flow was stopped by use of the barrier system that was available on the well at the time the incident started. Assumed to be release from the wellhead and Christmas trees. It will be modelled as a horizontal well fluid release at well pressures. Release sizes will be based on the same hole size distribution used for other release cases.

The blowout likelihood from the IOGP Blowout Frequencies [Ref. 11] will be used, specifically data for offshore operations in areas not operating according to North Sea Standard (Table 2-3 in the IOGP). It is noted that the Kapuni wellsites are located onshore, however, IOGP recommends the use of offshore data presented in Section 2 in the IOGP but noted that there will be a greater degree of uncertainty. The frequency for well wirelining considered in the KA-4/14 and KA-13 QRA [Ref. 1] is once per well per year, and no workover will be performed in the wells' life time. These assumptions will be used in this QRA as well.

Table 3-5: Blowout and Well Release Frequencies for Production Operation

Operation	Category	Frequency
Production (Excluding external causes ^{Note 1})	Blowout (surface flow)	3.3E-05 per well year
	Diverted well release	0 per well year
	Well release	2.9E-05 per well year
Wireline	Blowout (surface flow)	9.0E-06 per well year
	Diverted well release	0 per well year
	Well release	2.6E-05 per well year

Note 1: External causes are external loads such as storms or fire leading to blowout or well release.

3.5 Ignition Probabilities

The probability of ignition of a release is a function of the release rate, the nature of the material being released and the conditions of the surrounding plant. For this QRA, The Energy Institute (EI) ignition probability model referenced in IOGP Ignition Probabilities [Ref. 8] will be used for the estimation of overall ignition probability of loss of containment scenarios.

For wellsite, ignition probabilities should be taken from Scenarios 5 and 6 and they are assumed to particularly apply to a 'plant' where processing takes place. This is considered conservative for use at wellsites as not much processing takes place.

The scenarios are described as:

- Scenario 5 – Small Plant Gas LPG (Gas or LPG release from small onshore plant) - Releases of flammable gases, vapour or liquids significantly above their normal boiling point from small onshore plants (plant area up to 1200 m², site area up to 35,000 m²).
- Scenario 6 - Small Plant Liquid (Liquid release from small onshore plant) - Releases of flammable liquids that do not have any significant flash fraction (10% or less) if released from small onshore plants (plant area up to 1200 m², site area up to 35,000 m²) and which are not banded or otherwise contained.

The graphs of ignition probabilities as a function of mass release rate are shown in Figure 3-1.




Figure 3-1: Ignition Probability

Early and Delayed Ignition Probabilities

The graph represents the total ignition probability. An overall distribution for early to delayed ignition ratio of 30:70 to 50:50 split is considered reasonable. The timing of ignition is used as a means to predict the nature of the ignited event. Early ignition is taken to indicate a jet fire or pool fire depending on the material released. Delayed ignition is taken to indicate that the ignition would initially result in a flash fire or explosion.

For this study, a 30:70 split for early to delayed ignition probability will be used. Given the maturity of the hazardous area for all wellsites, it can be assumed that probability of early ignition would be low.

3.6 Material Composition

The Heat and Material Balances (HMBs) will be provided by Todd Energy's process engineer [Ref. 9]. The wellstream fluid from each well have different flowrates, material compositions and operating conditions. Any stream that has unique consequences will be represented by dedicated sections. For sections with similar operating conditions or fluid composition that have similar consequence results, the worst-case scenario will be selected as representative, to rationalise the number of scenarios performed. This is to avoid the averaging out of inputs of different wellstreams, as it may create a stream with 'brand new' operating conditions, material compositions and flowrates which does not represent the actual release conditions.

As far as is reasonable, the compositions in each stream are simplified, i.e. isomers are summed together and the C6+ hypothetical materials (KP01, up to KP30) are represented by different heavy alkanes. The following alkanes are selected to represent different ranges of hypothetical materials found in the streams based on their properties:

- KP01 to KP10 are assumed to be C7;
- KP11 to KP20 are assumed to be C10; and
- KP21 to KP30 are assumed to be C20.

Note that the hypothetical materials in the Todd Energy's Methodology Guideline are represented in ST01 to ST30; whereas the hypothetical materials in the HMB provided by the process engineer are represented in KP01 to KP30. The hypotheticals STXX are the same as KPXX [Ref. 19].

The important characteristic of molecular weight is kept close to the actual value to ensure the release rate is representative.

The effects of water cut of the hydrocarbon on fire hazards will be considered to identify the streams that are considered not flammable due to high water content. According to Oil and Gas UK Fire and Explosion Guidance [Ref. 10], for water cuts under 50%, no significant reduction in heat fluxes to engulfed objects can be expected (<10%). However, for water cuts over 50%, the flames are significantly less radiative, and the overall heat flux to an obstacle can be reduced by 40% or more. To be in line with Oil and Gas UK Fire and Explosion Guidance, it is assumed that a mixture remains flammable if it has a water cut of up to 125% (defined as mass of water/ mass of fuel x 100%), although not necessarily capable of supporting a stable flame in the absence of some other supporting mechanisms.

Similarly, increasing concentrations of CO₂ were found to reduce the likelihood of ignition of a methane jet release. At CO₂ concentrations of 22–40% (v/v) it was possible for a self-sustaining flame to exist, but beyond these concentrations a pilot flame was required to aid combustion. Beyond 60% CO₂ the pilot flame had no effect and the mixture was completely inert [Ref. 22].

The average flammability of the mixtures will be calculated by Safeti software, considering the effects of the inert components (e.g., CO₂, N₂ and H₂O).

3.7 Release Scenarios

Release rates will be calculated based on the release hole size and operating pressure. All releases will be modelled at initial process conditions until the entire isolatable inventory has been depleted and will not take account of the depressurisation that occurs over time.

All wellsites have automated ESD on fire detection, and KA-8/18 has automatic ESD on gas detection as well. Hydrocarbon leaks at the wellsites or along the pipelines (other than minor leaks) will lead to pressure and/or liquid level drop at KPS, which will alert the operators to perform a check at the wellsite(s).

Given the proximity to the KPS, operators can generally arrive at the wellsites within 15 minutes. As such, 15 minutes delayed detection will be assumed, and 15 minutes of released inventory will be added. Full bore rupture cases are only considered credible when there is major work on site, and the wellsite would be manned to detect the leak immediately. Hence undetected full bore rupture is not considered credible.

The inventory for well blowout and well release events will be considered as unlimited because they can be supplied from the downhole reservoirs.

The wellsites bunding and drainage systems are designed to contain hazardous materials within the boundaries of the wellsite. Therefore, condensate pools are assumed to remain confined within the site.

Other assumptions to be applied in the QRA include:

- The height of release from all scenarios will be assumed to be at 1 m above ground, although some equipment may be located at the elevation higher than the ground level.
- For wellsite releases, 70% of the releases should be modelled as horizontal releases and 30% of the releases as vertical releases. Well blowout will be modelled as 100% vertical release.
- All outdoor releases are modelled as non-impinged (free) releases and are monitored at the downwind direction.
- A free-field condition is assumed although in real facility situations, multiple obstructions beyond the leak source could shield or deflect the jet fire. Obstructions in the path of the vapour cloud could also alter the concentration of gas in the cloud
- Fire durations are estimated based on the assumption that isolation and shutdown are immediate.
- In estimating piping length, a safety factor of 1.25 will be applied to all lengths measured from the map to account for bends and elevations which could not be determined from the 2D map.
- For liquid releases from pressurised sources, if the rainout is significant then a pool fire will result. If not, a spray fire (equivalent to a jet fire) will result. It is suggested in the Oil and Gas UK Fire and Explosion Guidance [Ref. 10] that for ignited two-phase releases:
 - If the Gas Oil Ratio (GOR) is low, at drive pressures above 10 bar(abs) a spray fire will result;
 - If the GOR is high, at drive pressures above 5 bar(abs) a spray fire will result.

Note: Gas oil ratio is the ratio of gas to oil within the hydrocarbon fluid. A high GOR indicates a high gas content which has implications for the potential for gas fires from a depressurisation and release [Ref. 10].

3.8 Congested Area

A flammable vapour cloud accumulation at congested area(s) is the prerequisite to a vapour cloud explosion (VCE). There is limited equipment at the wellsites, and these areas are generally open with good ventilation expected throughout the year. The possibility of flammable vapour accumulating and developing into subsequent vapour cloud explosions, are considered not credible. Hence, VCE modelling will not be carried out.

3.9 Atmospheric Conditions for Modelling

Meteorological conditions impact the outcomes of release modelling, including downwind flammable and toxic vapour cloud dispersion distance (influenced by atmospheric stability and wind speed), rate of pool vaporisation (ambient temperature), and atmospheric attenuation of radiant heat (temperature and relative humidity).

3.9.1 Wind Speed and Direction

Wind speed and direction data are taken from NIWA’s Cliflo database [Ref. 16] for the Hawera Automatic Weather Station (AWS) to represent the atmospheric conditions at Kapuni. Data for 5-year period from January 2008 to December 2012 are taken, with wind speed and direction measurements taken every hour. The wind rose is shown in Figure 3-2.




Figure 3-2: Hawera AWS Windrose

The following combinations of wind speed and atmospheric stability will be considered in the QRA that represents the typical wind speed conditions around the wellsites:

- 2/F – wind speed of 2 m/s with Pasquill Stability class F – stable, night with moderate clouds and light/moderate wind
- 5/D – wind speed of 5 m/s with Pasquill Stability class D – neutral, little sun and high wind or overcast/windy night
- 10/D – wind speed of 10 m/s with Pasquill Stability class D

For the modelling, wind speed reference height (the height at which the wind impacts a release) will be set at 1 m (i.e., so as to match the release height). The Power Law wind profile will be applied where the wind speed varies with height according to power-law profile.

By consideration of the Pasquill Stability class relationship with day and night and wind speeds, the wind data for use in the QRA model is calculated as shown in Table 3-6.

Table 3-6: Hawera AWS Wind Data

Wind Speed / Pasquill Stability	North	North East	East	South East	South	South West	West	North West	Total
0 - 2 m/s / F	2.1%	1.1%	0.3%	1.4%	0.6%	0.3%	1.7%	1.5%	9.0%

Wind Speed / Pasquill Stability	North	North East	East	South East	South	South West	West	North West	Total
2 - 5 m/s / D	10.1%	5.1%	1.5%	6.9%	3.1%	1.4%	8.2%	7.2%	43.5%
> 5 m/s / D	11.1%	5.6%	1.7%	7.5%	3.4%	1.5%	8.9%	7.9%	47.5%
Total	23.3%	11.8%	3.5%	15.9%	7.1%	3.2%	18.7%	16.5%	100.0%

3.9.2 Ambient Temperature and Relative Humidity

The following ambient temperature and relative humidity as consistent with those used in the KPS QRA [Ref. 18] will be used in the QRA:

- Ambient temperature: 14°C
- Relative humidity: 83%

3.9.3 Solar Radiation

The allowance for solar radiation will not be included in the thermal radiation effects consideration.

3.9.4 Surface Roughness

Safeti cannot take into account the effects of the local undulating topography for the gas dispersion. The surface roughness of 30 mm will be applied, which generally represents an area of “open flat terrain; grass, few isolated objects” to represent the open area of the wellsites.

3.10 Fatality Criteria

The physical effects from these consequences can have different impacts on humans. The variation of harm from different effects is reflected in a parameter known as the harm probability. In this study, human harm relates to high potential for fatality.

3.10.1 Heat Radiation

The method of calculating the probability of fatality for an individual, given known exposure duration and thermal heat radiation levels, is undertaken by using a Probit function. The Probit function is a general formula which takes the same form, but with various constants used. The Probit used for lethality calculations is taken from the TNO Green Book [Ref. 17]. The Probit function is defined as follows:

$$\text{Probit} = -36.38 + 2.56 \ln (t \times q^{4/3})$$

Where:

t = exposure duration in seconds

q = thermal radiation level in W/m²

Safeti calculates the Probit values during the analysis.

An exposure duration of 20 seconds has been used as a base case, although it is noted that personnel are likely to find some form of shielding protection within this time frame.

3.10.2 Flash Fire

If personnel are within the 100% lower flammable limit (LFL) of the gas plume, 100% fatality is assumed. LFL is the lower end of the concentration range over which the flammable mixture of vapour in air can be ignited.

A flash fire occurs when a dispersed cloud of flammable vapour and air mixture is ignited within its flammable regions, causing a wall of flame to spread throughout the flammable region and back to the release point. The flame propagates through the cloud in a manner such that negligible or no damaging overpressure is generated. This flash is almost instantaneous as the flame propagates at high speed through the cloud and back to the source.

An assumption of 100% fatality rate within the footprint of the cloud is conservative and does not allow for potential risk reducing considerations such as:

- uneven mixing of flammable vapour and air in the cloud resulting in uneven propagation of the flame,
- topography,
- sparsely populated rural land use adjoining the site,
- availability of shelter,
- opportunity for escape, and
- clothing worn by persons exposed to the flash fire.

Thermal radiation outside of the flash fire footprint, reduces rapidly and is not sustained due to the instantaneous nature of the event. The potential for fatality outside the flash fire footprint is not considered credible.

3.10.3 BLEVE

Boiling Liquid Expanding Vapour Explosion (BLEVE) is an escalation scenario that occurs as a result of prolonged flame impingement on above ground pressurised vessels containing materials such as liquefied petroleum gas (LPG) or light end hydrocarbon. BLEVE would result in an explosion overpressure together with a fireball and missile generation over some distance. As the fireball tends to drift upward and to avoid double counting, only fatalities from the explosion overpressure effects are considered in this risk assessment. The probability of BLEVE depends on various factors, including the types of flammable material and liquid inventory in the vessel, material of construction of the vessel, types and number of fire protection systems (e.g. relief valves, cooling systems), mechanism of vessel failure (external impact, jet fire impingement or pool fire impingement), etc. Passive Fire Protection (PFP) can be provided on pressurised vessels to minimise the probability of BLEVE. There is no clear guideline or criteria to determine the likelihood of a BLEVE on a pressurised vessel. For this risk assessment, BLEVE will be considered credible if a pressurised vessel containing at least 4 m³ of volatile hydrocarbon (liquid butane or lighter) is exposed to direct flame impingement for 5 minutes or longer.

Liquid volume calculation for the vessels at the wellsites are shown in Table 3-7.

Table 3-7: Kapuni Wellsites Vessels Liquid Volume Estimation

Tag	Description	Diameter (m)	Length / Height (m)	Volume (m ³)	Liquid Level (mm)	Liquid Volume (m ³)
KA-02						
V-201A	HP Knockout	0.686	4.572	1.69	343	0.84
V-204A	Secondary Knockout	0.914	3.048	2.00	457	1.00
V-0202A	LT Separator	1.219	3.810	4.45	1905	2.22
KA-05						
V-0516	KA-5 Desander	0.406	4.572	0.59	406	0.59

Tag	Description	Diameter (m)	Length / Height (m)	Volume (m ³)	Liquid Level (mm)	Liquid Volume (m ³)
KA-19						
V-2154	Wellhead Knockout	1.068	4.572	4.10	534	2.05
KA-8/18						
V-2803	HP Knockout Drum	0.685	4.570	1.68	342.5	0.84
V-9010	Wellstream Separator (2 phase)	1.600	4.500	9.05	800	4.52
V-9020	Wellstream Separator (2 phase)	1.600	4.500	9.05	800	4.52
V-2808	LT Separator	1.830	5.640	14.83	915	7.42
V-2804	Low Temperature Separator	1.220	3.810	4.45	1905	2.23
V-2805	Secondary Knockout	915	3.050	2.01	457.5	1.00

Based on the table, the liquid volume for the KA-8/18 Wellstream Separators (V-9010 & V-9020) and LT Separator (V-2808) might be greater than 4 m³. However, based on the Heat and Material Balance, the composition of the liquid sections from the Wellstream Separators is mainly water (approx. 88 vol%), and the liquid from the LT Separator is mostly heavy hydrocarbons with volatile hydrocarbons making up only 15 vol% of the total composition. Therefore, it is considered that all vessels in Kapuni Wellsite do not have BLEVE potential.

3.10.4 Toxic Effects

Fatality probability when exposed to toxic gas as a function of exposure concentration and duration can be calculated by using a probit function of the form given below:

$$\text{Probit} = a + b \ln(C^n \times t)$$

where:

t = exposure duration in minutes

C = concentration in ppm

a, b and n = material specific probit constants

Toxic effect from methanol will be considered in the QRA. UK HSE gives the following toxic load values for methanol:

- SLOF = 8.02×10^5 ppmⁿ · min (1% fatality probability)
- SLOD = 2.67×10^6 ppmⁿ · min (50% fatality probability)

By solving the simultaneous equation, the other constants a and b can be calculated. The probit constants for methanol are:

$$a = -23.67$$

$$b = 1.94$$

$$n = 1$$

3.11 Risk Criteria

Risk is the combination of the likelihood and consequence of such accidents. It is defined as the probability of a specific adverse event occurring in a specific period or in specified circumstances. The likelihood may be expressed either as a frequency (i.e. the rate of events per unit time) or a probability (i.e. the chance of the event occurring in specified circumstances). The consequence is the degree of harm caused by the event.

Escape and evacuation fatalities are generally not considered for an onshore plant due to the open site layout and personnel’s ready accessibility to the muster area. Hence, only immediate fatalities will be taken into account when performing the risk analysis to onsite workers.

Key deliverable for this study is the location specific individual risk (LSIR) in the form of risk contour. LSIR is the risk of fatality at a point in space to a hypothetical individual at a location for 365 days per year, 24 hours a day, unprotected and unable to escape. In real situation, people do not constantly remain in one location, so this risk value does not provide a realistic representation of the true level of risk.

However, this value allows different areas to be compared on the same basis and is a useful measure for establishing the most hazardous areas of the plant, or for the comparison of facility risk profiles against standard criteria. The LSIR can be expressed as follows:

$$LSIR = \sum F \times P$$

Where:

F = Frequency of an event outcome per year

P = Probability of death due to the event at the location

∑ = Sum over all modelled events

LSIR is usually presented as risk contours or by defining risks at selected locations (e.g. site boundary).

As there are no standard risk criteria which have been developed for the NZ context, this deliverable will be assessed against the suggested risk criteria in the NSW Hazardous Industry Planning Advisory Paper No. 4 (HIPAP4) “Risk Criteria for Land Use Planning” as shown in Table 3-8.

Table 3-8: HIPAP 4 Individual Fatality Risk criteria

Land Use	Risk Criteria Adopted (per annum)	Interpretation for QRA
Hospitals, schools, childcare facilities, old age housing	0.5×10^{-6} (or 5×10^{-7}) (1 in 2 million)	5×10^{-7} risk contour should not extend to these areas
Residential, hotels, motels, tourist resorts	1×10^{-6} (1 in 1 million)	1×10^{-6} risk contour should not extend to these areas
Commercial developments including retail centres, offices and entertainment centres	5×10^{-6} (1 in 200,000)	5×10^{-6} risk contour should not extend to these areas
Sporting complexes and active open space	10×10^{-6} (or 1×10^{-5}) (1 in 100,000)	1×10^{-5} risk contour should not extend to these areas
Industrial	50×10^{-6} (or 5×10^{-5}) (1 in 20,000)	5×10^{-5} risk contour should, as a target, be contained within the boundaries of the industrial site where applicable

NSW HIPAP 4 states that where these criteria are initially exceeded, commercial and industrial land development may be appropriate where mitigating measures can be implemented to reduce risk exposure to less than the target individual fatality risk level.

4. REFERENCES

1. QRA Results – KA-4/14 & KA-13 Wellsites Memorandum, 620053-MMO-R0001, dated 17 July 2019.
2. Safety Case – Kapuni Production Station, Doc. No. NPL649981, Rev. 1, January 2018.
3. Email correspondence with Roisin Johnson, Mike Brophy and Rafeal Moreno (Todd Energy) and Yvette Lee (Worley New Zealand), Sub.: RE: 610114 Kapuni Wellsites QRA Clarification - KA-7 dated 6 May 2020.
4. Email correspondence with Roisin Johnson, Mike Brophy and Rafeal Moreno (Todd Energy) and Yvette Lee (Worley New Zealand), Sub.: RE: KA-15 well flow check dated 18 May 2020.
5. Todd Energy Fire and Gas Analysis and Quantitative Risk Assessment Methodology Guideline, NZ-1005-TECD721654, Rev. 0.
6. DNV GL Safeti software package version 8.22.
7. IOGP Risk Assessment Data Directory, Process Release Frequencies (OGP 434-1), September 2019.
8. IOGP Risk Assessment Data Directory, Ignition Probabilities (OGP 434-6), September 2019.
9. Email correspondence with Rebekah Heperi (Todd Energy) and Yvette Lee (Worley), Sub.: 610114 Wellsites QRA information request - heat and material balance dated 27 May 2020.
10. Oil and Gas UK, Fire and Explosion Guidance, Issue 1 May 2007.
11. IOGP Risk Assessment Data Directory, Blowout Frequencies, September 2019.
12. SINTEF Offshore Blowout Database website, <https://www.sintef.no/en/projects/sintef-offshore-blowout-database/>
13. New South Wales Hazardous Industry Planning Advisory Paper No. 4 (HIPAP4), Risk Criteria for Land Use Safety Planning, January 2011.
14. Australian Standard, The Storage and Handling of Flammable and Combustible Liquids, AS 1940:2017.
15. Pressure-relieving and Depressuring Systems, API Standard 521, 6th Edition, January 2014.
16. New Zealand National Climate Database (<http://cliflo.niwa.co.nz/>).
17. Methods for the Determination of Possible Damage to People and Objects Resulting from Release of Hazardous Materials ('TNO Green Book').
18. Kapuni Production Station, Quantitative Risk Assessment Report, 610052-RPT-R0002, Rev. 1, April 2020.
19. Email correspondence between Mike Brophy (Todd Energy) and Yvette Lee (Worley New Zealand), Sub.: RE: KA-18 Questions dated 13 July 2020.
20. Email correspondence between Mike Brophy (Todd Energy) and Yvette Lee (Worley New Zealand), Sub.: RE: 610114 Wellsites QRA information request - heat and material balance dated 13 July 2020.
21. Discussion between Mike Brophy and Yvette Lee on 31 July 2020.
22. Flammability of Hydrocarbon / CO₂ mixtures: Part 1, Ignition and Explosion Characteristic, Symposium Series No. 156, 2011.
23. TNO Purple Book, Guidelines for Quantitative Risk Assessment, December 2005.